



Holtec Center, 555 Lincoln Drive West, Marlton, NJ 08053

Telephone (856) 797-0900

Fax (856) 797-0909

BY FAX AND OVERNIGHT MAIL

February 28, 2000

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: USNRC Docket No. 71-9261; TAC No. L22085
HI-STAR 100 Transportation CoC 9261
License Amendment Request 9261-1, Supplement 3

References: 1. Holtec Project 5014
2. Holtec Letter to NRC dated November 24, 1999, LAR 9261-1

Dear Sir:

As committed during our telephone conversation last Friday, we are pleased to provide clarifying information regarding the uranium mass limits for the fuel authorized for loading into the HI-STAR 100 spent fuel storage system.

The criticality analyses are not affected by the maximum allowed design uranium masses shown in the Certificate of Compliance (CoC), or by the proposed changes to these masses. The uranium mass limits in the CoC are determined from the shielding analysis, and are specified as bounding values for groups of fuel classes (e.g. all B&W 15x15). The criticality analyses are based on an independent bounding assumption of a fuel stack density of 96.0% of the theoretical fuel density of 10.96 g/cm³. The fuel stack density is approximately equal to 98% of the pellet density. Therefore, while the pellet density of some fuels might be slightly greater than 96% of theoretical, the actual stack density will be less. For some fuel classes, this density assumption results in a uranium mass for the criticality analyses which is below the value shown in the CoC. However, this only indicates the conservatism of the shielding analysis for these classes. The criticality analyses are still valid and bounding for all classes, due to the density assumption stated above, which is valid for current and future fuel assemblies.

For the HI-STORM 100 System, the following clarification was added to the TSAR criticality chapter in Revision 6 (fourth bullet on TSAR page 6.1-5) in relation to the conservative nature of the fuel density assumption:

"The fuel stack density is conservatively assumed to be 96% of theoretical (10.522 g/cm³) for all criticality analyses. The fuel stack density is approximately equal to 98% of the pellet density.

41MSS01Publ/2



HOLTEC
INTERNATIONAL

Holtec Center, 555 Lincoln Drive West, Marlton, NJ 08053

Telephone (856) 797-0900

Fax (856) 797-0909

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Document ID 5014373
Page 2 of 3

Therefore, while the pellet density of some fuels might be slightly greater than 96% of theoretical, the actual stack density will be less."

We propose to add the same text to the HI-STAR SAR, page 6.1-4, as part of the revision to that document to be submitted after the amendment is approved.

If you have any questions or require additional information, please contact us.

Sincerely,

Approval:

Brian Gutherman, P.E.
Licensing Manager

K.P. Singh, Ph.D, P.E.
President and CEO

cc: Mr. Mark Delligatti, USNRC
Ms. Marissa Bailey, USNRC

Document ID: 5014373

Technical Concurrence:

Dr. Stefan Anton (Criticality Evaluation)

Distribution:

Recipient

Affiliation

Mr. David Bland
Mr. Ken Phy
Mr. J. Nathan Leech
Dr. Max DeLong

Southern Nuclear Operating Company
New York Power Authority
Commonwealth Edison
Private Fuel Storage



Holtec Center, 555 Lincoln Drive West, Marlton, NJ 08053

Telephone (856) 797-0900

Fax (856) 797-0909

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Document ID 5014373
Page 3 of 3

Distribution (cont'd):

| | |
|----------------------|---|
| Mr. Stan Miller | Vermont Yankee Nuclear Power Corporation |
| Mr. David Larkin | Energy Northwest |
| Mr. Bruce Patton | Pacific Gas & Electric – Diablo Canyon |
| Mr. Mark Smith | Pacific Gas & Electric – Humboldt Bay |
| Mr. Rodney Pickard | American Electric Power |
| Mr. Eric Meils | Wisconsin Electric Power Company |
| Mr. Paul Plante | Maine Yankee Atomic Power Company |
| Mr. Jeff Ellis | Southern California Edison |
| Mr. Darrell Williams | Entergy Operations – Arkansas Nuclear One |
| Mr. Joe Andrescavage | GPUN – Oyster Creek Nuclear Power Station |
| Mr. Ron Bowker | IES Utilities |
| Mr. William Swantz | Nebraska Public Power District |
| Mr. Chris Kudla | Entergy Operations – Millstone Unit 1 Decommissioning |
| Mr. Keith Waldrop | Duke Power Company |
| Mr. Matt Eyre | PECO Energy |
| Mr. Al Gould | Florida Power & Light |
| Dr. Seymour Raffety | Dairyland Power |
| Mr. John Sanchez | Consolidated Edison Company |
| Ms. Kathy Picciott | Niagara Mohawk Power Corporation |
| Mr. John Donnell | Private Fuel Storage, LLC (SWEC) |
| Dr. Stanley Turner | Holtec International, Florida Operations Center |