



July 14, 2000

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Document Control Manager:

Pursuant to the requirements of Donald C. Cook Nuclear Plant Unit 2 Technical Specification 6.9.1.8, the attached Monthly Operating Report for June 2000 is submitted.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert C. Godley".

R. C. Godley
Regulatory Affairs Director

RCG/mbd

Attachments

c: ANI Nuclear Engineering Department
A. C. Bakken, III
G. T. Gaffney – Canton
D. R. Hahn – Department of Health
S. Hamming – Department of Labor
RAF Harris
INPO Records Center
B. Lewis – McGraw-Hill Companies
D. H. Malin
NDM
NRC Project Manager – NRR
NRC Region III
NRC Resident Inspector
D. W. Paul – Lancaster
J. E. Pollock
R. P. Powers
B. A. McIntyre
M. W. Rencheck
W. H. Schalk

IE 24

NRC OPERATING DATA REPORT

DOCKET NO. 50 - 316
DATE July 11, 2000
COMPLETED BY J. W. Minor
TELEPHONE 616-465-5901

OPERATING STATUS

1. Unit Name D. C. Cook Unit 2
2. Reporting Period June - 2000
3. Licensed Thermal Power (MWt) 3411
4. Name Plate Rating (Gross MWe) 1133
5. Design Electrical Rating (Net MWe) 1090
6. Maximum Dependable Capacity (GROSS MWe) 1100
7. Maximum Dependable Capacity (Net MWe) 1060

Notes:

8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons: _____

9. Power Level to Which Restricted, If Any (Net MWe): _____

10. Reasons For Restrictions, If Any: _____

	This Month	Year-to-Date	Cumulative
11. Hours in Reporting Period	720.0	4368.0	197658.0
12. No. of Hrs. Reactor Was Critical	197.5	197.5	121968.5
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator on Line	141.0	141.0	118294.4
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Gen. (MWH)	276864.0	276864.0	366284514.4
17. Gross Electrical Energy Gen. (MWH)	82150.0	82150.0	118666790.0
18. Net Electrical Energy Gen. (MWH)	77489.0	77489.0	114335268.0
19. Unit Service Factor	19.6	3.2	60.5
20. Unit Availability Factor	19.6	3.2	60.5
21. Unit Capacity Factor (MDC Net)	10.2	1.7	55.1
22. Unit Capacity Factor (DER Net)	9.9	1.6	53.7
23. Unit Forced Outage Rate	80.0	96.8	26.0

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration): _____
None

25. If Shut Down At End of Report Period, Estimated Date of Startup: _____

26. Units in Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast

Achieved

DOCKET NO.	50 - 316
UNIT NAME	D.C. Cook Unit 2
DATE	July 11, 2000
COMPLETED BY	J. W. Minor
TELEPHONE	616-465-5901

AVERAGE DAILY POWER LEVEL (MWe-Net)

June 2000

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
6/1/2000	0	6/16/2000	0
6/2/2000	0	6/17/2000	0
6/3/2000	0	6/18/2000	0
6/4/2000	0	6/19/2000	0
6/5/2000	0	6/20/2000	0
6/6/2000	0	6/21/2000	0
6/7/2000	0	6/22/2000	0
6/8/2000	0	6/23/2000	0
6/9/2000	0	6/24/2000	0
6/10/2000	0	6/25/2000	196
6/11/2000	0	6/26/2000	326
6/12/2000	0	6/27/2000	356
6/13/2000	0	6/28/2000	621
6/14/2000	0	6/29/2000	812
6/15/2000	0	6/30/2000	917

DOCKET NO.	50 - 316
UNIT NAME	D.C. Cook Unit 2
DATE	July 11, 2000
COMPLETED BY	MB Depuydt
TELEPHONE	616-465-5901
PAGE	1 of 1

UNIT SHUTDOWNS AND POWER REDUCTIONS – June 2000

NO.	DATE	TYPE ¹	DURATION HOURS	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT NO.	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
335	010798	F	522.5	N/A	N/A	N/A	The unit returned to service June 25, 2000 after a shutdown to resolve design basis questions identified during the NRC Architect and Engineering (AE) Inspection.		

1 TYPE:

F: Forced
S: Scheduled

2 REASON:

A: Equipment Failure (Explain)
B: Maintenance or Test
C: Refueling
D: Regulatory Restriction
E: Operator Training and
License Examination
F: Administrative
G: Operational Error (Explain)
H: Other (Explain)

3 METHOD:

1: Manual
2: Manual Scram
3: Automatic Scram
4: Other (Explain)

4 SYSTEM:

Exhibit G - Instructions
for preparation of data
entry sheets for Licensee
Event Report (LER) File
(NUREG 0161)

5 COMPONENT:

Exhibit I: Same Source