



W. R. McCollum, Jr.
Vice President

Duke Energy Corporation

Oconee Nuclear Station
7800 Rochester Highway
Seneca, SC 29672
(864) 885-3107 OFFICE
(864) 885-3564 FAX

July 24, 2000

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Emergency Plan Implementing Procedures Manual
Volume C Revision 2000-07

Please find attached for your use and review copies of the revision to the Oconee Nuclear Station Emergency Plan: Volume C Revision 2000-07, July, 2000.


This revision is being submitted in accordance with 10 CFR 50-54(q) and does not decrease the effectiveness of the Emergency Plan or the Emergency Plan Implementing Procedures.

This revision was reviewed by Emergency Planning before being submitted to Document Management for issue but was not returned to Emergency Planning after final signature for timely distribution. This delay has resulted in the document not meeting the 30 day requirement.

Any questions or concerns pertaining to this revision please call Mike Thorne, Emergency Planning Manager at 864-885-3210.

By copy of this letter, two copies of this revision are being provided to the NRC, Region II, Atlanta, Georgia.

Very truly yours,



W. R. McCollum, Jr.
VP, Oconee Nuclear Site

xc: (w/2 copies of attachments)
Mr. Luis Reyes,
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
61 Forsyth St., SW, Suite 24T23
Atlanta, GA 30303

w/copy of attachments
Mr. Steven Baggett
Rockville, Maryland

(w/o Attachments, Oconee Nuclear Station)

AD45

July 24, 2000

OCONEE NUCLEAR SITE
INTRASITE LETTER

SUBJECT: Emergency Plan Implementing Procedures
Volume C, Revision 2000-07

Please make the following changes to the Emergency Plan Implementing Procedures Volume C by following the below instructions.

REMOVE

Cover Sheet Rev. 2000-06

Table of Contents - Page 2

Engineering Directive
03/08/99

ADD

Cover Sheet Rev. 2000-07

Table of Contents - Page 2

Engineering Directive - 04/12/00

DUKE POWER

EMERGENCY PLAN IMPLEMENTING PROCEDURES VOLUME C



APPROVED:

W. W. Foster Jr.

W. W. Foster, Manager
Safety Assurance

7/24/00

Date Approved

7/24/00

Effective Date

VOLUME C
REVISION 2000-07
JUNE, 2000

VOLUME C
TABLE OF CONTENTS

RP/0/B/1000/21	Operations Interface (EOF) - (07/06/98)
RP/0/B/1000/22	Procedure for Site Fire Damage Assessment and Repair - (06/04/96)
RP/0/B/1000/24	Protective Action Recommendations (11/10/99)
RP/0/B/1000/28	Communications & Community Relations World of Energy Emergency Response Plan - (02/17/97)
RP/0/B/1000/29	Fire Brigade Response - (12/12/96)
RP/0/B/1000/31	Oconee Nuclear Station Joint Information Center Emergency Response Plan - (06/12/00)
SR/0/B/2000/001	Standard Procedure for Public Affairs Response to the Emergency Operations Facility - (03/23/00)
Business Management	Business Management Emergency Plan - (03/29/00)
C&F Functional Area Directive 102	C&F Emergency Response Plan - ONS Specific - (02/02/2000)
Engineering Directive 5.1	Engineering Emergency Response Plan - (04/12/00)
Human Resources Procedure	ONS Human Resources Emergency Plan - (04/26/00)
Radiation Protection Manual Section 11.3	Off-Site Dose Assessment and Data Evaluation (04/06/99)
Radiation Protection Manual Section 11.7	Radiation Protection Environmental Monitoring for Emergency Conditions - (04/15/99)
Safety Assurance Directive 6.1	Safety Assurance Emergency Response Organization - (11/28/94)
Safety Assurance Directive 6.2	Safety Assurance Contingency Plan - (03/27/00)
Training Division	Training Division Emergency Response Guide DTG-007 (02/01/2000)

Revision 2000-07
July, 2000

INFORMATION ONLY

Engineering Directive 5.1

Review Ray Waterman
Emergency Planning

Approval W. K. M. J. A. L.
Engineering Manager

Original Date 5/27/92

Revised Date 4/12/00

DUKE POWER COMPANY OCONEE NUCLEAR STATION ENGINEERING EMERGENCY RESPONSE PLAN

1.0 Purpose

The purpose of this directive is to identify The Engineering Division responsibilities during an emergency at Oconee Nuclear Station. This directive is an implementation directive to the site emergency plan. Upon revision, a copy of this directive must be forwarded to Emergency Planning within three (3) working days of its approval.

2.0 References

Oconee Nuclear Site Emergency Response Plan

3.0 Definitions

- 3.1 Essential personnel: Personnel needed to mitigate the emergency as determined by the EOF, TSC, or OSC.
- 3.2 Engineering Emergency Response Person: Engineering personnel assigned to those positions in the EOF, TSC, or OSC listed in Sections 6.0 and 7.0 of this directive.

4.0 Responsibilities

- 4.1 Engineering Division Manager : The Engineering Division Manager shall be responsible for the implementation of this directive. During a site assembly he/she shall be responsible to account for all engineering personnel to the Security Shift Supervisor or designee.
- 4.2 Engineering Group Manager: During a site assembly each Engineering Group Manager shall be responsible to account for each person in his/her Group to the Engineering Division Manager or designee.
- 4.3 Engineering Section Manager: During a site assembly each Engineering Section Manager shall be responsible to account for each person on his/her section to his/her Engineering Group Manager or designee.
- 4.4 Engineering Supervisor: During a site assembly each Engineering Supervisor shall be responsible to account for each person on his/her team to his/her Engineering Group Manager or designee.
- 4.5 Engineering Emergency Response Person: When notified of EOF/TSC/OSC activation, the engineering emergency response persons will report to their assigned position in the EOF, TSC, or OSC. Notification during normally scheduled work hours will be by an announcement on the station PA system. Notification during unscheduled work hours will be by pager or Community Alert Network using the following:

PAGER CODES:

Blue Delta – EOF/TSC/OSC activated for a drill.

Blue Echo – EOF/TSC/OSC activated for an emergency.

NOTE: During flooding/dam failure/earthquake conditions assume bridges may be impassable to reach emergency facilities.

Blue Delta Bridges – Pager message used when bridges may be impossible and EOF/TSC/OSC activation is needed.

Blue Echo Bridges – Pager message used when EOF/TSC/OSC activated for an emergency and the bridges may be impassable to reach emergency facilities.

ACCESS CODE FOR THE COMMUNITY ALERT NETWORK: 1,2,3,4.

Each engineering emergency response person will carry a pager which will be turned on when leaving the station and left on at all times. He/she will remain fit for duty at all times while serving duty as an engineering emergency response person.

- 4.6 Employee: During a site assembly each employee will proceed to his/her site assembly location (generally the person's work area) and report to his/her supervisor within the specified time.

5.0 SITE ASSEMBLY AND EVACUATION

5.1 Site Assembly:

- 5.1.1 When a site assembly is commenced, a warbling tone will be broadcast over the Station PA system and the outdoor Site Assembly Horn will sound. All Engineering personnel shall immediately proceed to their site assembly location and report to his/her supervisor. Any person who cannot report to his/her designated area within eight (8) minutes of the commencement of the site assembly shall contact his/her supervisor by telephone for assembling instructions.
- 5.1.2 Personnel inside the Protected Area (PA) who must assemble at a location inside the PA or who cannot make it to their assembly point outside the PA shall card in at the nearest card reader, notify their supervisor of their location, and wait for further instructions.
- 5.1.3 Personnel working in an RCZ in protective clothing should leave the work area and go to the appropriate Change Room. Once in the Change Room area, they should card in (swipe their security badge) and contact their supervisor for accountability. Personnel should then follow the instructions of the RP personnel in the Change Room or RCZ.
- 5.1.4 Each Engineering Section Manager/Supervisor shall account for all personnel in his/her Section/Team and report the result to his/her Engineering Group Manager or designee. Unaccounted for personnel shall

be reported by name. This report should be made within 10 minutes of the commencement of the site assembly. Do NOT leave phone mail messages when reporting.

5.1.5 Each Engineering Group Manager shall account for all personnel in his/her Group and report the result to the Engineering Division Manager or designee. Unaccounted for personnel shall report by name. This report should be made within 15 minutes of the commencement of the site assembly. Do NOT leave phone mail messages when reporting.

5.1.6 The Engineering Division Manager or designee shall account for all Engineering personnel and report the result to the Security Shift Supervisor or designee. Do not report unaccounted for personnel by name at this time. This report shall be made within 20 minutes of the commencement of the site assembly.

5.1.7 During unscheduled work hours, each employee on site shall report to his/her assigned assembly area. If a Supervisor is present, the supervisor will call directly to the Security Shift Supervisor and report accountability within 15 minutes. If no Supervisor is present, the senior employee (or lone employee) will call the Security Shift Supervisor directly and report accountability.

5.1.8 If working in an RCZ in protective clothing, proceed to the appropriate Change Room. Report to the individual in charge of the change room. If no one is in charge of the change room, call the Security Shift Supervisor directly and report accountability.

5.2 Site evacuation instructions

Initial Notification:

5.2.1 Site evacuation will be activated only after a site assembly. When it has been deemed necessary to evacuate the site, an announcement will be made on the PA system and a Lotus Note sent to group evacuation coordinators giving instructions for an evacuation.

- 5.2.2 The Engineering Evacuation Coordinator monitors LOTUS Notes during an emergency, passes evacuation information on to Engineering group administrative assistants, and gets acknowledgement back that the information has been received.

The Evacuation Coordinator also lets Engineering Managers know that they need to provide 24 hour coverage for their areas during the emergency, gets that information from the managers, and relays it to the MSE manager in the TSC.

- 5.2.3 The Engineering Section Manager/Supervisors will determine which, if any, essential personnel should not evacuate. This will be based on the needs communicated from the TSC or OSC.
- 5.2.4 The Engineering Section Managers/Supervisors, based on needs communicated from the TSC or OSC, will establish shift lead persons and a continuous 24 hour staffing schedule, and communicate this schedule to all personnel in their section/team.
- 5.2.5 The Engineering Section Managers/Supervisors will give evacuation instructions to all personnel in their sections/teams and implement the evacuation plan.

Accountability Notification:

- 5.2.6 The Engineering Section Managers/Supervisors will report to their respective Engineering Group Manager or designee if transportation assistance is needed. They will report which personnel, if any, have been deemed essential and their location along with their shift lead persons and continuous 24 hour staffing schedule to the Engineering Evacuation Coordinator and their respective Group Manager.
- 5.2.7 The Engineering Sections Managers/Supervisors or designee will report the Status of their sections/teams to the Group Evacuation Coordinator.

NOTE: Subsequent Evacuations will be coordinated from the designated relocation

area(s) per NSD 114.

6.0 Technical Support Center

- 6.1 The Technical Support Center (TSC) is located on the Unit 2 side of the Units 1&2 control room. When reporting to the TSC, pick up MGs, TLDs, go to the Unit 1 or 2 Control Room Lobby, and frisk for possible contamination before entering the Control Room.

EMERGENCY RESPONSE SRWP NUMBER: 33 (For drills and emergency response)

If evacuation from the TSC becomes necessary, report to the alternate TSC on the third floor, room 316, of the Oconee Office Building. Assume the same duties as in the Primary TSC.

6.2 Technical Assistant to Emergency Coordinator:

6.2.1 The Technical Assistant to Emergency Coordinator will report to the Emergency Coordinator. This position is staffed by the Mechanical Systems and Equipment Section (MSE). This position should be staffed within 75 minutes of the emergency declaration.

6.2.2 The Technical Assistant to Emergency Coordinator's main duty will be to maintain a log of activities in the TSC. This log will include systems and components status, decisions, and announcements made in the TSC. The Technical Assistant to Emergency Coordinator will also perform any other duties assigned by the Emergency Coordinator.

6.3 TSC/OSC Liaison

6.3.1 The TSC/OSC Liaison will report to the Emergency Coordinator. This position is staffed by Engineering within 75 minutes.

6.3.2 The TSC/OSC Liaison is responsible for communicating task priority and status information between the TSC and OSC.

6.4 Technical Assistant to TSC/OSC Liaison:

6.4.1 The Technical Assistant to TSC/OSC Liaison will report to the TSC/OSC Liaison. This position is staffed by Modification Engineering. Individuals staffing this position will be contacted by the Community Alert Network (CAN) system.

6.4.2 The Technical Assistant to TSC/OSC Liaison will maintain the Plant status board in the TSC. The Technical Assistant to TSC/OSC Liaison will perform any other duties as assigned by the TSC/OSC Liaison.

6.5 Nuclear Engineer:

6.5.1 Nuclear Engineering will provide personnel for this position. This position is required by regulation with the person being available in the TSC within 75 minutes of the emergency declaration. This person is required to be in place prior to Control Room turnover to the TSC. The Nuclear Engineer will report to the Mechanical Systems Engineering Manager in the TSC.

6.5.2 A second person from Nuclear Engineering will be called by the Community Alert Network System.

6.5.3 The Nuclear Engineer(s) will provide engineering support and recommendations in the following areas:

1. Reactor core physics
2. Shutdown margin calculations
3. Transient assessment functions via the transient monitors
4. Safety review function
5. Core damage assessment.

6.6 Mechanical Systems and Equipment Manager:

6.6.1 The Mechanical Systems and Equipment Manager/alternate should report to the TSC within 75 Minutes of emergency declaration and report to the Emergency Coordinator. The Mechanical Systems and Equipment Section is responsible for assuring this position is filled.

6.6.2 The Mechanical Systems and Equipment Manager/alternate will be responsible for providing engineering support required by the TSC. He/she will be responsible for resolving mechanical systems and

equipment engineering problems. Also he/she will assure that any needed mechanical systems engineering personnel are contacted and given instruction on the necessary actions to be taken.

- 6.6.3 The Mechanical Systems and Equipment Manager will be responsible for making contact with the Accident Assessment Team in the Corporate Office to provide additional assessment expertise to the Technical Support Center.

6.7 Offsite Dose Assessment

- 6.7.1 The TSC Dose Assessment Liaison will report to the Emergency Coordinator in the TSC. He/she will be responsible for providing offsite Dose Assessment as needed and is to report within 45 minutes of the emergency classification.
- 6.7.2 The Offsite Dose Assessors report to the TSC Dose Assessment Liaison within 75 minutes of the emergency classification and provide dose assessment as needed.

7.0 Operational Support Center:

- 7.1 The Operational Support Center (OSC) is located at the back of the Unit 3 Control Room. When reporting to the OSC, pick up MGs, TLDs, go to the Unit 3 Control Room Elevator Lobby, and frisk for possible contamination before entering the Control Room.

EMERGENCY RESPONSE SRWP NUMBER: 33 (For drills and emergencies)

- 7.2 If evacuation from the OSC becomes necessary, report to the alternate OSC located on the third floor, room 316A, of the Oconee Office Building. Assume the same duties as in the Primary OSC.

- 7.3 Equipment Engineering Support for OSC:

- 7.3.1 The CEN Engineering Support duty person is required to report to the OSC within 75 minutes of emergency declaration. This position will report to the OSC Manager.
- 7.3.2 CEN Engineering Support will be responsible for providing Electrical Engineering support for any work performed by the OSC. Should any Mechanical/Civil Engineering needs arise from the OSC, this person will inform the appropriate party.

8.0 Emergency Operations Facility:

- 8.1 The Emergency Operations Facility (EOF) is located in Clemson on Isaqueena Trail next to Duke's Southern Operation Center.

8.2 Offsite Dose Assessment:

- 8.2.1 The Offsite Dose Assessment persons will report to the Radiological Assessment Manager in the EOF. They will be responsible for providing Offsite Dose Assessment as needed.

8.3 Technical Briefers:

- 8.3.1 The Technical Briefers will be notified as needed by the Joint Information Center (located at the EOF). They will report to the Technical Briefers Section Head in the Joint Information Center.
- 8.3.2 The Technical Briefers will be responsible for reading news releases or predeveloped messages for technical accuracy and responding to calls by following the rumor control procedure.
- 8.3.3 The Technical Briefers will keep the Technical Briefer Section Head informed of calls being received and assist in coordinating activities as needed.
- 8.3.4 The Technical Briefer position is filled by persons from across the organization who possess the skills needed.