

July 27, 2000

LICENSEE: ENERGY NORTHWEST
FACILITY: WNP-2
SUBJECT: SUMMARY OF MEETING HELD ON JUNE 26, 2000, TO DISCUSS A
PROPOSED SURVEILLANCE REQUIREMENT INTERVAL EXTENSION

On June 26, 2000, the NRC staff met with representatives of Energy Northwest to discuss their plan to submit a license amendment to extend six technical specifications surveillance requirements from 18 months to 24 months. The meeting handouts are located in ADAMS under accession number ML003726734. The meeting was attended by Messrs. Paul Inserra and Fred Schill from Energy Northwest and Messrs. Stephen Dembek, Jack Cushing and Hukam Garg from the NRC.

WNP-2 is in transition from an 18-month fuel cycle to a 24-month fuel cycle and the surveillance requirements that are performed every 18 months when the plant is in a refueling outage will need to be extended to every 24 months. Energy Northwest and the staff agreed that it would improve the process if a meeting was held and the staff could provide guidance to Energy Northwest's prior to their proposed submittal.

Mr. Inserra stated that most 18-month surveillance requirements can be performed safely during power operations, and therefore WNP-2 requires extensions for only 6 surveillance requirements in addition to the 2 already submitted.

Mr. Schill said the approach that Energy Northwest plans to take follows the guidance provided in Generic Letter (GL) 91-04, "Changes in Technical Specifications Surveillance Intervals to Accommodate a 24 Month Fuel Cycle." Mr. Schill stated that they plan to use the Electric Power Research Institute report EPRI TR-10335, "Guidelines for Instrument Calibration Extension/Reduction Programs," for instruments susceptible to instrument drift.

Mr. Garg stated that the staff has issued an evaluation of the EPRI report by letter dated December 1, 1997. The staff's evaluation contains guidance that would be useful in the preparation of Energy Northwest's submittal. Also, the assumption of no time dependency of instrument drift based on simple regression analysis is not acceptable. To determine time dependency, the change in the standard deviation of drift must also be analyzed.

July 27, 2000

Energy Northwest thanked the staff for providing guidance for their submittal.

/RA/

Jack Cushing, Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-397

cc: See next page

July 27, 2000

Energy Northwest thanked the staff for providing guidance for their submittal.

/RA/

Jack Cushing, Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-397

cc: See next page

DISTRIBUTION:

Hard Copy:

PUBLIC

PDIV-2 Reading

E-Mail:

JZwolinski/SBlack (RidsNrrDlpm)

SRichards (RidsNrrDlpmLpdiv)

OGC (RidsOgcRp)

ACRS (RidsAcrsAcnwMailCenter)

JCushing (RidsNrrPMJCushing)

EPeyton (RidsNrrLAEPeyton)

ERodrick

GTracy

LBrown

HGarg

LSmith, Region IV

Accession No: ML003735934

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	JCushing	EPeyton	JDohohew for SDembek
DATE	07/27/00	07/27/00	07/27/2000

OFFICIAL RECORD COPY

WNP-2

cc:

Mr. Greg O. Smith (Mail Drop 927M)
Vice President, Generation
Energy Northwest
P. O. Box 968
Richland, WA 99352-0968

Mr. Albert E. Mouncer (Mail Drop 1396)
Chief Counsel
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Ms. Deborah J. Ross, Chairman
Energy Facility Site Evaluation Council
P. O. Box 43172
Olympia, WA 98504-3172

Mr. D. W. Coleman (Mail Drop PE20)
Manager, Regulatory Affairs
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Mr. Paul Inserra (Mail Drop PE20)
Manager, Licensing
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Chairman
Benton County Board of Commissioners
P.O. Box 69
Prosser, WA 99350-0190

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 69
Richland, WA 99352-0069

Mr. Rodney L. Webring (Mail Drop PE08)
Vice President, Operations Support/PIO
Energy Northwest
P. O. Box 968
Richland, WA 99352-0968

Thomas C. Poindexter, Esq.
Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Mr. Bob Nichols
Executive Policy Division
Office of the Governor
P.O. Box 43113
Olympia, WA 98504-3113

Ms. Lynn Albin
Washington State Department of Health
P.O. Box 7827
Olympia, WA 98504-7827

Mr. J. V. Parrish
Chief Executive Officer
Energy Northwest
P.O. Box 968 (Mail Drop 1023)
Richland, WA 99352-0968