



Palo Verde Nuclear
Generating Station

William E. Ide
Vice President
Nuclear Production

TEL (623) 393-6116
FAX (623) 393-6077

Mail Station 7602
P.O. Box 52034
Phoenix, AZ 85072-2034

035-00609WEI/JDF
August 8, 2000

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, DC 20555

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Docket Nos. STN 50-528/529/530
Monthly Operating Reports for JULY 2000**

Enclosed are the Monthly Operating Reports for JULY 2000, prepared and submitted pursuant to Specification 6.9.1.6 of Appendix A (Technical Specifications) to the PVNGS Units 1, 2, and 3 Operating Licenses.

By copy of this letter, Arizona Public Service Company is also forwarding the Monthly Operating Reports to the Regional Administrator, NRC Region IV and the NRC Resident Inspector.

If you have any questions, please contact Judy Fulton at (602) 250-3549.

Sincerely,

WEI/JDF/cj

Enclosures: JULY 2000 Monthly Operating Reports

cc: E. W. Merschoff (all w/enclosures)
P. H. Harrell
J. H. Moorman
INPO Records Center
Utility Data Institute

IE24

NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-528
 UNIT NAME: PVNGS-1
 DATE: 8/8/00
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: July 2000

1. Design Electrical Rating (Net MWe): 1265
2. Maximum Dependable Capacity (Net MWe): 1243

	Unit 1 Generating Statistics	This Month	Yr. to Date	Cumulative
3.	Hours Reactor was Critical	744.0	5,112.0	94,820.1
4.	Hours Generator was On-Line	744.0	5,098.1	93,503.6
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	923,905	6,370,288	111,807,668

UNIT SHUTDOWNS

No.	Date	Type ¹	Outage Duration Hours	Reason ²	Method of Shutting Down Reactor ³	Cause and Corrective Action to Prevent Occurrence
-----	------	-------------------	-----------------------------	---------------------	--	--

No reactor shutdowns occurred during the month of July 2000.

¹F-Forced
S-Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Trip / Scram
 3-Automatic Trip / Scram
 4-Continuation
 5-Other-(Explain)

SUMMARY: _____

NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-529
 UNIT NAME: PVNGS-2
 DATE: 8/8/00
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: July 2000

1. Design Electrical Rating (Net MWe): 1265
2. Maximum Dependable Capacity (Net MWe): 1243

	Unit 2 Generating Statistics	This Month	Yr. To Date	Cumulative
3.	Hours Reactor was Critical	744.0	4,953.6	95,032.9
4.	Hours Generator was On-Line	744.0	4,944.6	93,795.1
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	936,031	6,165,397	113,481,129

UNIT SHUTDOWNS

No.	Date	Type ¹	Outage Duration Hours	Reason ²	Method of Shutting Down Reactor ³	Cause and Corrective Action to Prevent Occurrence
-----	------	-------------------	-----------------------------	---------------------	--	--

No reactor shutdowns occurred during the month of July 2000.

¹F-Forced
S-Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training / License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Trip / Scram
 3-Automatic Trip / Scram
 4-Continuation
 5-Other-(Explain)

SUMMARY: _____

NRC MONTHLY OPERATING DATA REPORT

DOCKET NO.: 50-530
 UNIT NAME: PVNGS-3
 DATE: 8/8/00
 COMPLETED BY: J. D. Fulton
 TELEPHONE: (602) 250-3549

Reporting Period: July 2000

1. Design Electrical Rating (Net MWe): 1269
2. Maximum Dependable Capacity (Net MWe): 1247

	Unit 3 Generating Statistics	This Month	Yr. to Date	Cumulative
3.	Hours Reactor was Critical	744.0	4,389.5	90,345.1
4.	Hours Generator was On-Line	744.0	4,355.1	89,450.8
5.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWh)	935,361	5,426,676	108,737,032

UNIT SHUTDOWNS

No.	Date	Type ¹	Outage Duration Hours	Reason ²	Method of Shutting Down Reactor ³	Cause and Corrective Action to Prevent Occurrence
-----	------	-------------------	-----------------------------	---------------------	--	--

No reactor shutdowns occurred during the month of July 2000.

¹F-Forced
S-Scheduled

²Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training / License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

³Method:

- 1-Manual
- 2-Manual Trip / Scram
- 3-Automatic Trip / Scram
- 4-Continuation
- 5-Other-(Explain)

SUMMARY: _____
