

**Florida  
Power**

CORPORATION  
Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72

August 10, 2000  
3F0800-02

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

Subject: Monthly Operating Report

Dear Sir:

Florida Power Corporation hereby submits the Crystal River Unit 3 (CR-3) July 2000 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Manager, Nuclear Licensing at (352) 563-4883.

Sincerely,

D. L. Roderick  
Director, Nuclear Plant Operations


DLR/ff

Attachment

xc: Regional Administrator, Region II  
Senior Resident Inspector  
NRR Project Manager

IE24

## APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-302  
UNIT NAME FLCRP-3  
DATE August 03, 2000  
COMPLETED BY L.J. Barbieri   
TELEPHONE (352) 795-6486 x3761

REPORTING PERIOD (Month/Year): July 2000

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	825		
2 MAXIMUM DEPENDABLE CAPACITY (Mwe-Net)	843		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	5,064.0	138,080
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	5,050.5	135,833
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	617,868	4,259,715	104,517,056

## APPENDIX B UNIT SHUTDOWNS

**DOCKET NO.** 50-302  
**UNIT NAME** FLCRP-3  
**DATE** August 03, 2000  
**COMPLETED BY** L. J. Barbieri  
**TELEPHONE** (352) 795-6486 x3761

**REPORTING PERIOD:** July 2000

No.	Date	Type	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
		F: Forced S: Scheduled				Comments
None						Crystal River Unit 3 operated at full power for the entire month of July.

### SUMMARY:

Crystal River Unit 3 operated at full power for the entire month of July.

#### (1) Reason:

A-EQUIPMENT FAILURE (Explain)  
 B-MAINTENANCE OR TEST  
 C-REFUELING  
 D-REGULATORY RESTRICTION  
 E-OPERATOR TRAINING / LICENSE EXAMINATION  
 F-ADMINISTRATIVE  
 G-OPERATIONAL ERROR (Explain)  
 H-OTHER (Explain)

#### (2) Method:

1-MANUAL  
 2-MANUAL TRIP / SCRAM  
 3-AUTO TRIP / SCRAM  
 4-CONTINUATION  
 5-OTHER (Explain)