



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001  
AREA CODE 716-546-2700



August 7, 2000


US Nuclear Regulatory Commission  
Document Control Desk  
Attn: Guy S. Vissing  
Project Directorate I-1  
Washington, DC 20555

Subject: Monthly Report for July, 2000  
Operating Status Information  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of July, 2000. A corrected unit shutdown and operating summary sheet for the month of June is attached. The date and reporting period were incorrect in the previous report.

Very truly yours,

  
Joseph A. Widay  
Plant Manager

xc: U.S. Nuclear Regulatory Commission  
Mr. Guy S. Vissing (Mail Stop 8C2)  
Project Directorate I-1  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

IE24.

# OPERATING DATA REPORT

-1-

50-244

August 7, 2000

COMPLETED BY:

John V. Walden  
John V. Walden

TELEPHONE (716) 771-3588

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period: July, 2000

3. Design Electric Rating (Net MWe): 470

4. Maximum Dependable Capacity (Net MWe): 480

	This Month	Yr.-to-Date	Cumulative**
5. Number of hours Reactor Was Critical	<u>744.0</u>	<u>5111.0</u>	<u>219325.0</u>
6. Hours Generator On-line	<u>744.0</u>	<u>5094.2</u>	<u>216238.1</u>
7. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
8. Net Electrical Energy Generated (MWH)	<u>361510.0</u>	<u>2449471.6</u>	<u>97834607.0</u>

\*\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244  
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT  
DATE: August 7, 2000  
COMPLETED BY: John V. Walden  
TELEPHONE: (716) 771-3588

### UNIT SHUTDOWN

REPORTING PERIOD: July, 2000  
(Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON <sup>(1)</sup>	METHOD OF SHUTTING DOWN <sup>(2)</sup>	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS

SUMMARY:

The unit operated at full power for the entire month of July. Average power for the month of July was 99.7%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO: 50-244  
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT  
DATE: July 12, 2000  
COMPLETED BY: John V. Walden  
TELEPHONE: (716) 771-3588

### UNIT SHUTDOWN

REPORTING PERIOD: June, 2000  
(Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON <sup>(1)</sup>	METHOD OF SHUTTING DOWN <sup>(2)</sup>	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS

SUMMARY:

The unit experienced one unplanned power reduction in June. The power reduction occurred on June 29, 2000 for repair of a heater drain line leak. Power was reduced to 74% for a quick weld repair.. Average power for the month of June was 99.6%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)