



Carolina Power & Light Company
P.O. Box 10429
Southport, NC 28461-0429

AUG-09 2000

SERIAL: BSEP 00-0116

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62
JULY 2000 MONTHLY OPERATING REPORT

Gentlemen:

In accordance with Technical Specification (TS) 5.6.4 for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2, Carolina Power & Light (CP&L) Company is submitting the enclosed report of operating statistics and shutdown experience for the month of July 2000. This report is being submitted to the NRC by the 15th day of the month following the calendar month covered by the report as specified in TS 5.6.4. There are no regulatory commitments being made in this submittal.

Please refer any questions regarding this submittal to Mr. Leonard R. Beller, Supervisor - Licensing, at (910) 457-2073.

Sincerely,

Warren J. Dorman
Manager - Regulatory Affairs
Brunswick Steam Electric Plant

WRM/wrm

Enclosures:

1. BSEP Unit No. 1 Monthly Operating Report July 2000
2. BSEP Unit No. 2 Monthly Operating Report July 2000

IE24

Document Control Desk
BSEP 00-0116 / Page 2

cc (with enclosures):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission
ATTN: Mr. Theodore A. Easlick, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P. O. Box 29510
Raleigh, NC 27626-0510

ElectriCities of N. C., Inc.
ATTN: Mr. Clarence C. Wells
P. O. Box 29513
Raleigh, NC 27626-0513

ENCLOSURE 1

**BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62**

**BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
MONTHLY OPERATING REPORT
JULY 2000**

APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE August 3, 2000
COMPLETED BY Kester Thompson
TELEPHONE (910) 457-2754

	REPORTING PERIOD	<u>July 2000</u> (Month/Year)	
	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	867	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net)	820	N/A	N/A
3. Number of Hours the Reactor Was Critical:	744	4,480	140,543
4. Number of Hours the Generator Was On Line:	744	4,449	136,144
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	618,937	3,690,015	98,990,511

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE August 3, 2000
COMPLETED BY Kester Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD July 2000
 (Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A						Unit No. 1 was not required to shut down during the month of July 2000.

SUMMARY:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

ENCLOSURE 2

**BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62**

**BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
MONTHLY OPERATING REPORT
JULY 2000**

APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE August 3, 2000
COMPLETED BY Kester Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD July 2000
 (Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	867	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net)	811	N/A	N/A
3. Number of Hours the Reactor Was Critical:	744	5,111	150,109
4. Number of Hours the Generator Was On Line:	744	5,111	144,202
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	603,993	4,187,222	100,538,581

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE August 3, 2000
COMPLETED BY Kester Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD July 2000
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A						Unit No. 2 was not required to shut down during the month of July 2000.

SUMMARY:

(1) Reason

A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training/License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)