

U.S. Nuclear Regulatory Commission
Page 2
August 14, 2000

JDS:JWP:DJS

cc (Enclosure):

Mr. R. W. Hernan, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5947

Ms. Barbara Lewis, Assistant Editor, Database
McGraw-Hill, Inc.
1200 G Street, NW, Suite 1100
Washington, D.C. 20005

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37384-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-3415

OPERATIONAL SUMMARY JULY 2000

I. SEQUOYAH OPERATIONAL SUMMARY

UNIT 1

Unit 1 generated 855,752 megawatthours (MWh) (gross) electrical power during July with a capacity factor of 99.1 percent. Unit 1 operated at 100 percent power throughout the month of July.

UNIT 2

Unit 2 generated 852,338 MWh (gross) electrical power during July with a capacity factor of 99.1 percent. Unit 2 operated at 100 percent power throughout the month of July.

II. CHALLENGES TO THE PRESSURIZER POWER-OPERATED RELIEF VALVES (PORVs) OR PRESSURIZER SAFETY VALVES

No PORVs or safety valves were challenged in July.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-327 UNIT NO. ONE DATE: August 9, 2000

COMPLETED BY: Tanya J. Hollomon TELEPHONE: (423) 843-7528

MONTH: JULY 2000

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1.	<u>1108</u>	17.	<u>1102</u>
2.	<u>1108</u>	18.	<u>1102</u>
3.	<u>1109</u>	19.	<u>1101</u>
4.	<u>1110</u>	20.	<u>1103</u>
5.	<u>1114</u>	21.	<u>1101</u>
6.	<u>1111</u>	22.	<u>1105</u>
7.	<u>1114</u>	23.	<u>1103</u>
8.	<u>1110</u>	24.	<u>1107</u>
9.	<u>1111</u>	25.	<u>1108</u>
10.	<u>1108</u>	26.	<u>1112</u>
11.	<u>1109</u>	27.	<u>1111</u>
12.	<u>1108</u>	28.	<u>1111</u>
13.	<u>1107</u>	29.	<u>1108</u>
14.	<u>1106</u>	30.	<u>1107</u>
15.	<u>1104</u>	31.	<u>1106</u>
16.	<u>1105</u>		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-328 UNIT NO. TWO DATE: August 9, 2000

COMPLETED BY: Tanya J. Hollomon TELEPHONE: (423) 843-7528

MONTH: JULY 2000

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1.	<u>1104</u>	17.	<u>1093</u>
2.	<u>1105</u>	18.	<u>1095</u>
3.	<u>1106</u>	19.	<u>1093</u>
4.	<u>1107</u>	20.	<u>1094</u>
5.	<u>1108</u>	21.	<u>1092</u>
6.	<u>1111</u>	22.	<u>1096</u>
7.	<u>1107</u>	23.	<u>1094</u>
8.	<u>1103</u>	24.	<u>1098</u>
9.	<u>1104</u>	25.	<u>1098</u>
10.	<u>1101</u>	26.	<u>1102</u>
11.	<u>1101</u>	27.	<u>1101</u>
12.	<u>1099</u>	28.	<u>1101</u>
13.	<u>1098</u>	29.	<u>1082</u>
14.	<u>1097</u>	30.	<u>1098</u>
15.	<u>1095</u>	31.	<u>1098</u>
16.	<u>1096</u>		

OPERATING DATA REPORT

Docket No.	50-327
Date:	August 9, 2000
Completed By:	T. J. Hollomon
Telephone:	(423) 843-7528

1. Unit Name:	SQN Unit 1
2. Reporting Period:	July 2000
3. Licensed Thermal Power (MWt):	3411.0
4. Nameplate Rating (Gross MWe):	1220.6
5. Design Electrical Rating (Net MWe):	1148.0
6. Maximum Dependable Capacity (Gross MWe):	1161
7. Maximum Dependable Capacity (Net MWe):	1122

8. If changes Occur in Capacity Rating (Item Numbers 3 & 7) Since Last Report, Give Reasons: N/A

9. Power Level To Which Restricted, If any (net MWe): N/A

10. Reasons for Restrictions, If any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744	5,111	167,304
12. Number of Hours Reactor was Critical	744.0	4,527.7	106,165
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	4,501.0	104,288.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWh)	2,535,072.0	14,781,536.6	342,560,039.2
17. Gross Electric Energy Generated (MWh)	855,752	5,098,745	117,026,992
18. Net Electrical Energy Generated (MWh)	822,908	4,925,187	112,517,742
19. Unit Service Factor	100.0	88.1	62.3
20. Unit Availability Factor	100.0	88.1	62.3
21. Unit Capacity Factor (Using MDC Net)	98.6	85.9	59.9
22. Unit Capacity Factor (Using DER Net)	96.3	83.9	58.6
23. Unit Forced Outage Rate	0.0	0.6	25.6

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): This information is no longer required by NRC.

25. If Shutdown at End of Report Period, Estimate Date of Startup. N/A

OPERATING DATA REPORT

Docket No.	50-328
Date:	August 9, 2000
Completed By:	T. J. Hollomon
Telephone:	(423) 843-7528

1. Unit Name:	SQN Unit 2
2. Reporting Period:	July 2000
3. Licensed Thermal Power (MWt):	3411.0
4. Nameplate Rating (Gross MWe):	1220.6
5. Design Electrical Rating (Net MWe):	1148.0
6. Maximum Dependable Capacity (Gross MWe):	1156
7. Maximum Dependable Capacity (Net MWe):	1117

8. If changes Occur in Capacity Rating (Item Numbers 3 & 7) Since Last Report, Give Reasons: N/A

9. Power Level To Which Restricted, If any (net MWe): N/A

10. Reasons for Restrictions, If any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744	5,111	159,264
12. Number of Hours Reactor was Critical	744.0	5,069.8	109,626
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	5,062.1	107,597.4
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWh)	2,534,181.6	17,195,980.1	347,444,535.8
17. Gross Electric Energy Generated (MWh)	852,338	5,931,108	118,533,634
18. Net Electrical Energy Generated (MWh)	819,494	5,745,250	113,929,172
19. Unit Service Factor	100.0	99.0	67.6
20. Unit Availability Factor	100.0	99.0	67.6
21. Unit Capacity Factor (Using MDC Net)	98.6	100.6	64.0
22. Unit Capacity Factor (Using DER Net)	95.9	97.9	62.3
23. Unit Forced Outage Rate	0.0	1.0	24.8

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): This information is no longer required by NRC.

25. If Shutdown at End of Report Period, Estimate Date of Startup. N/A

**UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH: JULY 2000**

DOCKET NO: 50-327
UNIT NAME: SQN-1
DATE: August 9, 2000
COMPLETED BY: T. J. Hollomon
TELEPHONE: (423) 843-7528

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
									There were no outages or power reductions of greater than 20 percent in the average daily power level during July.

¹ **F: Force**
S: Scheduled

² **Reason:**
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H- Other (Explain)

³ **Method**
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴ **Exhibit G - Instructions for (NUREG
Preparation of Data Entry sheets
for Licensee Event Report (LER)
File - NUREG - 1022**

⁵ **Exhibit I-Same Source**

**UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH: JULY 2000**

DOCKET NO: 50-328
UNIT NAME: SQN-2
DATE: August 9, 2000
COMPLETED BY: T. J. Hollomon
TELEPHONE: (423) 843-7528

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
									There were no outages or power reductions of greater than 20 percent in the average daily power level during July.

¹ **F: Force**
S: Scheduled

² **Reason:**
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H- Other (Explain)

³ **Method**
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴ **Exhibit G - Instructions for (NUREG
Preparation of Data Entry sheets
for Licensee Event Report (LER)
File - NUREG - 1022**

⁵ **Exhibit I-Same Source**

ENCLOSURE

**TENNESSEE VALLEY AUTHORITY
SEQUOYAH NUCLEAR PLANT (SQN)**

MONTHLY OPERATING REPORT

JULY 2000

UNIT 1

DOCKET NUMBER 50-327

LICENSE NUMBER DPR-77

UNIT 2

DOCKET NUMBER 50-328

LICENSE NUMBER DPR-79