

ENERGY
NORTHWEST

P.O. Box 968 ■ Richland, Washington 99352-0968

August 9, 2000
GO2-00-138

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21**
MONTHLY OPERATING REPORT
JULY 2000

Transmitted herewith is the Monthly Operating Report for the month of July 2000 as required by Technical Specification 5.6.4.

Respectfully,



G. O. Smith
Vice President, Generation
Mail Drop 927M

cc: EW Merschoff - NRC RIV
JS Cushing - NRR
NRC Sr. Resident Inspector - 927N
TC Poindexter - Winston & Strawn
INPO
ANI Library
Utility Data Institute
DL Williams - BPA / 1399

IE24

OPERATING STATUS REPORT
for WNP-2

Date: August 1, 2000

1. Docket: 50-397
 2. Reporting Period: July 2000
 3. Utility Contact: **Bernice Kasko** (509) 377-4473
 4. Design Electrical Rating (Net MW_e): 1153
 5. Maximum Dependable Capacity - summer (Net MW_e): 1107
- | | MONTH | YEAR | CUMULATIVE |
|--|-------|------|------------|
|--|-------|------|------------|
10. Challenges to safety/relief valves: None

UNIT SHUTDOWNS

DOCKET NO.: 50-397
 UNIT NAME: WNP-2
 DATE: August 1, 2000
 COMPLETED BY: B Kasko
 TELEPHONE: (509) 377-4473

REPORT PERIOD: July, 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
00-01	6/26/00	F	77.9	A	4	scram due to the erroneous indication of phase current mismatch in station electrical output due to a ground fault in a current transformer lead.

SUMMARY: Synchronized and connected main generator to grid at 05:54 July 4, 2000.
 Achieved full reactor power on 6-July-2000

(1) REASON

A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training &
 License Examination
 F - Administration
 G - Operational Error
 H - Other

(2) METHOD

1 - Manual
 2 - Manual Scram
 3 - Auto Scram
 4 - Continued
 5 - Reduced Load
 9 - Other