



## PECO NUCLEAR

A Unit of PECO Energy

PECO Energy Company  
200 Exelon Way  
Kennett Square, PA 19348

August 17, 2000

Docket No. 50-352  
50-353

License No. NPF-39  
NPF-85

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Limerick Generating Station, Units 1 and 2  
Revised Technical Specifications Bases 3/4.6.6

Dear Sir/Madam:

PECO Energy Company recently revised Technical Specifications Bases for Limerick Generating Station (LGS) Units 1 and 2, in accordance with 10CFR50.59. Bases section 3/4.6.6 has been revised to reflect the change in operation of the combustible gas analyzer from continuous mode of operation to standby mode of operation.

Attached are the revised Bases Pages B3/4 6-6 for LGS Unit 1 (Overleaf Page B3/4 6-5 for LGS Unit 1 is also provided for completeness; no changes have been made to the Overleaf Page) and B3/4 6-7 for LGS Unit 2. The attached pages are provided for updating NRC records as appropriate.

If you have any questions, please do not hesitate to contact us.

Very truly yours,

James A. Hutton  
Director - Licensing

Enclosures

cc: (w/encl) H. J. Miller, Administrator, Region 1, USNRC  
A. L. Burritt, USNRC Senior Resident Inspector, LGS

A001

## CONTAINMENT SYSTEMS

### BASES

#### 3/4.6.5 SECONDARY CONTAINMENT (Continued)

The field tests for bypass leakage across the SGTS charcoal adsorber and HEPA filter banks are performed at a flow rate of  $5764 \pm 10\%$  cfm. The laboratory analysis performed on the SGTS carbon samples will be tested at a velocity of 66 fpm based on the system residence time.

The SGTS filter train pressure drop is a function of air flow rate and filter conditions. Surveillance testing is performed using either the SGTS or drywell purge fans to provide operating convenience.

Each reactor enclosure secondary containment zone and refueling area secondary containment zone is tested independently to verify the design leak tightness. A design leak tightness of 2500 cfm or less for each reactor enclosure and 764 cfm or less for the refueling area at a 0.25 inch of vacuum water gage will ensure that containment integrity is maintained at an acceptable level if all zones are connected to the SGTS at the same time.

The Reactor Enclosure Secondary Containment Automatic Isolation Valves and Refueling Area Secondary Containment Automatic Isolation Valves can be found in the UFSAR.

The post-LOCA offsite dose analysis assumes a reactor enclosure secondary containment post-draw down leakage rate of 2500 cfm and certain post-accident X/Q values. While the post-accident X/Q values represent a statistical interpretation of historical meteorological data, the highest ground level wind speed which can be associated with these values is 7 mph (Pasquill-Gifford stability Class G for a ground level release). Therefore, the surveillance requirement assures that the reactor enclosure secondary containment is verified under meteorological conditions consistent with the assumptions utilized in the design basis analysis. Reactor Enclosure Secondary Containment leakage tests that are successfully performed at wind speeds in excess of 7 mph would also satisfy the leak rate surveillance requirements, since it shows compliance with more conservative test conditions.

#### 3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL

The OPERABILITY of the systems required for the detection and control of hydrogen combustible mixtures of hydrogen and oxygen ensures that these systems will be available to maintain the hydrogen concentration within the primary containment below the lower flammability limit during post-LOCA conditions. The primary containment hydrogen recombiner is provided to maintain the oxygen concentration below the lower flammability limit. The combustible gas analyzer is designed to operate either in standby or continuous mode during normal operation. However, the combustible gas analyzer is required to continuously monitor hydrogen and oxygen concentrations in the primary containment following a LOCA. The primary containment atmospheric mixing system is provided to ensure adequate mixing of the containment atmosphere to prevent localized accumulations of hydrogen and oxygen from exceeding the lower flammability limit. The hydrogen control system is consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA," March 1971.

## CONTAINMENT SYSTEMS

### BASES

#### 3/4.6.5 SECONDARY CONTAINMENT

Secondary containment is designed to minimize any ground level release of radioactive material which may result from an accident. The Reactor Enclosure and associated structures provide secondary containment during normal operation when the drywell is sealed and in service. At other times the drywell may be open and, when required, secondary containment integrity is specified.

Establishing and maintaining a vacuum in the reactor enclosure secondary containment with the standby gas treatment system once per 24 months, along with the surveillance of the doors, hatches, dampers and valves, is adequate to ensure that there are no violations of the integrity of the secondary containment.

The OPERABILITY of the reactor enclosure recirculation system and the standby gas treatment systems ensures that sufficient iodine removal capability will be available in the event of a LOCA or refueling accident (SGTS only). The reduction in containment iodine inventory reduces the resulting SITE BOUNDARY radiation doses associated with containment leakage. The operation of this system and resultant iodine removal capacity are consistent with the assumptions used in the LOCA and refueling accident analyses. Provisions have been made to continuously purge the filter plenums with instrument air when the filters are not in use to prevent buildup of moisture on the adsorbers and the HEPA filters.

Although the safety analyses assumes that the reactor enclosure secondary containment draw down time will take 930 seconds, these surveillance requirements specify a draw down time of 916 seconds. This 14 second difference is due to the diesel generator starting and sequence loading delays which is not part of this surveillance requirement.

The reactor enclosure secondary containment draw down time analyses assumes a starting point of 0.25 inch of vacuum water gauge and worst case SGTS dirty filter flow rate of 2800 cfm. The surveillance requirements satisfy this assumption by starting the drawdown from ambient conditions and connecting the adjacent reactor enclosure and refueling area to the SGTS to split the exhaust flow between the three zones and verifying a minimum flow rate of 2800 cfm from the test zone. This simulates the worst case flow alignment and verifies adequate flow is available to drawdown the test zone within the required time. The Technical Specification Surveillance Requirement 4.6.5.3.b.3 is intended to be a multi-zone air balance verification without isolating any test zone.

The SGTS fans are sized for three zones and therefore, when aligned to a single zone or two zones, will have excess capacity to more quickly drawdown the affected zones. There is no maximum flow limit to individual zones or pairs of zones and the air balance and drawdown time are verified when all three zones are connected to the SGTS.

The three zone air balance verification and drawdown test will be done after any major system alteration, which is any modification which will have an effect on the SGTS flowrate such that the ability of the SGTS to drawdown the reactor enclosure to greater than or equal to 0.25 inch of vacuum water gage in less than or equal to 916 seconds could be affected.

## CONTAINMENT SYSTEMS

### BASES

---

#### 3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL

The OPERABILITY of the systems required for the detection and control of hydrogen combustible mixtures of hydrogen and oxygen ensures that these systems will be available to maintain the hydrogen concentration within the primary containment below the lower flammability limit during post-LOCA conditions. The primary containment hydrogen recombiner is provided to maintain the oxygen concentration below the lower flammability limit. The combustible gas analyzer is designed to operate either in standby or continuous mode during normal operation. However, the combustible gas analyzer is required to continuously monitor hydrogen and oxygen concentrations in the primary containment following a LOCA. The primary containment atmospheric mixing system is provided to ensure adequate mixing of the containment atmosphere to prevent localized accumulations of hydrogen and oxygen from exceeding the lower flammability limit. The hydrogen control system is consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA," March 1971.

THIS PAGE INTENTIONALLY LEFT BLANK