

September 12, 2000

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Victor Nerses, Sr. Project Manager, Section 2 **/RA/**
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE (TAC NO. MA4586)

Northeast Nuclear Energy Company, et al., Docket No. 50-423, Millstone Nuclear Power
Station, Unit No. 3, New London County, Connecticut

Date of application for amendment: January 18, 1999, and supplemented by letters dated
April 5 and December 21, 1999; and May 2 and August 10, 2000.

Brief description of amendment: The amendment revises the Technical Specifications
(TSs) and the Final Safety Analysis Report for Millstone 3 to allow an entire reactor core to
be offloaded to the spent fuel pool (SFP) and an increase in the maximum design basis
normal SFP water temperature limit from 140 °F to 150 °F during planned refueling
outages. The increase in maximum design basis normal SFP water temperature up to
150 °F affects certain Fuel Building area TS temperature limits that require a revision to the
TSs.

Date of issuance: September 12, 2000.

Effective date: As of the date of issuance and shall be implemented within 60 days from the
date of issuance.

Amendment No.: 182.

Facility Operating License No. NPF-49: Amendment revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: March 10, 1999 (64 FR 11962)

The letters dated April 5 and December 21, 1999, and May 2, 2000, provided clarifying
information and did not change the staff's initial proposed no significant hazards

consideration determination or expand the scope of the application as published in the
FEDERAL REGISTER.

The Commission's related evaluation of this amendment is contained in a Safety Evaluation
dated September 12, 2000.

No significant hazards consideration comments received: No.

consideration determination or expand the scope of the application as published in the
FEDERAL REGISTER.

The Commission's related evaluation of this amendment is contained in a Safety Evaluation
dated September 12, 2000.

No significant hazards consideration comments received: No.

DISTRIBUTION

PDI-2 Reading

OGC

VNerses JClifford

RUrban, RI

JLinville, RI

TClark

DOCUMENT NAME: G:\PDI-2\MILLSTONE3\BWIA4586.wpd ***Previous Concurrence**

OFFICE	PDI-2/PM	PDI-2/LA	OGC*	PDI-2/SC
NAME	VNerses	TLClark	APHodgdon	EAdensam for JClifford
DATE	9/11/00	9/11/00	04/28/00	9/11/00
COPY	YES NO	(YES) NO	YES NO	YES NO

OFFICIAL RECORD COPY