

June 2, 2000

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: COMPLETION OF ACTIONS FOR BULLETIN 96-03, "POTENTIAL PLUGGING OF EMERGENCY CORE COOLING SUCTION STRAINERS BY DEBRIS IN BOILING-WATER REACTORS," LASALLE COUNTY STATION, UNITS 1 AND 2 (TAC NOS. M96151 AND M96152)

Dear Mr. Kingsley:

On May 6, 1996, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin (BL) 96-03, "Potential Plugging of Emergency Core Cooling Suction Strainers by Debris in Boiling-Water Reactors" to all holders of operating licenses or construction permits for boiling-water reactors (BWRs). The NRC issued BL 96-03 to ensure that the emergency core cooling systems (ECCS) in BWRs can perform their intended safety function to mitigate the effects of a postulated loss-of-coolant accident (LOCA). The BL provided three options for resolving this issue including: (1) installation of large capacity passive strainers, (2) installation of self-cleaning strainers, or (3) installation of a backflush system.

In BL 96-03, the NRC staff specifically requested that licensees submit the following reports for each of their facilities:

1. A description of planned actions and mitigative strategies to use, the schedule for implementation, and proposed technical specification, if appropriate.
2. A report confirming completion and summarizing actions taken.

In response to BL 96-03, you provided a letter dated November 1, 1996. You stated that you planned to install large capacity passive strainers which would be designed using the guidance in the Boiling Water Reactors Owners Group Utility Resolution Guidance (URG). The staff reviewed the URG and issued a safety evaluation on August 20, 1998. Commonwealth Edison's (ComEd's) review of the NRC's safety evaluation was provided by letter dated October 19, 1998. By letter dated April 28, 2000, you informed the staff that you had completed all actions requested by the bulletin. These actions included: (1) large capacity passive strainers were installed and tested in both units; (2) the wetwells of both units were desludged and the suppression chambers, strainers, and downcomers were inspected; (3) the non-reflective metal insulation systems in the drywell were inspected and reworked to remove fiber sources; and (4) procedures were implemented that require inspections of the drywell and wetwell to be performed at each refueling outage and desludging of the suppression chamber every refueling outage until the foreign material exclusion controls are proven.

The staff has reviewed your response and has determined that the actions taken should minimize the potential for clogging of ECCS suction strainers and ensure the capability of the ECCS to provide long-term cooling following a LOCA as required by 10 CFR 50.46. The staff considers your actions responsive to the concerns raised in BL 96-03. Therefore, BL 96-03 is closed for your facility. Detailed reviews of your strainer design and 10 CFR 50.59 evaluation may be performed on a plant-specific basis in the future.

Sincerely,

/RA/

Donna M. Skay, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

cc: See next page

O. Kingsley
Commonwealth Edison Company

LaSalle County Station
Units 1 and 2

cc:

Phillip P. Steptoe, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Robert Cushing, Chief, Public Utilities Division
Illinois Attorney General's Office
100 W. Randolph Street
Chicago, Illinois 60601

Assistant Attorney General
100 W. Randolph St. Suite 12
Chicago, Illinois 60601

Document Control Desk-Licensing
Commonwealth Edison Company
1400 Opus Place, Suite 400
Downers Grove, Illinois 60515

U.S. NRC-LaSalle Resident Inspectors Office
2605 N. 21st Road
Marseilles, Illinois 61341-9756

Commonwealth Edison Company
Site Vice President - LaSalle
2601 N. 21st Road
Marseilles, Illinois 61341-9757

Chairman
LaSalle County Board
707 Etna Road
Ottawa, Illinois 61350

Mr. David Helwig
Senior Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Attorney General
500 S. Second Street
Springfield, Illinois 62701

Chairman
Illinois Commerce Commission
527 E. Capitol Avenue, Leland Building
Springfield, Illinois 62706

Mr. Gene H. Stanley
Vice President - Nuclear Operations
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Mr. Christopher Crane
Senior VP - Nuclear Operations
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Commonwealth Edison Company
LaSalle Station Manager
2601 N. 21st Road
Marseilles, Illinois 61341-9757

O. Kingsley
Commonwealth Edison Company

- 2 -

LaSalle County Station
Units 1 and 2

89

Mr. R. M. Krich
Vice President - Regulatory Services
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, Illinois 60515

Commonwealth Edison Company
Reg. Assurance Supervisor - LaSalle
2601 N. 21st Road
Marseilles, Illinois 61341-9757

Ms. Pamela B. Stroebel
Senior Vice President and General Counsel
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690-0767

O. Kingsley

-2-

The staff has reviewed your response and has determined that the actions taken should minimize the potential for clogging of ECCS suction strainers and ensure the capability of the ECCS to provide long-term cooling following a LOCA as required by 10 CFR 50.46. The staff considers your actions responsive to the concerns raised in BL 96-03. Therefore, BL 96-03 is closed for your facility. Detailed reviews of your strainer design and 10 CFR 50.59 evaluation may be performed on a plant-specific basis in the future.

Sincerely,

/RA/

Donna M. Skay, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

cc: See next page

Distribution:

PUBLIC

PDIII/2 r/f

A. Mendiola

C. Moore

D. Skay

OGC, O15B18

ACRS, T2E26

M. Leach, RIII

Accession No. ML003760670

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:PDIII/2		LA:PDIII/2		SPLB		SC:PDIII/2	
NAME	DSKAY		CMOORE		GHubbard		AMENDIOLA	
DATE	05/24/00		05/24/00		06/01/00		6/1/00	

OFFICIAL RECORD COPY