

James A. FitzPatrick
Nuclear Power Plant
268 Lake Road
P.O. Box 41
Lycoming, New York 13093
315-342-3840



Michael J. Colomb
Site Executive Officer

November 15, 2000
JAFP-00-0265

U. S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D. C. 20555

ATTENTION: Document Control Desk

SUBJECT: OPERATING STATUS REPORT

Reference: Docket No. 50-333

Dear Sir:

Enclosed is the Operating Status Report for the James A. FitzPatrick Nuclear Power Plant for the month of October 2000.

If there are any questions concerning this report, please contact Jeff Boyer, Lead Systems Engineer, (315) 349-6147.

A handwritten signature in black ink, appearing to read 'M. Colomb', with a long horizontal flourish extending to the right.

MICHAEL J. COLOMB

MJC:GC:JB:tb
Enclosure

cc: JAF Department Heads
White Plains Office
Todd Tierney IP3
Robert Penney WPO
JTS JAFP File
RMS (JAF)
RMS (WPO)

IE24

REPORT MONTH: OCTOBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	November 13, 2000
Completed By:	J. Boyer
Telephone:	(315)349-6147

OPERATING STATUS

1. Unit name: FitzPatrick
2. Reporting period: 10/01/2000 – 10/31/2000
3. Licensed thermal power (MWT): 2536
4. Nameplate rating (gross MWE): 883.0
5. Design electrical rating (net MWE): 816
6. Maximum dependable capacity (gross MWE): 839
7. Maximum dependable capacity (net MWE): 813
8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons:
9. Power level to which restricted, if any (net MWE):
10. Reasons for restrictions, if any:

NO.	DATA REQUESTED	THIS MONTH	YR-TO-DATE	CUMULATIVE
11	Hours in reporting period:	744.00	7319.00	221472.00
12	Number of hours reactor was critical:	150.58	6576.73	163304.13
13	Reactor reserve shutdown hours:	0.00	0.00	0.00
14	Hours generator on-line:	145.00	6472.54	158239.67
15	Unit reserve shutdown hours:	0.00	0.00	0.00
16	Gross thermal energy generated (MWH):	353157.97	15805338.28	357621067.08
17	Gross electrical energy generated (MWH):	117770.00	5349640.00	120869790.00
18	Net electrical energy generated (MWH):	114810.00	5183190.00	116412685.00
19	Unit service factor:	19.49	88.43	71.45
20	Unit availability factor:	19.49	88.43	71.45
21	Unit capacity factor (using MDC net):	18.98	87.11	72.99
22	Unit capacity factor (using DER net)	18.91	86.79	64.42
23	Unit forced outage rate:	0	11.57	11.97

24. Shutdowns scheduled over next 6 months (type, date, and duration of each): Refuel Outage commenced October 6 and to last 35 days.
25. If shutdown at end of report period, estimated date of startup: November 12, 2000
26. Units in test status (prior to commercial operation):
- | | <u>FORECAST</u> | <u>ACHIEVED</u> |
|-----------------------|-----------------|-----------------|
| Initial Criticality: | | |
| Initial Electricity: | | |
| Commercial Operation: | | |

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORT MONTH: OCTOBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	November 13, 2000
Completed By:	J. Boyer
Telephone:	(315)349-6147

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	778	17	0
2	823	18	0
3	821	19	0
4	824	20	0
5	824	21	0
6	711	22	0
7	3	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

REPORT MONTH: OCTOBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date	November 13, 2000
Completed By:	J. Boyer
Telephone:	(315)349-6147

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE
1	10/6	S	35 DAYS	C	1	N/A	N/A	N/A	

F: FORCED
S: SCHEDULED

REASON:

- A. Equipment failure (explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator training and license examination
- F. Administrative
- G. Operational error (explain)
- H. Other (explain)

METHOD:

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Continued
- 5. Reduced load
- 9. Other

EXHIBIT G: Instructions for preparation of data entry sheets for Licensee Event Report (LER) file (NUREG-0161)

REPORT MONTH: OCTOBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	November 13, 2000
Completed By:	J. Boyer
Telephone:	(315)349-6147

FitzPatrick shutdown on October 6, 2000 to begin a scheduled Refueling Outage.