

---

### Job Performance Measure Worksheet

---

Facility: Pilgrim

Task No: 356-01-07-004

Task Title: Perform a Short Form Heat Balance

JPM No: Admin 1

K/A Reference: 293007 K1.13 2.3/2.9

Position: RO/SRO

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_

Date: \_\_\_\_\_

Method of testing:

Simulated Performance \_\_\_\_\_

Actual Performance: ✓

Classroom \_\_\_\_\_

Simulator ✓ Plant \_\_\_\_\_

#### Read to the Examinee:

"I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied."

**Initial Conditions:** Plant conditions are as follows:

- The plant is at 100% power.
- Plant conditions are stable.
- The plant process computer is out of service.

**Task Standard:** Attachment 4 of PNPS 2.1.10 is completed with no errors. The system procedure shall be followed without failure of critical tasks. Critical steps must be performed in order. Other steps may be performed out of sequence.

**Note:** PNPS 9.3 Attachment 3 is an alternate method for performing a short form heat balance and provides the same results.

**Required Materials:** Steam Tables

**General References:** PNPS 2.1.10, Rev. 21

**Initiating Cue:** "[Operator's name], Perform a Short Form Heat Balance.

**Time Critical Task:** NO

**Validation Time:** 5 minutes

~~XXXXXXXXXXXXXXXXXXXX~~

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

\_\_\_\_\_ **Performance Step 1:** Operator reviews the applicable sections of the procedure.

**Standard:** Operator reviews the applicable sections of the procedure.

**Comment:** IF Operator: Restore to 100% power IC (IC-14).

---

\_\_\_\_\_ **Performance Step 2:** Operator fills out date/time and performed by on Attachment 4.

**Standard:** Date/time and performed by recorded on Attachment 4.

**Comment:**

---

\_\_\_\_\_ **Performance Step 3:** Find and record reading for Feedwater Flow A from FI-640-24A on Panel C905.

**Standard:** FI-640-24A reading recorded.

**Comment:** Approximately 4 Mlb/hr.

---

\_\_\_\_\_ **Performance Step 4:** Find and record reading for Feedwater Flow B from FI-640-24B on Panel C905.

**Standard:** FI-640-24B reading recorded.

**Comment:** Approximately 4 Mlb/hr.

---

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

\_\_\_\_\_ **Performance Step 5:** Find and record reading for Feedwater Temperature A from TR-3496A on Panel C1.

**Standard:** TR-3496A reading recorded (red pen).

**Comment:** Approximately 365°F.

---

\_\_\_\_\_ **Performance Step 6:** Find and record reading for Feedwater Temperature B from TR-3496B on Panel C1.

**Standard:** TR-3496B reading recorded (blue pen).

**Comment:** Approximately 365°F.

---

\_\_\_\_\_ **Performance Step 7:** Calculate Total Feedwater flow by adding the A and B Feedwater Flows.

**Standard:** Total Feedwater flow calculated.

**Comment:** Approximately 8 Mlb/hr.

---

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

**Performance Step 8:** Average the A and B Feedwater Temperatures loops together.

**Standard:** Average Feedwater temperature calculated.

**Comment:** Approximately 365°F.

---

**Performance Step 9:** Using steam tables, determine Feedwater enthalpy.

**Standard:** Feedwater enthalpy is recorded.

**Comment:**  $h_f 365^\circ\text{F} \approx 337.6 \text{ BTU/lb}$

---

✓

**Performance Step 10:** Determine Core Thermal Power by subtracting Feedwater enthalpy from 1189.6 and dividing by 3.413, multiply by Total feedwater flow and add 9.02.

**Standard:** Core Thermal Power is calculated [2018 MWth (+/- 50 mw)].

**Comment:**

---

**Terminating Cue:** When the candidate has completed the core thermal power calculation, the examiner shall inform him/her that the task is complete.

---

VERIFICATION OF COMPLETION

---

JPM No.: \_\_\_\_\_

Examinee's Name: \_\_\_\_\_

Examiner's Name: \_\_\_\_\_

Date performed: \_\_\_\_\_

Number of attempts: \_\_\_\_\_

Time to complete: \_\_\_\_\_

Question Documentation:

Question: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Response: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Result: **SAT** or **UNSAT**

Examiner's signature and date: \_\_\_\_\_

---

Job Performance Measure  
Quality Checklist

---

Every JPM should:

1. ☒ Be supported by facility licensee's job task analysis.
2. ☒ Be operationally important (meets NRC K/A Catalog threshold criterion of 2.5 (3 for requalification exams) or as determined by the facility and agreed to by the NRC).
3. ☒ Be designed as either SRO only, RO/SRO or AO/RO/SRO.
4. Include the following, as applicable:
  - a. ☒ Initial conditions
  - b. ☒ Initiating cues
  - c. ☒ References and tools, including associated procedures
  - d. ☒ Validated time limits (average time allowed for completion) and specific designation of those JPMs that are deemed to be time-critical by the facility operations department
  - e. ☒ Specific performance criteria that include:
    - (1) ☒ Expected actions with exact control and indication nomenclature and criteria (switch position, meter reading), even if these criteria are not specified in the procedural step
    - (2) ☒ System response and other cues that are complete and correct so that the examiner can properly cue the examinee, if asked
    - (3) ☒ Statements describing important observations that should be made by the examinee
    - (4) ☒ Criteria for successful completion of the task
    - (5) ☒ Identification of those steps that are considered critical
    - (6) ☒ Restrictions on the sequence of steps

## **Information Provided to Candidate**

**Initial Conditions:** Plant conditions are as follows:

- The plant is at 100% power.
- Plant conditions are stable.
- The plant process computer is out of service.

**Initiating Cue:** “[Operator’s name], Perform a Short Form Heat Balance.

**Security (Awareness and Familiarity)**  
**Admin 2 Question #1:**

You are the CRS, what are the Immediate Operator Actions if a credible bomb threat has been reported to the Control Room?



**Security (Awareness and Familiarity)**  
**Admin 2 Question #1:**

You are the CRS, what are the Immediate Operator Actions if a credible bomb threat has been reported to the Control Room?

ANSWER:

Enter PNPS 5.3.14, Security Incidents

**Immediate Operator Actions:**

- [1] Notify the SAS or CAS operator. (.5 pts.)
- [2] Ensure the Operations Shift Supervisor (OSS) is aware of any incident. (.5 pts.)

CLOSED REFERENCE:

Reference: PNPS 5.3.14, Rev. 11, Security Incidents  
Section 3.0, Immediate Operator Actions

K/A: 2.4.28 2.3/3.3

**Security (Awareness and Familiarity)**

**Admin 2 Question #2:**

A System Engineer needs to be called in due to a problem with the plant. When called, he states that he has consumed two (2) alcoholic drinks in the last hour.

What requirements must be met if/when the System Engineer reports to the plant?

**Security (Awareness and Familiarity)**  
**Admin 2 Question #2:**

A System Engineer needs to be called in due to a problem with the plant. When called, he states that he has consumed two (2) alcoholic drinks in the last hour.

What requirements must be met if/when the System Engineer reports to the plant?

**ANSWER:**

- Candidate refers to PNPS 1.3.61-1, Fitness for Duty Determination Due to Unscheduled Work Shifts (0.2 pts.)
- Section 5.1, Call-In of Personnel for Unscheduled Work Shift (0.2 pts)
- Perform Attachment 1
- [1] Call in another person if possible. (0.2 pts)
  - [2] If this is not possible, the individual will be consulted as to the time and amount of alcohol consumed and whether or not he/she feels fit to drive. (0.2 pts.)
  - [3] If individual indicates he/she is able to drive, then a Medical or Security person, who shall be trained and/or certified to administer the test, will administer a breathalyzer test upon arrival at Pilgrim Station. (0.2 pts.)

**OPEN REFERENCE:**

Reference: PNPS 1.3.61-1, Rev. 3, Fitness for Duty Determination Due to Unscheduled Work Shifts

K/A: 2.1.5 2.3/3.4

---

**Job Performance Measure  
Worksheet**

---

Facility: Pilgrim

Task No: 341-03-02-021

Task Title: Determine RBCCW Pump Operability  
Using Flow Rate Surveillance Test Data

JPM No: Admin 3

K/A Reference: 2.2.12 3.0/3.4

Position: RO/SRO

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_

Date: \_\_\_\_\_

Method of testing:

Simulated Performance \_\_\_\_\_

Actual Performance: ✓

Classroom \_\_\_\_\_

Simulator ✓ Plant \_\_\_\_\_

**Read to the Examinee:**

"I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied."

**Initial Conditions:** Plant conditions are as follows:

- Procedure PNPS 8.5.3.1, "RBCCW Pump Operability And Flow Rate Tests" is in progress for Quarterly Pump Test on 'A' RBCCW pump.
- Data has been taken on the pump and is recorded in the working copy of the procedure.

**Task Standard:** Using data taken during a surveillance for the Quarterly Pump Test on 'A' RBCCW pump, determine that the shutoff head for the 'A' RBCCW pump is outside the acceptance criteria and declare the pump inoperable. The system procedure shall be followed without failure of critical tasks. Critical steps must be performed in order. Other steps may be performed out of sequence.

**Required Materials:** Calculator

**General References:** PNPS 8.5.3.1, Rev. 34

**Initiating Cue:** "[Operator's name], complete Attachment 1A of PNPS 8.5.3.1 for the Quarterly Pump Test using data taken on the 'A' RBCCW pump.

**Time Critical Task:** No

**Validation Time:** 10 minutes

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

\_\_\_\_\_ **Performance Step 1:** Operator reviews the applicable sections of the procedure.

**Standard:** Operator reviews the applicable sections of the procedure.

**Comment:**

---

\_\_\_\_\_ **Performance Step 2:** Complete the RBCCW Pump A (P-202A) Inservice Pump Testing Data Sheet documentation (Sheet 6) as follows:

Calculate and record the total head (TH) at shutoff in equivalent feet of water for RBCCW Pump A (P-202A).

**Standard:** Using data already recorded calculates TH = 111.99 (+/- .2) and records it in Attachment 1A step [4] (a) [measured value].

**Comment:**

---

\_\_\_\_\_ **Performance Step 3:** Record information from [measured value] and [calculation] steps within this attachment on the Inservice Pump Testing Data Sheet.

**Standard:** Information recorded on the Inservice Pump Testing Data Sheet corresponds to Attachment 1 of the JPM.

**Comment:** Attachment 1 is a completed Inservice Data Sheet with the values required to be entered in **BOLD**.

---

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

- ✓ **Performance Step 4:** Determines that the calculated Total Head at Shutoff puts the pump in the "Required Action" range and declares the 'A' RBCCW pump inoperable. (Per Section 10 [3] of PNPS 8.5.3.1.

**Standard:** 'A' RBCCW pump is declared inoperable.

**Comment:** When the candidate has declared the 'A' RBCCW pump inoperable, cue "The 'B' RBCCW pump is already Danger tagged out of service. Determine the required Tech Spec action(s)".

- 
- ✓ **Performance Step 5:** Determines that there is a 7 day LCO.

**Standard:** 7 day LCO declared.

**Comment:**

---

**Terminating Cue:** When the candidate has determined the required Tech Spec action(s), the examiner shall inform him/her that the task is complete.

# **ATTACHMENT 1 ANSWER SHEET**

ATTACHMENT 1A  
Sheet 6 of 6

## INSERVICE PUMP TESTING DATA SHEET (P-202A)

| TEST PARAMETER                         | REFERENCE VALUE |              | ACCEPTABLE RANGE | ALERT RANGE      |                  | REQUIRED ACTION RANGE |            | MEASURED VALUE     |                    |
|--|-----------------|--------------|------------------|------------------|------------------|-----------------------|------------|--------------------|--------------------|
|  |                 |              |                  | LOW              | HIGH             | LOW                   | HIGH       |                    |                    |
| SPEED (RPM)                            | NA              |              | NA               | NA               | NA               | NA                    | NA         | NA                 |                    |
| STOP SUCTION                           | ≥ 20 psig       |              | ≥ 20 psig        | NA               | NA               | NA                    | NA         | <b>21 psig</b>     |                    |
| RUNNING SUCTION (psig)                 | 38.5            |              | NA               | NA               | NA               | NA                    | NA         | <b>39.5 psig</b>   |                    |
| DISCHARGE PRESSURE AT SHUTOFF (psig)   | 92.5            |              | NA               | NA               | NA               | NA                    | NA         | <b>88.0 psig</b>   |                    |
| TOTAL HEAD (TH) AT SHUTOFF FT OF WATER | 124.7           |              | 116.0 to 130.9   | 112.2 to < 116.0 | > 130.9 to 137.2 | < 112.2               | > 137.2    | <b>111.99</b>      |                    |
| VIB. DISPLACEMENT (mils)               | (H)<br>0.07     | (V)<br>0.13  | 0 to 1 mil       | NA               | > 1 to 1.5 mils  | NA                    | > 1.5 mils | (H)<br><b>.08</b>  | (V)<br><b>.12</b>  |
| VIB. VELOCITY (in./sec)                | (H)<br>0.023    | (V)<br>0.025 | ≤ 0.314          | NA               | NA               | NA                    | NA         | (H)<br><b>.024</b> | (V)<br><b>.029</b> |

PERFORMED BY: (Signature) \_\_\_\_\_ DATE \_\_\_\_\_ TIME \_\_\_\_\_

IST REVIEW BY: (Signature) \_\_\_\_\_ DATE \_\_\_\_\_ TIME \_\_\_\_\_

### **CALCULATIONS:**

#### TOTAL HEAD

TH = [DISCH PRESS at shutoff – running suction pressure] x 2.309

TH = [( 88.0 ) psig – ( 39.5 ) psig] x 2.309

TH = 111.99 ft

**NOTES:** Reference Values: PNPS 8.5.3.1 on 1/8/98 (Hydraulic)  
PNPS 8.1.11.19 on 11/29/97 (Vibration)

### **TEST EQUIPMENT:**

| TEST PARAMETER             | INST NO.         | CAL. DATE         | CAL. DUE DATE     |
|----------------------------|------------------|-------------------|-------------------|
| DISCHARGE PRESS M&TE GAUGE | <u>_PIA-123_</u> | <u>_10/23/00_</u> | <u>_11/23/00_</u> |
| DISCHARGE PRESS M&TE GAUGE | <u>_PIA-124_</u> | <u>_10/20/00_</u> | <u>_11/20/00_</u> |
| VIBRATION                  | <u>_VIB-123_</u> | <u>_10/12/00_</u> | <u>_1/12/01_</u>  |

---

VERIFICATION OF COMPLETION

---

JPM No.: \_\_\_\_\_

Examinee's Name: \_\_\_\_\_

Examiner's Name: \_\_\_\_\_

Date performed: \_\_\_\_\_

Number of attempts: \_\_\_\_\_

Time to complete: \_\_\_\_\_

Question Documentation:

Question: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Response: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Result: **SAT** or **UNSAT**

Examiner's signature and date: \_\_\_\_\_



---

Job Performance Measure  
Quality Checklist

---

Every JPM should:

1.   ✓   Be supported by facility licensee's job task analysis.
2.   ✓   Be operationally important (meets NRC K/A Catalog threshold criterion of 2.5 (3 for requalification exams) or as determined by the facility and agreed to by the NRC).
3.   ✓   Be designed as either SRO only, RO/SRO or AO/RO/SRO.
4. Include the following, as applicable:
  - a.   ✓   Initial conditions
  - b.   ✓   Initiating cues
  - c.   ✓   References and tools, including associated procedures
  - d.   ✓   Validated time limits (average time allowed for completion) and specific designation of those JPMs that are deemed to be time-critical by the facility operations department
  - e.   ✓   Specific performance criteria that include:
    - (1)   ✓   Expected actions with exact control and indication nomenclature and criteria (switch position, meter reading), even if these criteria are not specified in the procedural step
    - (2)   ✓   System response and other cues that are complete and correct so that the examiner can properly cue the examinee, if asked
    - (3)   ✓   Statements describing important observations that should be made by the examinee
    - (4)   ✓   Criteria for successful completion of the task
    - (5)   ✓   Identification of those steps that are considered critical
    - (6)   ✓   Restrictions on the sequence of steps

## Information Provided to Candidate

**Initial Conditions:** Plant conditions are as follows:

- Procedure PNPS 8.5.3.1, "RBCCW Pump Operability And Flow Rate Tests" is in progress for Quarterly Pump Test on 'A' RBCCW pump.
- Data has been taken on the pump and is recorded in the working copy of the procedure.

**Initiating Cue:** "[Operator's name], complete Attachment 1A of PNPS 8.5.3.1 for the Quarterly Pump Test using data taken on the 'A' RBCCW pump.


**Radiation Work Permits**  
**Admin 4 Question #1:**

Using the attached survey, identify the radiological postings required at the entrance to the 'A' RHR Valve Room, if any.


Survey By: R.P. Teesh (Print) Signature: RP Teesh MAP # 33

|  |   |   |   |
|--|---|---|---|
| Dose Rate Inst: <u>20-2</u><br>= <u>836</u><br>= <u>12/19/00</u> | Cont. Inst: <u>RM-14</u><br>Serial No.: <u>3317</u><br>Cal Due: <u>12/23/00</u> | Alpha Contamination Inst: <u>SAC</u><br>Serial No.: <u>14</u><br>Cal Due: <u>1/1/01</u> | Date: <u>12/17/00</u><br>Time: <u>1140</u><br>Rx Power: <u>100</u> %<br>H2 Level: <u>32</u> SCF |
| Routine / Specific RWP <u>00-101</u>                             | Probe No.: <u>921</u><br>Cal Due: <u>12/11/00</u>                               | Collimated Probe # <u>1</u><br>Cal Due: <u>1</u>  | Status Map Updated Initial: <u>RP</u>   |
| Survivor's Dose: <u>2.6 mSv</u>                                  |   |   |   |

## A VALVE RM



| Contamination |      |          |
|---------------|------|----------|
| #             | Beta | Location |
| 1             | 6K   | 28A      |
| 2             | 6K   | side     |
| 3             | 2K   | 28A      |
| 4             | 6K   | 28A      |
| 5             | 6K   | 28A      |
| 6             | 1K   | 28A      |
| 7             | 1K   | 28A      |
| 8             | 2K   | 47       |
| 9             | 4K   | 28A      |
| 10            |      |          |
| 11            |      |          |
| 12            |      |          |
| 13            |      |          |
| 14            |      |          |
| 15            |      |          |
| 16            |      |          |
| 17            |      |          |
| 18            |      |          |
| 19            |      |          |
| 20            |      |          |
| 21            |      |          |
| 22            |      |          |
| 23            |      |          |
| 24            |      |          |
| 25            |      |          |
| 26            |      |          |
| 27            |      |          |
| 28            |      |          |
| 29            |      |          |
| 30            |      |          |



- AIRBORNE = .03 DAC**
1. Circled number indicates smear location
  2. Smears in dpm/100cm<sup>2</sup> unless indicated
  3. Triangles indicate air sample locations
  4. Underlined numbers are gamma dose in mR
  5. Squares indicate Beta dose rates in mrad/hr
  6. \*Indicate contact dose rates in mrad/hr
  7. Contamination in KDPM unless noted

**FOR TRAINING USE ONLY!!**

COMMENTS: head removed from 47 valve  
updated hot spot label 00-17

ROS Review: \_\_\_\_\_

**Radiation Work Permits**  
**Admin 4 Question #1:**

Using the attached survey, identify the radiological postings required at the entrance to the 'A' RHR Valve Room, if any.

Answer:

Caution (or Danger), High Radiation Area (0.33)  
Caution, Contaminated Area (0.33)  
RWP Required For Entry (0.33)

Open Reference

Reference: PNPS 6.1-025 Rev. 8 Section 3.0 Definition of Contaminated Area and High Radiation Area, Section 8.2 and 8.8

K/A: 2.3.10 2.9/3.3

**Radiation Work Permits**  
**Admin 4 Question #2:**

Under what conditions may a General RWP be used for access to a High Radiation Area?

**Radiation Work Permits**  
**Admin 4 Question #2:**

Under what conditions may a General RWP be used for access to a High Radiation Area?

Answer:

Operator Rounds (operator assigned to Radwaste inclusive) or inspections (0.5)

Radiation Protection entries and surveys (0.5)

Open Reference

Reference: 6.1-031 Rev. 7 Page 8

K/A: 2.3.10 2.9/3.3

---

### Job Performance Measure Worksheet

---

Facility: Pilgrim

Task No: 015-05-05-003

Task Title: Perform Dose Assessment Using  
DAPAR Software, V2.0

JPM No: Admin 5

K/A Reference: 295038 4.2/4.4 EK1.02

Position: RO/SRO

Examinee: \_\_\_\_\_

NRC Examiner: \_\_\_\_\_

Date: \_\_\_\_\_

Method of testing:

Simulated Performance \_\_\_\_\_

Actual Performance \_\_\_\_\_ ✓

Classroom \_\_\_\_\_

Simulator \_\_\_\_\_ ✓ Plant \_\_\_\_\_

#### Read to the Examinee:

"I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied."

- Initial Conditions:**
- A General Emergency has been declared following a LOCA.
  - The reactor has been shut down for 2 hours.
  - Time and date is what it is and it is a sunny day.
  - The release path is through the main stack.

**Task Standard:** Protective Action Recommendations shall be completed without assistance using the DAPAR software. The dose assessment shall be accomplished in accordance with EP-IP-300. There shall be no failure of critical elements. Critical steps must be performed in order. Other steps may be performed out of sequence.

**Required Materials:** None

**Note:** As part of the setup for the JPM, enter the data on Attachment 1 into the simulator.

**General References:** PNPS EP-IP-300, Rev. 3

**Initiating Cue:** "[Operator's name], perform an offsite dose assessment using the DAPAR computer software in accordance with EP-IP-300. Utilize the available Met tower and Main Stack high range effluent monitor data from panel C-170 to perform your dose assessment, and ignore all other simulator conditions. Obtain a printout of the dose assessment and inform me when you have determined if any subareas are required to be evacuated based on the dose assessment".

**Time Critical Task:** No

**Validation Time:** 10 Minutes



---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

---

**Performance Step 1:** Operator reviews the applicable sections of the procedure.

**Standard:** Section 5.0 of EP-IP-300 reviewed.

**Comment:**

---

**Performance Step 2:** Operator verifies the monitor is on, or turns on the monitor.

**Standard:** Power light on the monitor is illuminated.

**Comment:**

---

**Performance Step 3:** Operator verifies the printer is connected to the computer and is turned on, or connects the printer to the computer and turns on the printer.

**Standard:** Power on light on the printer is illuminated and printer is connected to the computer.

**Comment:**

---

**Performance Step 4:** Operator verifies a mouse is connected to the computer, or connects a mouse or other pointing device to the computer.

**Standard:** Mouse is connected to the computer.

**Comment:**

---

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

---

**Performance Step 5:** Operator verifies the keyboard is connected to the computer, or connects the keyboard to the computer.

**Standard:** Keyboard is connected to the computer.

**Comment:**

---

**Performance Step 6:** Operator verifies no floppy disks are inserted into the A drive, or removes any floppy disks in the A drive.

**Standard:** No floppy disks are in the A drive.

**Comment:**

---

✓ **Performance Step 7:** Operator turns the computer on, if it is not already on, pushes Control, Alt., and Delete (if required), double clicks on the mouse on the DAPAR V2.0 icon.

**Standard:** Computer is on. User logon window appears, DAPAR is started.

**Comment:**

---

✓ **Performance Step 8:** Operator selects 'Quick Assessment' option.

**Standard:** Quick Assessment screen appears.

**Comment:**

---

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

- ✓ **Performance Step 9:** Operator enters the following information to complete the Quick Assessment screen:

|                    |                                       |
|--------------------|---------------------------------------|
| Monitor            | (Main Stack)                          |
| Range              | (High Range)                          |
| Monitor Reading    | (200 R/hr.) – C170                    |
| Vent Flow Rate     | (4000 scfm) will appear automatically |
| Hours After S/D    | (2:00) Initial condition              |
| Tower Used         | (220') will appear automatically      |
| Wind Speed         | (15 MPH +/- 5 MPH) – Met tower panel  |
| Wind Direction     | (From 160 +/-10) – Met tower panel    |
| Delta T            | (3.0°F +/- 1) – Met tower panel       |
| Stability Class    | (F) will appear automatically.        |
| Weather Conditions | - Time of Year <u>Off-season</u>      |
|                    | - Time of Week <u>Midweek</u>         |
|                    | - Time of Day <u>Midday</u>           |
|                    | - Conditions <u>Good</u>              |
| Release Duration   | (5:45) will automatically appear      |

**Standard:** Operator inputs data correctly and DAPAR software accepts the above information until the PARs Command Button is enabled.

**Comment:**

- 
- ✓ **Performance Step 10:** Operator clicks on the PARs Command Button.

**Standard:** Protective Action Recommendation screen appears.

**Comment:**

- 
- ✓ **Performance Step 11:** Operator clicks on the print command button.

**Standard:** Protective Active Recommendations come out of the printer.

**Comment:**

---

**PERFORMANCE INFORMATION**  
(Critical steps denoted with a check mark)

---

✓

**Performance Step 12:** Operator determines no sub-areas require evacuation.

**Standard:** No sub-areas are recommended for evacuation.

**Comment:**

---

**Terminating Cue:** When the candidate has made his/her recommendation, the examiner will inform the candidate that the task is complete.

## **ATTACHMENT 1**

### **METEOROLOGICAL AND RADIOLOGICAL DATA FOR DOSE ASSESSMENT**

- **RM-1705-18A, Stack Gas MON #1 (RM02) Upscale**
- **RM-1705-18B, Stack Gas MON #2 (RM02) Upscale**
- **RT-1001-608, Main Stack Gas (RM02) to a value of 200R/Hr**
- **Tower Used** **I/O:** 220'
- **Wind Speed** **I/O:** 15 MPH
- **Wind Direction** **I/O:** 160° at 220'
- **MT1 Temp Recorder Point 1 (Delta 'T')** **I/O:** 3.0°F
- **MT1 Temp Recorder Point 2** **I/O:** 48°F

---

VERIFICATION OF COMPLETION

---

JPM No.: \_\_\_\_\_

Examinee's Name: \_\_\_\_\_

Examiner's Name: \_\_\_\_\_

Date performed: \_\_\_\_\_

Number of attempts: \_\_\_\_\_

Time to complete: \_\_\_\_\_

Question Documentation:

Question: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Response: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Result: **SAT** or **UNSAT**

Examiner's signature and date: \_\_\_\_\_

---

Job Performance Measure  
Quality Checklist

---

Every JPM should:

1.   ✓   Be supported by facility licensee's job task analysis.
2.   ✓   Be operationally important (meets NRC K/A Catalog threshold criterion of 2.5 (3 for  
  requalification exams) or as determined by the facility and agreed to by the NRC).
3.   ✓   Be designed as either SRO only, RO/SRO or AO/RO/SRO.
4. Include the following, as applicable:
  - a.   ✓   Initial conditions
  - b.   ✓   Initiating cues
  - c.   ✓   References and tools, including associated procedures
  - d.   ✓   Validated time limits (average time allowed for completion) and specific  
  designation of those JPMs that are deemed to be time-critical by the facility  
  operations department
  - e.   ✓   Specific performance criteria that include:
    - (1)   ✓   Expected actions with exact control and indication nomenclature and  
  criteria (switch position, meter reading), even if these criteria are not  
  specified in the procedural step
    - (2)   ✓   System response and other cues that are complete and correct so that  
  the examiner can properly cue the examinee, if asked
    - (3)   ✓   Statements describing important observations that should be made by the  
  examinee
    - (4)   ✓   Criteria for successful completion of the task
    - (5)   ✓   Identification of those steps that are considered critical
    - (6)   ✓   Restrictions on the sequence of steps

## Information Provided to Candidate

- Initial Conditions:**
- A General Emergency has been declared following a LOCA.
  - The reactor has been shut down for 2 hours.
  - Time and date is what it is and it is a sunny day.
  - The release path is through the main stack.

**Initiating Cue:** “[Operator’s name], perform an offsite dose assessment using the DAPAR computer software in accordance with EP-IP-300. Utilize the available Met tower and Main Stack high range effluent monitor data from panel C-170 to perform your dose assessment, and ignore all other simulator conditions. Obtain a printout of the dose assessment and inform me when you have determined if any subareas are required to be evacuated based on the dose assessment”.