

January 18, 2001

Mr. Harold B. Ray
Executive Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

SUBJECT: SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 -
WITHDRAWAL OF REQUEST FOR AMENDMENTS RE: TECHNICAL
SPECIFICATIONS SURVEILLANCE REQUIREMENT 3.0.3
(TAC NOS. MA8013 and MA8014)

Dear Mr. Ray:

By letter dated January 19, 2000, you proposed to revise the Technical Specification Surveillance Requirement (SR) 3.0.3. Presently, upon discovery that a surveillance was not performed within its specified frequency (a missed surveillance), SR 3.0.3 allows a delay "up to 24 hours or up to the limit of the specified Frequency, whichever is less." You proposed to revise the allowable delay up to 24 hours or up to the limit of the specified Frequency, whichever is greater. Subsequently, by letter dated January 4, 2001, you withdrew the request for the amendments. This completes our effort under technical assignment control (TAC) numbers MA8013 and MA8014, and the TACs are closed.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication.

Sincerely,

/RA/

L. Raghavan, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

Enclosure: Notice of Withdrawal

cc w/encl: See next page

January 18, 2001

Mr. Harold B. Ray
Executive Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

SUBJECT: SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 -
WITHDRAWAL OF REQUEST FOR AMENDMENTS RE: TECHNICAL
SPECIFICATIONS SURVEILLANCE REQUIREMENT 3.0.3
(TAC NOS. MA8013 and MA8014)

Dear Mr. Ray:

By letter dated January 19, 2000, you proposed to revise the Technical Specification Surveillance Requirement (SR) 3.0.3. Presently, upon discovery that a surveillance was not performed within its specified frequency (a missed surveillance), SR 3.0.3 allows a delay "up to 24 hours or up to the limit of the specified Frequency, whichever is less." You proposed to revise the allowable delay up to 24 hours or up to the limit of the specified Frequency, whichever is greater. Subsequently, by letter dated January 4, 2001, you withdrew the request for the amendments. This completes our effort under technical assignment control (TAC) numbers MA8013 and MA8014, and the TACs are closed.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication.

Sincerely,

/RA/

L. Raghavan, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 r/f

RidsNrrDlpmLpdiv (S.Richards)

RidsNrrPMLRaghavan

RidsNrrLAMMcAllister

RidsNrrDripRtsb (W.Beckner)

RidsAcrsAcnwMailCenter

RidsOgcRp

RidsRgn4MailCenter (C.Marschall, L.Hurley, D.Bujol)

Accession No: ML010180184

OFFICE	PDIV-2/PM	PDIV-D/LA	OGC	PDIV-2/SC
NAME	LRaghavan:lcc	MMcAllister		SDembek
DATE	1/17/01	1/17/01		1/18/01

OFFICIAL RECORD COPY

San Onofre Nuclear Generating Station, Units 2 and 3

February 15, 2000

cc:

Mr. R. W. Krieger, Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P. O. Box 128
San Clemente, CA 92674-0128

Mr. Douglas K. Porter
Southern California Edison Company
2244 Walnut Grove Avenue
Rosemead, CA 91770

Mr. David Spath, Chief
Division of Drinking Water and
Environmental Management
P. O. Box 942732
Sacramento, CA 94234-7320

Chairman, Board of Supervisors
County of San Diego
1600 Pacific Highway, Room 335
San Diego, CA 92101

Alan R. Watts, Esq.
Woodruff, Spradlin & Smart
701 S. Parker St. No. 7000
Orange, CA 92668-4720

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City of Riverside
3900 Main Street
Riverside, CA 92522

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Mr. Michael Olson
San Onofre Liaison
San Diego Gas & Electric Company
P.O. Box 1831
San Diego, CA 92112-4150

Mr. Steve Hsu

Radiologic Health Branch
State Department of Health Services
Post Office Box 942732
Sacramento, CA 94327-7320

Mr. Ed Bailey, Radiation Program Director
Radiologic Health Branch
State Department of Health Services
Post Office Box 942732 (MS 178)
Sacramento, CA 94327-7320

Resident Inspector/San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, CA 92674

Mayor
City of San Clemente
100 Avenida Presidio
San Clemente, CA 92672

Mr. Dwight E. Nunn, Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

Mr. Robert A. Laurie, Commissioner
California Energy Commission
1516 Ninth Street (MS 31)
Sacramento, CA 95814

UNITED STATES NUCLEAR REGULATORY COMMISSION
SOUTHERN CALIFORNIA EDISON COMPANY
SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3
DOCKET NOS. 50-361 AND 50-362
NOTICE OF WITHDRAWAL OF APPLICATION FOR
AMENDMENTS TO FACILITY OPERATING LICENSES

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Southern California Edison (licensee) to withdraw its January 19, 2000, application, for proposed amendments to Facility Operating Licenses No. NPF-10 and NPF-15 for the San Onofre Nuclear Generating Station, Units 2 and 3 respectively, located in San Diego County, California.

The proposed amendments would have modified facility Technical Specification Surveillance Requirement 3.0.3.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the *Federal Register* on April 19, 2000 (65 FR 21038). However, by letter dated January 4, 2001, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendments dated January 19, 2000, and the licensee's letter dated January 4, 2001, which withdrew the application for license amendments. These documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the ADAMS Public Library component on the NRC Web site (the Electronic Reading Room).

- 2 -

Dated at Rockville, Maryland, this 18th day of January, 2001.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

L. Raghavan, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation