

3

EXHIBIT 11

24/4

EXHIBIT 11

WPA/TPG/CAV/RXW
Phil M. Qualls (PMQ)
12/7/95
From: Phil M. Qualls (PMQ)
To: WPA, TPG, CAV, RXW
Date: Thursday, December 7, 1995 1:17 pm
Subject: REVIEW OF ALLEGATION 95-A-009

I have completed a review of the OI memorandum dated November 2, 1995, concerning ANO.

I reviewed the document and licensee statement for possible violations and safety concerns.

There appears to be very minimal safety concern. The ~~allegor~~ stated that the fire seal installation was completed inside of a junction box but that all screws may not have been reinstalled on the junction box. The junction box integrity is not an Appendix R concern.

A violation of licensee procedures may have occurred in that the employee stated that he signed off work as complete when it was not. The screws were not all in place. In my opinion any possible violation would be a NCV due to the low safety significance. There is also a possibility that the missing screws were identified by licensee QC during some post maintenance activity inspections.