



**Florida  
Power**

CORPORATION  
Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72

January 15, 2001  
3F0101-02

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

Subject: Monthly Operating Report

Dear Sir:

Florida Power Corporation hereby submits the Crystal River Unit 3 (CR-3) December 2000 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

D. L. Roderick  
Plant General Manager

DLR/ff

Attachment

xc: Regional Administrator, Region II  
Senior Resident Inspector  
NRR Project Manager

IES4

## APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-302  
UNIT NAME FLCRP-3  
DATE January 5, 2001  
COMPLETED BY L. J. Barbieri  
TELEPHONE (352) 795-6486 x3761

REPORTING PERIOD (Month/Year): December 2000

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	825		
2 MAXIMUM DEPENDABLE CAPACITY (MWe-Net)	843		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	8,574.5	141,590
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	8,555.5	139,338
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	633,872	7,197,730*	107,455,071*

\* The "YEAR TO DATE" and "CUMULATIVE" totals were increased 2,122MWHs.

The slight increase is an adjustment based on an error previously reported in April.

## APPENDIX B UNIT SHUTDOWNS

**DOCKET NO.** 50-302  
**UNIT NAME** FLCRP-3  
**DATE** January 5, 2001  
**COMPLETED BY** L. J. Barbieri  
**TELEPHONE** (352) 795-6486 x3761

**REPORTING PERIOD:** December 2000

No.	Date	Type	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
		F: Forced S: Scheduled				Comments
N/A						

### SUMMARY:

Crystal River Unit 3 operated for the entire month of December.

There were no plant shut downs or down powers greater than 20% during the month.

#### (1) Reason:

A-EQUIPMENT FAILURE (Explain)  
 B-MAINTENANCE OR TEST  
 C-REFUELING  
 D-REGULATORY RESTRICTION  
 E-OPERATOR TRAINING / LICENSE EXAMINATION  
 F-ADMINISTRATIVE  
 G-OPERATIONAL ERROR (Explain)  
 H-OTHER (Explain)

#### (2) Method:

1-MANUAL  
 2-MANUAL TRIP / SCRAM  
 3-AUTO TRIP / SCRAM  
 4-CONTINUATION  
 5-OTHER (Explain)