



## PECO NUCLEAR

A Unit of PECO Energy

**John Doering, Jr.**  
Vice President  
Peach Bottom Atomic Power Station

PECO Energy Company  
1848 Lay Road  
Delta, PA 17314-9032  
717 456 4000  
Fax 717 456 4243  
E-mail: jdoering@peco-energy.com

**January 4, 2001**

**Docket Nos. 50-277  
50-278**

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

**SUBJECT: 2000 Annual Report on Safety Relief Challenges for the Peach Bottom Atomic Power Station**

Gentlemen:

This represents the 2000 Annual Report on Safety Relief Challenges for the Peach Bottom Atomic Power Station (PBAPS) as required by the TMI Action Plan, Item II. K.3, and by PBAPS Technical Requirement Manual Appendix A Item 5.0 R17. During 2000 there were no automatic actuations of the Main Steam Relief Valves or the Main Steam Safety Valves in response to high reactor pressure.

If you have any questions regarding this matter, please call.

Sincerely,

John Doering, Jr.  
Vice President,  
Peach Bottom Atomic Power Station

*JD CHM CLB JJK*  
JD/PJD/CHM/CLB/JJK/jjk

cc: E. Salowitz, Public Service Electric & Gas  
R. R. Janati, Commonwealth of Pennsylvania  
R. I. McLean, State of Maryland  
H. J. Miller, Administrator, Region I, USNRC  
A.C. McMurtry, USNRC, Senior Resident Inspector  
A.F. Kirby, III, Delmarva Power & Light  
INPO Records Center  
A. Winter, PBAPS Experience Assessment  
Correspondence Control Desk, KSA 1-N

CCN# 01-14001

ADD1