



Monticello Nuclear Generating Plant  
2807 West County Road 75  
Monticello, MN 55362-9637

Operated by Nuclear Management  
Company LLC

January 23, 2001

Tech Spec Section 6.7.A.6

US Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

Annual Report of Safety Relief Valve Challenges  
January 1 through December 31, 2000

In accordance with Monticello Technical Specification Section 6.7.A.6, and NUREG 0737 item II.K.3.3, the following Annual Report of Safety Relief Valve Failures and Challenges is provided:

Failures:

For the period of January 1, 2000 to December 31, 200, no safety/relief valve (SRV) failures occurred.

Challenges:

2/28/2000 All eight SRVs were manually opened at reactor pressure of approximately 150 psig in accordance with a surveillance test performed during plant startup.

This letter contains no new NRC commitments, nor does it modify any prior commitments. Please contact Sam Shirey at (763) 295-1449 if you require additional information concerning this report.

Byron D. Day  
Plant Manager  
Monticello Nuclear Generating Plant

cc: Director, Office of Nuclear Regulatory Research  
Regional Administrator-III, NRC  
NRR Project Manager, NRC  
Resident Inspector, NRC  
Minnesota Department of Commerce

A 001