

STONE & WEBSTER ENGINEERING CORPORATION

CALCULATION TITLE PAGE

*SEE INSTRUCTIONS ON REVERSE SIDE

A 5010 64 (FRONT)

CLIENT & PROJECT PRIVATE FUEL STORAGE, LLC - PRIVATE FUEL STORAGE FACILITY				PAGE 1 OF 6	
CALCULATION TITLE (Indicative of the Objective): DYNAMIC SETTLEMENTS OF THE SOILS UNDERLYING THE SITE				QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER	
CALCULATION IDENTIFICATION NUMBER					
J. O. OR W. O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.	
05996.01	G(B)	11			
* APPROVALS - SIGNATURE & DATE			REV. NO. OR NEW CALC NO.	SUPERSEDES * CALC. NO. OR REV. NO.	CONFIRMATION * REQUIRED (✓) YES NO
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)			
PAUL J. TRUDEAU 5/20/97 <i>Paul J. Trudeau</i>	THOMAS E. SPONSELER 5/20/97 <i>Thomas E. Sponseler</i>	THOMAS E. SPONSELER 5/20/97 <i>Thomas E. Sponseler</i>	0		✓
DISTRIBUTION *					
GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	ORIG (BOSTON) COPY R4.2 FIRE FILE	✓ ✓ ✓			

9707300143 970714
PDR ADOCK 07200022
8 PDR

NOTED MAY 20 1997. P. J.
Irwin

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>2</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
05996.01	G(8)	11		

TABLE OF CONTENTS

	PAGE #
Title Page	1
Table of Contents	2
Objective	3
Method	3
Discussion	3
Conclusions	4
References	5
Figures	6

NOTED MAY 20 1997 P. J.
Trotter

CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
05996.01	G(B)	11		

OBJECTIVE:

Assess the potential for the soils underlying the proposed Private Fuel Storage Facility (PFSF) at the Skull Valley, UT site to experience dynamic settlements due to shaking caused by the design earthquake.

METHOD: Not required—See discussion below.

DISCUSSION:

Dynamic settlements due to the design earthquake are not expected to occur at the PFSF site because of the nature of the subsurface materials. Dynamic settlements, as reported in the geotechnical literature, are based on two different mechanisms, depending on whether the soils are above the groundwater table or below the groundwater table. Silver and Seed (1971) developed a technique for estimating dynamic settlements of dry cohesionless sands above the groundwater table. For such soils, the dynamic settlement mechanism is compaction due to soil grain slip, and it is a function of the magnitude of the cyclic shear strain developed due to the earthquake, the applied number of cycles of this shear strain, and the relative density of the soils.

Figure 1 presents a generalized subsurface profile, which was developed based on the borings that were drilled in late 1996. The groundwater table was not encountered in these borings, the deepest of which were drilled to depths of 100 ft. In addition, seismic refraction surveys indicate that the groundwater table is greater than ~100 ft below grade at the site (see p11 of Geosphere Midwest, 1997).

The top ~30 ft of the profile consists of silt, silty clay, and clayey silt. As documented in Calculation 05996.01-G(B)-05-0, the median blow count for this material is ~14 blows per ft, indicating that it is "stiff", it appears to be weakly cemented, and undrained triaxial tests on this material indicate that it has a cohesion of greater than 2000 psf. Therefore, the technique for estimating dynamic

NOTED MAY 20 1997 P. J.
Tredenn

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.Q. NO. 05996.01	DIVISION & GROUP G(B)	CALCULATION NO. 11	OPTIONAL TASK CODE

PAGE 4

1
2
3 settlements of soils above the groundwater table is not applicable for these
4 materials, since they are not expected to compact due to soil grain slip.
5

6
7 As indicated on the boring logs in PFSF Report 05996.01-G(B)-2-0 (SWEC, 1997),
8 this material is underlain by very dense, fine sands, which have uncorrected blow
9 counts that commonly exceed 100 blows per ft. The underlying soils, which are
10 below the groundwater table, are greater than 100 ft below grade, and the P-wave
11 velocities (5100 fps to 5900 fps), reported by Geosphere Midwest (1997), indicate
12 that these soils too are very dense. Further, these soil are too far removed from the
13 surface to cause problems if they were to experience dynamic settlement.
14
15

16
17 **CONCLUSIONS:**
18

19
20 The soils underlying the proposed site are not susceptible to dynamic settlements
21 due to shaking caused by the design earthquake, because above the groundwater
22 table, they are not cohesionless sands, and below the groundwater table, they are
23 very dense.
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

NOTED MAY 20 1997, P. J. Tinkman

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.Q. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
05996.01	G(B)	11		

REFERENCES:

- Geosphere Midwest, PFSF Report No. 0599601-G(PO9)-1, Rev 0, "Seismic Survey of the Private Fuel Storage Facility—Skull Valley, Utah," prepared for Stone & Webster Engineering Corp by Geosphere Midwest, Midland, MI, February 1997.
- Silver, M. and Seed, H. B., 1971, "Volume Changes in Sands During Cyclic Loading," Proceedings of the American Society of Civil Engineers, Journal of the Soil Mechanics and Foundations Division, Vol 97, SM9, September.
- SWEC (1997), PFSF Report No. 05996.01-G(B)-2 Rev 0, "Geotechnical Data Report," Stone & Webster Engineering Corporation, Boston, MA, 1997.

NOTED MAY 20 1997, P.L. *Truckee*

STONE & WEBSTER ENGINEERING CORPORATION

CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
05996.01	G(B)	11		

