



NOTE:  
A. THE VALVE MANIFOLD IS LOCATED ABOVE OR BELOW TRANSMITTER  
AS CLOSE AS POSSIBLE. (NOT MORE THAN 8" FROM  
CENTERLINE OF VALVE, TO THE BOTTOM OF TRANSMITTER.)

- REFERENCE DRAWINGS:
- |               |                            |
|---------------|----------------------------|
| 2-47610-3-1   | MECHANICAL CONTROL DIAGRAM |
| 2-47610-163-1 | REACTOR FEEDWATER SYSTEM   |
| 2-47610-163-1 | BILL OF MATERIAL           |
| 2-476491-583  | PILE CONSTRUCTION DETAILS  |
| 2-476491-584  | SUPPORT DETAILS            |
| 2-476491-585  | CONDUIT ISOMETRIC          |
| 2-476491-586  | REACTOR FEEDWATER SYSTEM   |
| 2-476491-587  | INSTRUMENT TABULATION      |

FOR ASME SECTION XI  
USE ONLY

☐ -ASME CODE CLASS 1 EQUIVALENT  
☐ -NON NUCLEAR CODE CLASS

[illegible]