

February 15, 2001

Mr. Mike Reandeau  
Director - Licensing  
Clinton Power Station  
P.O. Box 678  
Mail Code #V920  
Clinton, IL 61727

SUBJECT: CLINTON POWER STATION - EXTENSION OF EMERGENCY DIESEL  
GENERATOR ALLOWED OUTAGE TIME TO 14 DAYS (TAC NO. MB0861)

Dear Mr. Reandeau:

By letter dated December 29, 2000, AmerGen Energy Company, LLC (AmerGen, the licensee) submitted an application for license amendment to extend the Technical Specification (TS) allowed outage time (AOT) from 72 hours to 14 days for the Division 1 and 2 diesel generators (DGs).

Subsequently, by letter dated January 14, 2001, AmerGen requested enforcement discretion for the Division 2 DG, due to high vibration of a bearing during the 24-hour surveillance test. AmerGen also requested exigent review of the amendment request. The U.S. Nuclear Regulatory Commission (NRC) staff granted the enforcement discretion as discussed in a letter dated January 18, 2001. In that letter, the staff stated that it would review and issue the license amendment request as promptly as possible (i.e., exigent review schedule).

Upon further review, the NRC staff has found that permanent risk informed TS changes of a magnitude such as this one should not be reviewed and approved on an exigent basis. This particular risk informed permanent TS change requires a careful review because of the risk significance. We believe that this constitutes special circumstances under which exigent review is not appropriate following issuance of enforcement discretion. Therefore, the staff will review your amendment request on a normal priority schedule instead of an exigent schedule.

Contact me if you have any questions.

Sincerely,

**/RA/**

Jon B. Hopkins, Senior Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc: See next page

Mike Reandeau

Clinton Power Station, Unit 1  
AmerGen Energy Company, LLC

cc:

J. Michael Heffley  
Vice President  
Clinton Power Station  
P.O. Box 678  
Clinton, IL 61727

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
ATTN: Mr. Frank Niziolek  
1035 Outer Park Drive  
Springfield, IL 62704

Patrick Walsh  
Manager Nuclear Station  
Engineering Department  
Clinton Power Station  
P.O. Box 678  
Clinton, IL 61727

Kevin P. Gallen  
Morgan, Lewis & Bockius LLP  
1800 M Street, NW  
Washington, DC 20036

Resident Inspector  
U.S. Nuclear Regulatory Commission  
RR#3, Box 229 A  
Clinton, IL 61727

R. T. Hill  
Licensing Services Manager  
General Electric Company  
175 Curtner Avenue, M/C 481  
San Jose, CA 95125

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Chairman of DeWitt County  
c/o County Clerk's Office  
DeWitt County Courthouse  
Clinton, IL 61727

J. W. Blattner  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, IL 60603

Mr. Mike Reandeau  
Director - Licensing  
Clinton Power Station  
P.O. Box 678  
Mail Code #V920  
Clinton, IL 61727

February 15, 2001

SUBJECT: CLINTON POWER STATION - EXTENSION OF EMERGENCY DIESEL  
GENERATOR ALLOWED OUTAGE TIME TO 14 DAYS (TAC NO. MB0861)

Dear Mr. Reandeau:

By letter dated December 29, 2000, AmerGen Energy Company, LLC (AmerGen, the licensee) submitted an application for license amendment to extend the Technical Specification (TS) allowed outage time (AOT) from 72 hours to 14 days for the Division 1 and 2 diesel generators (DGs).

Subsequently, by letter dated January 14, 2001, AmerGen requested enforcement discretion for the Division 2 DG, due to high vibration of a bearing during the 24-hour surveillance test. AmerGen also requested exigent review of the amendment request. The U.S. Nuclear Regulatory Commission (NRC) staff granted the enforcement discretion as discussed in a letter dated January 18, 2001. In that letter, the staff stated that it would review and issue the license amendment request as promptly as possible (i.e., exigent review schedule).

Upon further review, the NRC staff has found that permanent risk informed TS changes of a magnitude such as this one should not be reviewed and approved on an exigent basis. This particular risk informed permanent TS change requires a careful review because of the risk significance. We believe that this constitutes special circumstances under which exigent review is not appropriate following issuance of enforcement discretion. Therefore, the staff will review your amendment request on a normal priority schedule instead of an exigent schedule.

Contact me if you have any questions.

Sincerely,

**/RA/**

Jon B. Hopkins, Senior Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc: See next page

DISTRIBUTION:

PD3-2 r/f      OGC  
PUBLIC      ACRS  
GGrant, RIII

OFFICE	PM:PD3-2	LA:PD3-2	SC:PD3-2
NAME	JHopkins	THarris	AMendiola
DATE	2/8/01	2/9/01	2/15/01

DOCUMENT NAME: G:\PDIII-2\CLINTON\edg-review-ltr.wpd  
OFFICIAL RECORD COPY