

# **FENOC**

FirstEnergy Nuclear Operating Company

Perry Nuclear Power Plant  
10 Center Road  
Perry, Ohio 44081

John K. Wood  
Vice President, Nuclear

440-280-5224  
Fax: 440-280-8029

February 13, 2001  
PY-CEI/LCDU-0061L

Attention: Robert Shelby, Mentor Waste Facility  
Lake County Department of Utilities  
P.O. Box 490  
Painesville, Ohio 44077-0490

Ladies and Gentlemen:

Enclosed are the results of an isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material was detected.

If you have questions or require additional information, please contact Mr. Leo Harte at (440) 280-5514.

Very truly yours,



LJH

Enclosures

cc: NRC Region III  
NRC Resident Inspector Office  
NRC Project Manager  
NRC Document Control Desk (Docket No. 50-440)

0001

Note:

Validate by Sample Screen

System Name:	ENVIRONMEN	Desc:	Environmental Sample
MPL Number:	SEWAGE	Desc:	Sewage Lift Station
Reason/Freq:	Q	Desc:	Quarterly
Mode Number:	6	Desc:	At All Times
Sample ID	313626	Date Collected:	9:20:00 2/07/01
Validation Status:	<input checked="" type="checkbox"/> (V/I)		


Status:

Isotopic by Gamma Spectroscopy

Limit:

0.00 to 0.00

0.00E+00 uCi/ml

MCA:  

NOTE: A numeric result of zero indicates 'None Detected'