

LIMITING CONDITIONS FOR OPERATION

3.7 CONTAINMENT SYSTEMS (Cont.)

A. Primary Containment (Cont.)

With no H₂ analyzer operable, reactor operation is allowed for up to 48 hours. If one of the inoperable analyzers is not made fully operable within 48 hours, the reactor shall be in at least Hot Shutdown within the next 12 hours.

B. Standby Gas Treatment System and Control Room High Efficiency Air Filtration System

1. Standby Gas Treatment System

- a. Except as specified in 3.7.B.1.c or 3.7.B.1.e below, both trains of the standby gas treatment shall be operable when in the Run, Startup, and Hot Shutdown MODES, during movement of irradiated fuel assemblies in the secondary containment, and during movement of new fuel over the spent fuel pool, and during **CORE ALTERATIONS**, and during operations with a potential for draining the reactor vessel (OPDRVs),

or

the reactor shall be in cold shutdown within the next 36 hours.

- b. 1. The results of the in-place cold DOP tests on HEPA filters shall show $\geq 99\%$ DOP removal. The results of halogenated hydrocarbon tests on charcoal adsorber banks shall show $\geq 99.9\%$ halogenated hydrocarbon removal.

SURVEILLANCE REQUIREMENTS

4.7 CONTAINMENT SYSTEMS (Cont.)

B. Standby Gas Treatment System and Control Room High Efficiency Air Filtration System

1. Standby Gas Treatment System

- a. 1. At least once per operating cycle, it shall be demonstrated that pressure drop across the combined high efficiency filters and charcoal adsorber banks is less than 8 inches of water at 4000 cfm.
2. At least once per operating cycle, demonstrate that the inlet heaters on each train are operable and are capable of an output of at least 14 kW.
3. The tests and analysis of Specification 3.7.B.1.b. shall be performed at least once per operating cycle or following painting, fire or chemical release in any ventilation zone communicating with the system while the system is operating that could contaminate the HEPA filters or charcoal adsorbers.
4. At least once per operating cycle, automatic initiation of

LIMITING CONDITIONS FOR OPERATION

3.7 CONTAINMENT SYSTEMS (Cont.)

B. Standby Gas Treatment System and Control Room High Efficiency Air Filtration System (Cont.)

b. 2. The results of the laboratory carbon sample analysis shall show each carbon adsorber bank is capable of $\geq 97.5\%$ methyl iodide removal at 70% R.H. and 86°F. The carbon sample shall be obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978 and tested in accordance with ASTM D3803-1989. The analysis results are to be verified as acceptable within 31 days after sample removal, or declare that train inoperable and take the actions specified in 3.7.B.1.c.

c. From and after the date that one train of the Standby Gas Treatment System is made or found to be inoperable for any reason, continued reactor operation, irradiated fuel handling, or new fuel handling over the spent fuel pool is permissible only during the succeeding seven days providing that within 2 hours all active components of the other standby gas treatment train are verified to be operable and the diesel generator associated with the operable train is operable.

If the system is not made fully operable within 7 days, reactor shutdown shall be initiated and the reactor shall be in cold shutdown within the next 36 hours and fuel handling operations shall be terminated within 2 hours.

Fuel handling operations in progress may be completed.

SURVEILLANCE REQUIREMENTS

4.7 CONTAINMENT SYSTEMS (Cont.)

B. Standby Gas Treatment System and Control Room High Efficiency Air Filtration System (Cont.)

each branch of the standby gas treatment system shall be demonstrated, with Specification 3.7.B.1.d satisfied.

5. Each train of the standby gas treatment system shall be operated for at least 15 minutes per month.

6. The tests and analysis of Specification 3.7.B.1.b.2 shall be performed after every 720 hours of system operation.

b. 1. In-place cold DOP testing shall be performed on the HEPA filters after each completed or partial replacement of the HEPA filter bank and after any structural maintenance on the HEPA filter system housing which could affect the HEPA filter bank bypass leakage.

2. Halogenated hydrocarbon testing shall be performed on the charcoal adsorber bank after each partial or complete replacement of the charcoal adsorber bank or after any structural maintenance on the charcoal adsorber housing which could affect the charcoal adsorber bank bypass leakage.

LIMITING CONDITIONS FOR OPERATION

3.7 CONTAINMENT SYSTEMS (Cont.)

B. Standby Gas Treatment System and Control Room High Efficiency Air Filtration System (Cont.)

2. Control Room High Efficiency Air Filtration System

- a. Except as specified in Specification 3.7.B.2.c or 3.7.B.2.e below, both trains of the Control Room High Efficiency Air Filtration System used for the processing of inlet air to the control room under accident conditions shall be operable when in the Run, Startup, and Hot Shutdown MODES, during movement of irradiated fuel assemblies in the secondary containment, and during movement of new fuel over the spent fuel pool, and during CORE ALTERATIONS, and during operations with a potential for draining the reactor vessel (OPDRVs),

or

the reactor shall be in cold shutdown within the next 36 hours.

- b. 1. The results of the in-place cold DOP tests on HEPA filters shall show $\geq 99\%$ DOP removal. The results of the halogenated hydrocarbon tests on charcoal adsorber banks shall show $\geq 99.9\%$ halogenated hydrocarbon removal when test results are extrapolated to the initiation of the test.
2. The results of the laboratory carbon sample analysis shall show $\geq 97.5\%$ methyl iodide removal at 70% R.H and 86°F. The carbon sample shall be obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978 and tested in accordance with ASTM D3803-1989. The analysis results are to be verified as acceptable within 31 days after sample removal, or declare that train inoperable and take the actions specified in 3.7.B.2.c.

SURVEILLANCE REQUIREMENTS

4.7 CONTAINMENT SYSTEMS (Cont.)

B. Standby Gas Treatment System and Control Room High Efficiency Air Filtration System (Cont.)

2. Control Room High Efficiency Air Filtration System

- a. At least once per operating cycle the pressure drop across each combined filter train shall be demonstrated to be less than 6 inches of water at 1000 cfm or the calculated equivalent.

- b. 1. The tests and analysis of Specifications 3.7.B.2.b shall be performed once per operating cycle or following painting, fire or chemical release in any ventilation zone communicating with the system while the system is operating.

2. In-place cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing which could affect the HEPA filter bank bypass leakage.

3. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing which could affect the charcoal adsorber bank bypass leakage.

4. Each train shall be operated with the heaters in automatic for at least 15 minutes every month.

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- i. Limitations on the annual and quarterly doses to a member of the public from Iodine-131, Iodine-133, Tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I; and
- j. Limitations on the annual dose or dose commitment to any member of the public due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the FSAR Section C.3.4.1, cyclic and transient occurrences to ensure that components are maintained within the design limits.

5.5.6 Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

- a. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews.
- b. Licensees may make changes to Bases without prior NRC approval provided the changes do not involve either of the following:
 - 1. a change in the TS incorporated in the license; or
 - 2. a change to the updated FSAR or Bases that involves an unreviewed safety question as defined in 10 CFR 50.59.
- c. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the FSAR.
- d. Proposed changes that meet the criteria of Specification 5.5.6b above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

(continued)

5.5 Programs and Manuals

5.5.7 Configuration Risk Management Program (CRMP)

CRMP provides a proceduralized risk-informed assessment to manage the risk associated with equipment inoperability. The program applies to technical specification structures, systems, or components for which a risk-informed allowed outage time has been granted.

The CRMP includes the following elements:

- a. Provisions for the control and implementation of a Level 1 at power internal event PRA-informed methodology. The assessment is capable of evaluating the applicable plant configuration.
 - b. Provisions for performing an assessment prior to entering the LCO Action Statement for preplanned activities.
 - c. Provisions for performing an assessment after entering the LCO Action Statement for unplanned entry into the LCO Action Statement activities.
 - d. Provisions for assessing the need for additional actions after the discovery of additional equipment out of service conditions while in the LCO Action Statement.
 - e. Provisions for considering other applicable risk significant contributors such as Level 2 issues and external events, quantitatively or qualitatively.
-

5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Occupational Radiation Exposure Report

A tabulation on an annual basis of the number of station, utility, and other personnel (including contractors) receiving exposures > 100 mrem/yr and their associated man rem exposure according to work and job functions (e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (including description), waste processing, and refueling). This tabulation supplements the requirements of 10 CFR 20.2206. The dose assignments to various duty functions may be estimated based on pocket dosimeter, thermoluminescent dosimeter (TLD), or film badge measurements. Small exposures totaling < 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources should be assigned to specific major work functions. The report shall be submitted by April 30 of each year.

5.6.2 Annual Radiological Environmental Operating Report

The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

The Annual Radiological Environmental Operating Report shall include a summary of the results of analyses of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the table and figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

(Continued)

5.6 Reporting Requirements

5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the unit shall be submitted in accordance with 10 CFR 50.36a by May 15th of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and process control procedures and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 Core Operating Limits Report (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
 1. Table 3.1.1 Å APRM High Flux trip level setting
 2. Table 3.2.C ÅAPRM Upscale trip level setting
 3. 3.11.A Å Average Planar Linear Heat Generation Rate (APLHGR)
 4. 3.11.B Å Linear Heat Generation Rate (LHGR)
 5. 3.11.C ÅMinimum Critical Power Ratio (MCPR)
 6. 3.11.D Å Power/Flow Relationship During Power Operation
 7. 4.2 Å Reactor Core
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
 1. NEDE-24011-P-A, "General Electric Standard Application for Reactor Fuel," (the approved version at the time the reload analyses are performed shall be identified in the COLR).

(Continued)

5.6 Reporting Requirements

5.6.5 (continued)

2. NEDC-31852P, "Pilgrim Nuclear Power Station SAFER/GESTR-LOCA Loss of Coolant Accident Analysis", dated September, 1990 (the approved version at the time the reload analyses are performed shall be identified in the COLR), and
 3. NEDC-31312-P, "ARTS Improvement Program Analyses for Pilgrim Nuclear Power Station", dated September 1987, (the approved version at the time the reload analyses are performed shall be identified in the COLR).
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as shutdown margin, transient analysis limits, and accident analysis limits) of the safety analysis are met.
 - d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.
-

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.1 Pursuant to 10 CFR 20, paragraph 20.1601(c), in lieu of the requirements of 10 CFR 20.1601, each high radiation area, as defined in 10 CFR 20, in which the intensity of radiation is > 100 mrem/hr but < 1000 mrem/hr, shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP). Individuals qualified in radiation protection procedures (e.g., Health Physics personnel) or personnel continuously escorted by such individuals may be exempt from the RWP issuance requirement during the performance of their assigned duties in high radiation areas with exposure rates ≤ 1000 mrem/hr, provided they are otherwise following plant radiation protection procedures for entry into such high radiation areas.

Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device that continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device that continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate levels in the area have been established and personnel are aware of them.
- c. An individual qualified in radiation protection procedures with a radiation dose rate monitoring device, who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the Radiation Protection Manager in the RWP.

5.7.2 In addition to the requirements of Specification 5.7.1, areas with radiation levels ≤ 1000 mrem/hr shall be provided with locked or continuously guarded doors to prevent unauthorized entry and the keys shall be maintained under the administrative control of the Nuclear Watch Engineer on duty or health physics supervision. Doors shall remain locked except during periods of access by personnel under an approved RWP that shall specify the dose rate levels in the immediate work areas and the maximum allowable stay times for individuals in those areas. In lieu of the stay time specification of the RWP, direct or remote (such as closed circuit TV cameras) continuous surveillance may be made by

(Continued)

5.7 High Radiation Area

5.7.2 (continued)

personnel qualified in radiation protection procedures to provide positive exposure control over the activities being performed within the area.

5.7.3

For individual high radiation areas with radiation levels of > 1000 mrem/hr, accessible to personnel, that are located within large areas such as reactor containment, where no enclosure exists for purposes of locking, or that cannot be continuously guarded, and where no enclosure can be reasonably constructed around the individual area, that individual area shall be barricaded and conspicuously posted, and a flashing light shall be activated as a warning device.
