

March 5, 2001

Mr. John H. Mueller
Chief Nuclear Officer
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Operations Building, Second Floor
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 1 - WITHDRAWAL OF
REPORTING REQUIREMENT IMPOSED BY SAFETY EVALUATION DATED
AUGUST 11, 1994 (TAC NOS. M85003 AND MB1100)

Dear Mr. Mueller:

By letter dated August 11, 1994 (D. S. Brinkman to B. R. Sylvia), the NRC staff transmitted its safety evaluation (SE) on reduction factors used for condensation oscillation loads in the torus. Among other things, the transmittal letter and the SE state that it is appropriate for Niagara Mohawk Power Corporation (NMPC) to continue monitoring the corrosion rate of the torus shell to ensure that any reduction in the shell thickness due to corrosion will not result in stresses greater than the Code allowable in future operation, and that results of such monitoring program be submitted to the NRC within 60 days after completion of each inspection (see last paragraph of page 6 of the SE). By letter dated September 14, 1994, NMPC accordingly made such a commitment.

Subsequently, NMPC submitted numerous letters documenting inspection results. The most recent letter was dated October 13, 2000. All NMPC's letters reported the average wall thickness to be greater than the minimum 0.431 inches found acceptable in the staff's SE.

Having noted the inspection results transmitted by NMPC's letters, and recognizing that the inspections will continue to be performed by NMPC and results available onsite for NRC review, the staff determines that there is no more need for NMPC to submit such results for the docket. In effect, the last paragraph of page 6 of the SE is deleted as of today. This deletion only eliminates the need to submit future torus reinspection results to the NRC; it does not obviate the need for NMPC to perform measurements and record the results, or otherwise affect other commitments and requirements described in NMPC's submittals referenced in the SE. If you have any questions, please feel free to call me at 301-415-1451.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

Mr. John H. Mueller
Chief Nuclear Officer
Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Operations Building, Second Floor
Lycoming, NY 13093

March 5, 2001

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 1 - WITHDRAWAL OF
REPORTING REQUIREMENT IMPOSED BY SAFETY EVALUATION DATED
AUGUST 11, 1994 (TAC NOS. M85003 AND MB1100)

Dear Mr. Mueller:

By letter dated August 11, 1994 (D. S. Brinkman to B. R. Sylvia), the NRC staff transmitted its safety evaluation (SE) on reduction factors used for condensation oscillation loads in the torus. Among other things, the transmittal letter and the SE state that it is appropriate for Niagara Mohawk Power Corporation (NMPC) to continue monitoring the corrosion rate of the torus shell to ensure that any reduction in the shell thickness due to corrosion will not result in stresses greater than the Code allowable in future operation, and that results of such monitoring program be submitted to the NRC within 60 days after completion of each inspection (see last paragraph of page 6 of the SE). By letter dated September 14, 1994, NMPC accordingly made such a commitment.

Subsequently, NMPC submitted numerous letters documenting inspection results. The most recent letter was dated October 13, 2000. All NMPC's letters reported the average wall thickness to be greater than the minimum 0.431 inches found acceptable in the staff's SE.

Having noted the inspection results transmitted by NMPC's letters, and recognizing that the inspections will continue to be performed by NMPC and results available onsite for NRC review, the staff determines that there is no more need for NMPC to submit such results for the docket. In effect, the last paragraph of page 6 of the SE is deleted as of today. This deletion only eliminates the need to submit future torus reinspection results to the NRC; it does not obviate the need for NMPC to perform measurements and record the results, or otherwise affect other commitments and requirements described in NMPC's submittals referenced in the SE. If you have any questions, please feel free to call me at 301-415-1451.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

DOCUMENT NAME: **ML010470381**

OFFICE	PM:PDI-1	LA:PDI-1	EMEB	SC:EMEB	SC:PDI-1	
NAME	PTam	SLittle	BJain	KManoly	PTam for MGamberoni	
DATE	2/28/01	2/28/01	2/28/01	3/1/01	3/2/01	

Official Record Copy

DATED: March 5, 2001

WITHDRAWAL OF REPORTING REQUIREMENT IMPOSED BY SE DATED AUGUST 11,
1994

PUBLIC

PDI Reading

M. Gamberoni

S. Little

P. Tam

OGC

ACRS

B. Platchek, Region I

cc: Plant Service list

Nine Mile Point Nuclear Station
Unit No. 1

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 126
Lycoming, NY 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Paul D. Eddy
Electric Division
NYS Department of Public Service
Agency Building 3
Empire State Plaza
Albany, NY 12223

Mr. William M. Flynn, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Gary D. Wilson, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, NY 13202

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126