

February 16, 2001

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Grand Gulf Nuclear Station
Docket No. 50-416
License No. NPF-29
Relocation of SR 3.8.3.6 Fuel Oil Storage Tank Surveillance to the
UFSAR per NRC Letter Dated June 30, 2000 (TSTF-2) Amendment
142

GNRO-2001/00014


Ladies & Gentlemen:

In a letter from the NRC to Grand Gulf Nuclear Station dated June 30, 2000 (TAC NO. MA6765/GNRI-2000/00065) the following statement was included.

"In the application of TSTF 2 to the TSs, it was stated that the requirements of SR 3.8.3.6 on cleaning of the emergency diesel generator fuel oil storage tank will be relocated to the GGNS Updated Final Safety Analysis Report (UFSAR). We are relying on that in approving the application of TSTF-2 to the TSs. You are requested to include this relocation in the next update to the UFSAR in accordance with 10 CFR 50.71 (e) and to state in the letter submitting this update to the Commission that the update includes this relocation."

As requested by the staff, we did relocate SR 3.8.3.6 to the UFSAR. This change was included in the UFSAR 10CFR50.71(e) update (page 16B.1-109A) we submitted via CD-ROM on October 5, 2000 (GNRO-2000/00069). However, a specific statement was not included in the letter stating we had relocated this information. This letter serves as notification that SR 3.8.3.6 has been relocated as required and that the October 5, 2000 UFSAR update included this item. The UFSAR page has been included in this letter for information. It should be noted that Grand Gulf is submitting UFSAR updates in excess of 10CFR50.71(e) update requirements for the purpose of promotion of the living UFSAR concept. If you have any questions please contact Michael Larson at 601-437-6685. **This letter does contain any commitments.**

Yours truly,



CAB/MJL
attachment: Page 16B.1-109 of the Grand Gulf UFSAR

cc: (See Next Page)

cc:

Hoeg	T. L.	GGNS Senior Resident)	(w/a)
Levanway	D. E.	(Wise Carter)	(w/a)
Reynolds	N. S.		(w/a)
Smith	L. J.	(Wise Carter)	(w/a)
Thomas	H. L.		(w/o)

Mr. E. W. Merschoff (w/2) Regional Administrator U.S. Nuclear Regulatory Commission Region IV 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011	ALL LETTERS
Mr. S. P. Sekerak, NRR/DLPM/PD IV-1 (w/2) ATTN: ADDRESSEE ONLY U.S. Nuclear Regulatory Commission One White Flint North, Mail Stop O7-D1 11555 Rockville Pike Rockville, MD 20852-2378	ALL LETTERS

GG
UFSAR

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR TR3.8.3.6 For each fuel oil storage tank:</p> <ul style="list-style-type: none">a. Drain the fuel oil;b. Remove the sediment; andc. Clean the tank. <p>Draining of the fuel oil stored in the supply tanks, removal of accumulated sediment, and tank cleaning are required at 10 year intervals by Regulatory Guide 1.137, paragraph 2.f. This SR is typically performed in conjunction with the ASME Boiler and Pressure Vessel Code, Section XI, examinations of the tanks. To preclude the introduction of surfactants in the fuel oil system, the cleaning should be accomplished using sodium hypochlorite solutions, or their equivalent, rather than soap or detergents. This SR is for preventive maintenance. The presence of sediment does not necessarily represent a failure of this SR provided that accumulated sediment is removed during performance of the Surveillance.</p>	<p>10 years</p>