

To: DC DESK

MAC: N/A

Destination:

Description: NRC

Document:	Revision:	II	IC#	Comment:	Select Copy Totals
EM0204B	28				1
EM0213	28				1
EM0219	14				1

Instructions to the Addressee: Please verify the document(s) received agrees with the above information. Notify Document Control if changes are required to addressee information.

Engineering managers are required by NEP-121 to determine if new, revised, or temporary changes to procedures affect job functions of their personnel. Managers will communicate change information appropriately and provide documentation of any training conducted to the Engineering Training Coordinator.

NO ACKNOWLEDGEMENT REQUIRED

(End of Page)

A045



FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
PLANT OPERATING MANUAL

EMERGENCY PLAN IMPLEMENTING PROCEDURE

EM-204B

**OFF-SITE DOSE ASSESSMENT DURING
RADIOLOGICAL EMERGENCIES
(USER INSTRUCTIONS FOR RADDOSE-IV)**

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 PURPOSE	3
2.0 REFERENCES	3
2.1 Developmental References	3
3.0 PERSONNEL INDOCTRINATION	3
3.1 Definitions	3
3.2 Responsibilities	4
3.3 Limits & Precautions	4
4.0 INSTRUCTIONS	5
4.1 Communications.....	5
4.2 Program Startup.....	5
4.3 Data Input	6
4.4 Data Output	12
4.5 Protective Actions Recommendation.....	14
4.6 Documentation.....	14

ENCLOSURES

1	Reference Source Terms for Dose Assessment	15
2	Conference Call Instructions.....	16
3	RADDOSE-IV Installation Instructions	17
4	Data From the Plant Computer.....	18
5	Input Data Sheet for RADDOSE-IV (Optional Records Non-Quality)	24
6	Copying RADDOSE-IV Data Files	26
7	Alternate Methods for Determining Meteorological Data	27
8	Selection of Accident Type	28
9	Noble Gas and Iodine Methods Descriptions.....	32
10	Steam Generator Tube Rupture Evaluation (Optional Records Non-Quality)	33
11	Source Term Determination for LOCA in Containment (Optional Records Non-Quality)	36
12	Instructions for Entering Multiple Accidents and Release Points	37
13	Iodine Ratio Method (Optional Records Non-Quality).....	38
14	Instructions for Correcting and Recalculating a Step.....	39

1.0 PURPOSE

The RADDPOSE-IV Computer model provides a method to evaluate the magnitude of a radiological release from CR-3, to track the plume, and to estimate offsite exposure. This procedure contains operating instructions for RADDPOSE-IV and information to be used in developing program inputs.

[NOCS 00388,00389,01029,01062,01128,01582,01589,01592,05647
12210,13040,13140]

2.0 REFERENCES

2.1 Developmental References

- 2.1.1 RADDPOSE-IV Operator's Manual
- 2.1.2 RADDPOSE-IV Detailed Design Manual
- 2.1.3 RADDPOSE-IV Verification & Validation Manual
- 2.1.4 CR-3 Radiological Emergency Response Plan (RERP)
- 2.1.5 EM-202, Duties of Emergency Coordinator
- 2.1.6 Manual of Protective Action Guides and Protective Actions for Nuclear Incidents, EPA-400-R-92-001 Environmental Protection Agency (October, 1991).
- 2.1.7 B&W Nuclear Technologies Document 77-1206359-00 (steam generator tube rupture offsite doses calculated with CRAC2 computer code)
- 2.1.8 Nuclear Regulatory Commission Response Technical Manual.
- 2.1.9 Final Safety and Analysis Report.

3.0 PERSONNEL INDOCTRINATION

NOTE

A safety assessment was performed for this procedure. A determination was made that this procedure is outside the scope of 10 CFR.50.59.

3.1 Definitions

- 3.1.1 **Advection Step** - ("time step" or "step") The entry of a set of meteorological and source term data into RADDPOSE-IV and performance of calculations.
- 3.1.2 **Core Melt** - deformation of fuel pellet configuration due to excessive core temperature releasing large quantities of gaseous and particulate fission products.
- 3.1.3 **Depletion** - reduction of the concentration of the plume (i.e., deposition and dispersion).
- 3.1.4 **Deposition** - a means of puff depletion that deposits particulate radioactive material on the ground.
- 3.1.5 **Field** - the space provided on the monitor for one value on the meteorological and source term entry screens.

- 3.1.6 **Gas Gap Failure** - degradation of the protective cladding around the fuel pellets due to elevated core temperature releasing only gaseous activities contained in the space between pellet and the cladding.
- 3.1.7 **Sea breeze Effect** - a wind circulation system produced when the land temperature is higher than the ocean temperature causing a lower level wind direction from sea to land.
- 3.1.8 **Sigma-Theta** - The standard deviation of a set of wind range measurements. The Sigma-Theta meter automatically calculates and displays the standard deviation of wind range for the previous 15 minutes.
- 3.1.9 **Stability Class** - a lettering system from A to G to designate certain atmospheric conditions which affect the dispersion of the plume. Class A indicates rapid dispersion and class G indicates slow dispersion.
- 3.2 Responsibilities**
- 3.2.1 The Emergency Coordinator (EC) is responsible for ensuring the Dose Assessment Team is aware of plant development related to offsite dose projections.
- 3.2.2 The Dose Assessment team is responsible for the implementation of this procedure.
- 3.3 Limits & Precautions**
- 3.3.1 Protective Action Guideline doses from the Environmental Protection Agency are 1 REM TEDE and 5 REM Thyroid at the site boundary (0.83 miles). EM-202 Enclosure 1 specifies conditions in which site boundary dose or dose rate may require declaration of a Site Area Emergency or General Emergency.
- 3.3.2 The RADDOSE-IV model has several switches (options) that may be set during program startup which affect the method the model uses to calculate doses. The calculation switches have been pre-set, but further details are available in the Operator's Manual, Section 2.3.1.
- 3.3.3 Detailed instructions, notes, and cautions are provided on various screens depending on input and parameters.
- 3.3.4 Doses calculated by RADDOSE-IV are approximately two times the doses calculated by the NRC's RASCAL model. To perform a reasonable comparison, inputs to both models must match as closely as possible (i.e., isotopic distribution, Ci/sec, meteorological data, exposure location, and exposure duration).
- 3.3.5 In a station blackout, the following instrumentation is available:
- RM-A1, RM-A2 meters and detectors powered, but not pumps.
 - RM-Gs 1, 3, 5, 7, 9, 11, 25, 26, 27, 28, 29, 30.
 - RM-Ls 2, 7.
 - Primary Meteorological Tower local readouts only (at the tower).
- 3.3.6 Recorder AH-32-FIR Channel D indicates total Reactor Building stack flow and is the correct flow to use when using RM-A1 as the RADDOSE-IV release method. AH-294-FT measures Reactor Building purge flow rate only and does not include make up flow.

4.0 INSTRUCTIONS

4.1 Communications

4.1.1 Using the Dose Assessment Ringdown Telephone, ESTABLISH communications among the TSC and EOF Dose Assessment Teams (DATs) and the Dose Assessment Communicator in the Control Room monitoring radiological and meteorological data. [NOCS 00387]

4.1.1.1 LIFT the receiver of the Dose Assessment Ringdown telephone and the telephones at the other facility (TSC or EOF) and Control Room automatically ring.

4.1.2 IF the Dose Assessment Ringdown telephone is inoperable,
THEN REFER TO Enclosure 2 for instruction on establishing a conference call on the conventional telephone.

4.1.3 REQUEST the Dose Assessment Communicator in the Control Room SCAN the monitors and provide all abnormal readings (especially effluent monitors).

4.2 Program Startup

4.2.1 IF the dose assessment computer fails,
THEN CONSIDER the following alternatives:

- o OBTAIN dose projection data from the other facility (TSC or EOF) as appropriate.
- o USE EM-204(A) as backup dose assessment.
- o INSTALL RADDose-IV on another computer. REFER TO Enclosure 3 for program installation instructions.

4.2.2 LOG ON to computer.

4.2.3 START RADDose-IV by double clicking on the RADDose-IV icon on the desktop.

4.2.4 ACKNOWLEDGE Current Switch Settings (options for decay and depletion calculations, etc.).

4.2.5 From the Startup Menu, SELECT either:

- o Begin New Incident - This selection erases previously stored data and displays the Accident Definition Screen.
- or
- o Continue Previous Incident - This selection recalls all entries and calculations for the previous incident and allows continuation.

4.2.6 IF previous incident data has been stored on a diskette(s),
THEN REFER TO Enclosure 6 for loading instructions.

4.3 Data Input

4.3.1 OBTAIN Meteorological data and radiological data from the Control Room or by using the plant computer. REFER TO Enclosure 4 for plant computer instructions. [NOCS 00387]

4.3.2 RECORD input data on Enclosure 5, Input Data Sheet for RADDose-IV if desirable.

4.3.3 Accident Scenario Definition Screen

ENTER the following information:

- o Trip/decay start date
- o Trip/decay start time
- o Release date
- o Release time
- o Time step (normally 30 minute increments)
- o Sea breeze effects (normally "ON")
- o Operator's initials

4.3.4 Meteorological Data Input Screen

4.3.4.1 USE the following priority when collecting wind speed, wind direction and outside air temperature:

1. 33' Primary Tower
2. 175' Primary Tower
3. 33' Alternate Tower (only source for Sigma-Theta, precipitation rate.

4.3.4.2 IF Sigma-Theta is not available,
THEN USE the wind range to establish the stability class.
REFER to Enclosure 7, Alternate Methods for Determining Meteorological Data.

4.3.4.3 IF Control Room instrumentation is used to obtain meteorological data,
THEN ENSURE that values for wind speed, average wind direction, and wind range are determined using the average of the previous 15 minutes as displayed on the appropriate recorder.

4.3.4.4 From the Main Menu, SELECT "Enter/Edit Meteorological Data."

4.3.4.5 ENTER the following data (if not available from the plant computer or the Control Room, REFER TO Enclosure 7):

- o Wind speed (meters/second, 15-minute average)
- o Wind direction from (degrees, 15-minute average)
- o Sigma-Theta or
- o Stability class (entered directly, see Enclosure 7)
- o Outside air temperature (degrees F)
- o Precipitation rate (inches/15 minutes)

4.3.4.6 IF there has not been any recorded rainfall, THEN ENTER a "0" for "precipitation rate."

NOTE

This feature could be used to enter data for several steps at one time (e.g., from release start time to present time).

4.3.4.7 After all the meteorological data for the current step have been entered, ADD another step by PRESSING the [Insert] key if desirable.

4.3.4.8 PRESS the Down Arrow key and the Up Arrow key to move between the steps.

4.3.4.9 After all the meteorological data have been entered, PRESS the [F9] key to accept and continue.

4.3.5 Source Term Data Entry Screen

NOTE

Enclosure 1 provides reference source terms for dose assessment.

4.3.5.1 From the Main Menu, SELECT "Enter/Edit Source Term Data."

4.3.5.2 DETERMINE the appropriate Accident Type and proceed to the indicated section.

4.3.5.3 - Loss of Coolant Accident (LOCAN, LOCAG, LOCAC)

4.3.5.4 - Fuel Handling Accident (FHA)

4.3.5.5 - Waste Gas Decay Tank Rupture (WGDTR)

4.3.5.6 - Steam Generator Tube Rupture (SGTRN, SGTRG, SGTRC)

4.3.5.3 Loss of Coolant Accident:

NOTE

Offsite doses for LOCAN (no fuel damage) are not likely to exceed 1 REM TEDE or 5 REM Thyroid.

1. SELECT and ENTER the appropriate LOCA Accident Type based on the status of the core (REFER TO Enclosure 8):

LOCAN - no fuel damage, normal RCS
LOCAG - gas gap failure
LOCAC - core melt
2. SELECT and ENTER one of the following Release Methods for Noble Gas (NG MTHD) and Iodine (I MTHD) based on the information available. REFER TO Enclosure 9 for more information on Release Methods:

RMA1 - ENTER RM-A1 cpm (NG and/or I) and Reactor Building vent CFM from recorder AH-32-FIR Channel D. Use for LOCA inside the Reactor Building with a purge in progress.

RMA2 - ENTER RM-A2 cpm (NG and/or I) and Auxiliary Building vent CFM. Use for LOCA inside the Auxiliary Building (e.g., Letdown leak, Spent Fuel Cooling leak) or LOCA inside the Reactor Building with leak into the Auxiliary Building (e.g., penetration failure).

CONC - ENTER $\mu\text{Ci/cc}$ (NG and/or I) and release point CFM. Reactor Building concentrations may be obtained from RM-A6, PASS, RM-A1 Mid or High Range, grab samples, Enclosure 11 (RM-G29/30). Auxiliary Building concentrations may be obtained from RM-A2 Mid or High Range, RM-A3, RM-A4, RM-A7, RM-A8, PASS, grab samples.

USE the Radiation Monitor Sensitivity Curve Log to convert RM-A readings to concentration.

EFFL - ENTER isotopic $\mu\text{Ci/cc}$ (NG and I) and release point CFM. Obtain isotopic concentrations from PASS, analysis of grab sample.

DIRECT - ENTER calculated Ci/sec (NG and/or I).

DEFLT - Program supplies default Ci/sec.

RATIO - (For I only) Program calculates I Ci/sec based on NG Ci/sec. Use when the Iodine monitor is off-scale or unreliable (e.g., gas contamination).
3. GO TO Section 4.3.5.7.

4.3.5.4

Fuel Handling Accident:

1. ENTER FHA as the Accident Type.
2. SELECT and ENTER one of the following Release Methods for Noble Gas (NG MTHD) and Iodine (I MTHD) based on the information available. REFER TO Enclosure 9 for more information on Release Methods.
 - RMA1 - ENTER RM-A1 cpm (NG and/or I) and Reactor Building vent CFM from recorder AH-32-FIR Channel D. Use for FHA inside the Reactor Building with a purge in progress.
 - RMA2 - ENTER RM-A2 cpm (NG and/or I) and Auxiliary Building vent CFM. Use for FHA in the Auxiliary Building.
 - CONC - ENTER $\mu\text{Ci/cc}$ (NG and/or I) and release point CFM. Reactor Building concentrations may be obtained from RM-A6, PASS, RM-A1 Mid or High Range, grab samples, Enclosure 11 (RM-G29/30). Auxiliary Building concentrations may be obtained from RM-A2 Mid or High Range, RM-A4, RM-A8, PASS, grab samples.

USE the Radiation Monitor Sensitivity Curve Log to convert RM-A readings to concentration.
 - EFFL - ENTER isotopic $\mu\text{Ci/cc}$ (NG and I) and release point CFM. Obtain isotopic concentrations from PASS, analysis of grab sample.
 - DRECT - ENTER calculated Ci/sec (NG and/or I).
 - DEFLT - Program supplies default Ci/sec.
3. GO TO Section 4.3.5.7.

4.3.5.5 Waste Gas Decay Tank Rupture:

NOTE

Offsite doses for a WGDTR are not likely to exceed 1 REM TEDE or 5 REM Thyroid.

1. ENTER WGDTR as the Accident Type.
2. SELECT and ENTER one of the following Release Methods for Noble Gas (NG MTHD) and Iodine (I MTHD) based on the information available. REFER TO Enclosure 9 for more information on Release Methods:
 - RMA2 - ENTER RM-A2 cpm (NG and/or I) and Auxiliary Building vent CFM.
 - CONC - ENTER $\mu\text{Ci/cc}$ (NG and/or I) and release point CFM Concentrations may be obtained from RM-A2 Mid or High Range, RM-A8, RM-A11, PASS, grab samples.

USE the Radiation Monitor Sensitivity Curve Log to convert RM-A readings to concentration.
 - EFFL - ENTER isotopic $\mu\text{Ci/cc}$ (NG and I) and release point CFM. Obtain isotopic concentrations from PASS, analysis of grab sample.
 - DRECT - ENTER calculated Ci/sec (NG and/or I).
 - DEFLT - Program supplies default Ci/sec.
3. GO TO Section 4.3.5.7.

4.3.5.6 Steam Generator Tube Rupture:

NOTE

Offsite doses for a SGTRN (no fuel damage) are not likely to exceed 1 REM TEDE or 5 REM Thyroid.

1. SELECT and ENTER the appropriate SGTR Accident Type based on the status of the core (REFER TO Enclosure 8):

SGTRN - no fuel damage, normal RCS
SGTRG - gas gap failure
SGTRC - core melt
2. REFER TO Enclosure 10 for information on calculating source terms.
3. IF source term is derived from Enclosure 10,
THEN SELECT and ENTER one of the following Release Methods for Noble Gas (NG MTHD) and Iodine (I MTHD) based on the information available.

RMA2 - ENTER RM-A2 Noble Gas cpm and Auxiliary Building vent CFM. Use for Noble Gas when the affected generator is not isolated.

DIRECT - ENTER calculated Ci/sec (NG and/or I) from Enclosure 10.

CONC - ENTER $\mu\text{Ci/cc}$ (NG and/or I) and release point CFM. Concentrations may be obtained from RM-A2 Mid or High Range, RM-A4, RM-A12, RM-G25/28, PASS, and grab samples.

USE the Radiation Monitor Sensitivity Curve Log to convert radiation monitor readings to concentration.
4. If source term information was derived independent of Enclosure 10, the following Release Methods are also available. (REFER TO Enclosure 9 for more information on Release Methods.)

CONC - ENTER $\mu\text{Ci/cc}$ (NG and/or I) and release point CFM. Concentrations may be obtained from RM-A2 Mid or High Range, RM-A4, RM-A12, RM-G25/28, PASS, and grab samples.

USE the Radiation Monitor Sensitivity Curve Log to convert radiation monitor readings to concentration.

EFFL - ENTER isotopic $\mu\text{Ci/cc}$ (NG and I) and release point CFM. Obtain isotopic concentrations from PASS, analysis of grab sample.

DEFLT - Program supplies default Ci/sec.

- 4.3.5.7 IF multiple accidents or multiple release points for the same accident are to be entered, THEN REFER TO Enclosure 12 for specific instructions.
- 4.3.5.8 After all the source term data for the current step have been entered, ADD another step by PRESSING the [Insert] key and FOLLOWING instructions beginning at Section 4.3.5.2, if desirable.
- 4.3.5.9 IF more steps are added, THEN PRESS the [Tab] key to move forward or the [Shift][Tab] keys to move backward.
- 4.3.5.10 After all source term data have been entered, PRESS the [F9] key to accept and continue.
- 4.3.5.11 From the Main Menu, SELECT "Perform Calculations" (not required on first step).
- 4.3.5.12 REVIEW the plume map and dose rates displayed after the calculations are complete and PRESS any key to continue.
- 4.3.5.13 To view or print results, SELECT "Output Menu" from the Main Menu.
- 4.3.5.14 To perform a forecast, REFER TO Section 4.4.5.
- 4.3.5.15 IF more steps have been entered, AND it is desirable to complete all calculations before printing. THEN SELECT "Continue with Calculations" from the Main Menu.
- 4.3.5.16 After the plume map for each step is displayed, CONTINUE to SELECT "Continue with Calculations" until all steps have been calculated.
- 4.3.5.17 From the Main Menu, SELECT "Output Menu."
- 4.4 Data Output**
- 4.4.1 Dose Rates at User-entered Locations

NOTE

Plume centerline dose rates are automatically calculated at 0.83, 2, 5, and 10 miles. Dose rates can be calculated at user-entered locations. Dose rates at user-enter locations will appear in the printed reports.

- 4.4.1.1 SELECT "Display PLUME CENTERLINE Dose Rates" from the Output Menu.
- 4.4.1.2 ENTER the Ring Distance in miles (distance from the plant) and the Direction in degrees (or "M" for plume centerline maximum).
- 4.4.1.3 PRESS [F9] to calculate.
- 4.4.1.4 REPEAT as necessary, PRESS [Esc] when finished.
- 4.4.2 Displayed Reports**
- 4.4.2.1 To display maps or the tabular results of dose, dose rates, and/or deposition calculations, SELECT any of the "Display" options listed on the Output Menu.
- 4.4.3 Printed Reports**
- 4.4.3.1 From the Output Menu, SELECT "Go to Report Menu."

NOTE

The Dose/Dose Rate Report, the Deposition Report, and the Complete Report contain detailed tabular results of calculations. In most cases, the "Summary Report" will be sufficient.

4.4.3.2 From the Report Menu, SELECT the "Summary Report" which includes the following:

- o Header Page
- o 10 mile Map
- o Maximum dose rates for 0.83, 2, 5, and 10 mile distances, dose rates at any user selected points, and dose rates and accumulated doses at special receptors.
- o A flag to consider Protective Action Recommendations (PARs), if needed.

4.4.3.3 REVIEW the following information on the Header Page:

- o Trip/decay start date and time
- o Release date and time
- o Projection number (step)
- o List of program switches (e.g., source decay, etc.)
- o Meteorological data including mixing height
- o Source term data
- o Release rates for Noble Gas, Iodine, and particulates
- o Cumulative release data
- o Isotope % abundance

4.4.3.4 After the printout is complete, SELECT "Output Menu" from the Report Options Menu.

NOTE

If data for one or more steps have been entered but not calculated, the program will automatically begin the next step calculation and display the plume map as in Section 4.3.5.12. If no more data have been entered, the cycle of data entry, calculation, and reporting starts again as in Section 4.3.4.

4.4.4 From the Output Menu, SELECT "Continue With Calculations."

4.4.5 Performing a Forecast

NOTE

After at least one step has been calculated, the Forecast option is available. This option can be used to project dose information and plume position two or more hours into the future based on one set of meteorological and source term inputs. Doses will be calculated for the Forecast period only.

- 4.4.5.1 ENTER meteorological and source term inputs to be used for the forecast period as described in Sections 4.3.4 and 4.3.5.
- 4.4.5.2 From the Main Menu, SELECT "Performing a Forecast."
- 4.4.5.3 ENTER the forecast period in multiples of two hours (e.g., 2, 4, 6, 8 hours, etc.).
- 4.4.5.4 PRESS the [F9] key to accept and continue.

NOTE

On the 10 mile EPZ map displayed after a forecast calculation, the dose units are mREM accumulated during the forecast period NOT mR/hr. However, the printed report is in mR/hr.

- 4.4.5.5 DISPLAY or PRINT the forecast results just as with a real-time (normal) step if needed.
- 4.4.6 Before performing the next step after the forecast, REVIEW the meteorological and source term data and CORRECT as necessary as described in Sections 4.3.4 and 4.3.5.
- 4.4.7 Correcting and Recalculating a Step
 - 4.4.7.1 COMPARE field measurements received from the Offsite Radiation Monitoring Team with calculated values (i.e., Noble Gas/Iodine ratios, doserates, dose, etc.) obtained from RADDose-IV.
 - 4.4.7.2 IF calculated values seem inconsistent with field team data,
THEN REFER TO EM-219 section 4.5.
 - 4.4.7.3 IF incorrect data are discovered for a previous step,
THEN REFER TO Enclosure 14 for correction/recalculation instructions.

4.5 Protective Actions Recommendation

- 4.5.1 IF dose projections equal or exceed 1 REM TEDE or 5 REM Thyroid at the site boundary (0.83 miles),
THEN NOTIFY the EC to CONSIDER public protective action recommendations.

4.6 Documentation

- 4.6.1 FORWARD All documentation created in the TSC to the Dose Assessment Coordinator for review as time permits.
- 4.6.2 TRANSMIT the documentation to Records Management under EM-204(B).

REFERENCE SOURCE TERMS FOR DOSE ASSESSMENT [NOCS 40771]

As a reference for dose assessment calculations, the following source terms are an indication of approximately 1 mR/hr DDE and 1 mR/hr Thyroid at the site boundary for LOCAN, FHA, WGDTR, SGTRN (release through Auxiliary Building vent). For SGTRN through pressure relief valves, refer to Enclosure 10, Page 3 of 3.

2.15E-1 Noble Gas Ci/sec \approx 1 mR/hr DDE
 1.50E-5 Iodine Ci/sec \approx 1 mR/hr Thyroid

Met Data Assumptions:

Wind Speed = 1 m/sec

Wind Direction = 270°

Stability Class = E

Temperature = 80° F

Rain = 0 inches/15 min

RELEASES FROM THE AUXILIARY BUILDING

Assuming an Auxiliary Building Vent flow rate of 156,000 cfm, the following RM-A2 concentrations are required to yield the above source terms:

Noble Gas $\mu\text{Ci/cc}$ = 2.92E-3*
 Iodine $\mu\text{Ci/cc}$ = 2.04E-7
 Iodine μCi accumulating in 30 minutes at 1 cfm = 1.73E-1
 I-131 μCi accumulating in 30 minutes at 1 cfm = 5.69E-2*

RELEASES FROM THE REACTOR BUILDING

Assuming a Reactor Building Vent flow rate of 45,000 cfm, the following RM-A1 concentrations are required to yield the above source terms:

Noble Gas $\mu\text{Ci/cc}$ = 1.01E-2*
 Iodine $\mu\text{Ci/cc}$ = 7.06E-7
 Iodine μCi accumulating in 30 minutes at 1 cfm = 6.00E-1
 I-131 μCi accumulating in 30 minutes at 1 cfm = 1.97E-1*

Assuming a Reactor Building Design Basis Leakage flow rate of 6.1 cfm, the following Reactor Building atmosphere concentrations are required to yield the above source terms:

Noble Gas $\mu\text{Ci/cc}$ = 7.50E+1
 Iodine $\mu\text{Ci/cc}$ = 5.21E-3

* Convert to cpm using the Radiation Monitor Sensitivity Curve Log.

CONFERENCE CALL INSTRUCTIONS

Communications should first be established between the Dose Assessment Communicator in the Control Room (providing met and rad monitor information) and the TSC Dose Assessment Team (DAT). Once the EOF DAT is established, it should be tied into the conference call as soon as possible. (A conference call can be initiated by any of the parties using the appropriate phone numbers.)

Dose assessment phone extensions are posted at the Dose Assessment Ringdown Phones in the Control Room, in the TSC, and EOF dose assessment rooms.

1. The Dose Assessment Communicator to the Control Room should establish communication with the TSC DAT.
2. Hookflash * (receive a stutter dial tone), then dial the EOF DAT extension.
3. Hookflash, and receive the feature dial tone.
4. Dial access code 4 to establish the conference.
5. If the extension at the EOF cannot be reached, hookflash again and communication with the TSC will be re-established.

*A hookflash is quickly depressing and releasing the connection button.

INSTALLING RADDOSE-IV

- 1.0 The program is contained on one 3 1/2" 1.4 MB diskette marked "FPC RADDOSE-IV, Version 2.0" stored in TSC procedure cabinet with EM-204(B) or in the EOF Dose Assessment Cabinet.
- 2.0 If Directory "RD4V2" already exists, go to 2.3.
- 2.1 Create a directory called "RD4V2" on drive C and make this the current directory. Type the following lines in the DOS Command Prompt window:
- C:
CD\
MD\RD4V2
CD\RD4V2
- 2.2 If Directory "RD4V2" has just been created, go to 3.0.
- 2.3 If this directory already exists, delete all files by typing:
- CD\RD4V2
DEL *.*
Y
- 3.0 Insert the RADDOSE-IV disk into drive A.
- 4.0 Run the installation program by typing "A:FPCINST."
- 5.0 Prompts are provided for the type printer to be used.
- 6.0 When installation is complete, a prompt will confirm the model is correctly installed.
- 7.0 There are additional data files on disk that must be copied manually. Leave disk inserted and type the following at the prompt:
- COPY A:\DF*.*
- 8.0 To start the program, type "FPC" at the DOS prompt.

DATA FROM THE PLANT COMPUTER [NOCS 40188]

This Enclosure contains four methods for obtaining data from the plant computer. Select the most appropriate method. Not all methods may be available. Data can also be obtained directly from the Control Room.

DYNAMIC DATA EXCHANGE SPREADSHEET - Live data from radiation monitors and meteorological instruments displayed in an Excel spreadsheet.

1. Double-click on the PICS icon.
2. Access Control Client box :
 - a. In the "Choose a system" box, Select CR3 SPDS.
 - b. In the User Name box, type either tsc or eof.
 - c. In the Password box, type either tsc or eof.
 - d. Click LogOn.
3. Minimize the PICS Access Control Client window.
4. In Windows NT Explorer, go to the c:\Pics\RtdbDde directory and double-click on RtdbDde.exe file. When the hourglass disappears, go to the next step.
5. Start Excel.
6. Open the file c:\My Documents\Dde\RADMET.xls
7. Click Yes to update all linked information.

SPDS DISPLAYS – Live operational data, graphs, and selected radiation monitors.

1. Double-click on the PICS icon.
2. Access Control Client box :
 - a. In the "Choose a system" box, Select CR3 SPDS.
 - b. In the User Name box, type either tsc or eof.
 - c. In the Password box, type either tsc or eof.
 - d. Click LogOn.
3. In the PICS Access Control Client window, double-click on the SPDS Display icon.
4. When the SPDS graphic screen is displayed, press the "A" key to display the Alpha pages. Page 7 of 8 displays RM-G29/30, RM-A6, RM-L1, RM-A1 low-range, RM-A2 low-range, RM-A12, RM-Gs25-28, RM-L2, RM-L7, RM-G1, RM-A5.

PICS ARCHIVE RETRIEVAL – Data from any point recorded in the PICS Real Time Database downloaded per the user specifications of point selection, time selection, and time intervals.

1. Double-click on the PICS icon.
2. Access Control Client box :
 - a. In the "Choose a system" box, Select CR3 SPDS.
 - b. In the User Name box, type either tsc or eof.
 - c. In the Password box, type either tsc or eof.
 - d. Click LogOn.
3. In the PICS Access Control Client window, double-click on the Retrieval icon.
4. In the PDRSrtv box, select File, New Retrieval.
5. On the Simple Retrieval Query Form:
 - a. Enter start and stop times of desired data.
 - b. Select Fixed Width Text.
 - c. Enter file name and path for output file.
 - d. Enter Snapshot interval (time between data points).
 - e. Highlight point to read and click Select. Repeat as needed.
 - f. Add point EVI-1 to the point selection list.
 - g. Click Submit.
6. Start Excel.
7. Open the output file from 5.c above.
8. In the Text Import Wizard box:
 - a. Select Fixed Width.
 - b. Click Finish.

REDAS USE FOR DOSE ASSESSMENT

I. LOGGING ON THE NETWORK

Dose assessment team members log on per instructions on the monitor.

II. REDAS ACCESS & INITIAL SET-UP

1. From the Desktop menu, double click on the REDAS icon.
2. REDAS Network Accessor box is displayed, click on **OK**.
3. Select **Request**, then **Request Group**.
4. Verify that Standard Group, Sort By Name, and LOTUS(PRN) File Format have been selected.
5. Specify Start & End Dates & Times. To change parameters, click on the box, then enter dates/times. Specify at least one hour.

III. SELECTING REDAS GROUPS & DOWNLOADING

The order in which groups are selected is not important, however, all four dose assessment groups must be downloaded before importing the data into the Lotus spread sheet.

Group Names:

AA_ENG	Engineering Instruments
AA_MET	Meteorological Instruments
AA_RADAL	Air and Liquid Radiation Monitors
AA_RADG	General Area Radiation Monitors

1. Click on **AA_ENG**.
2. Verify Frequency is 15 minutes and Average box is checked.
3. Click on **OK**. All download parameters will be displayed in a "Group Confirmation" window. If data are correct, click on **Yes**. Otherwise, click on **No** to return to previous screen.
4. Downloading will start, and should take less than 1 minute. While downloading is taking place, the "Data Request Status" window will be active.
5. When downloading is complete, the "REDAS-NIS" window will be displayed.
6. Click on **OK** in the "REDAS-NIS" screen.
7. Select **Request**, then **Request Group**.
8. Click on **AA_MET**.
9. Verify Frequency is 15 minutes and Average box is checked.
10. Click on **OK** to accept download settings.
11. Verify settings in "Group Confirmation" window. Click on **Yes** to accept & begin download.
12. When downloading is complete, the "REDAS-NIS" window will be displayed.
13. Click on **OK** in the "REDAS-NIS" screen.
14. Select **Request**, then **Request Group**.
15. Click on **AA-RADAL**.
16. Verify Frequency is 15 minutes and Average box is checked.
17. Click on **OK** to accept download settings.
18. Verify settings in "Group Confirmation" window. Click on **Yes** to accept & begin download.
19. When downloading is complete, the "REDAS-NIS" window will be displayed.
20. Click on **OK** in the "REDAS-NIS" screen.
21. Select **Request**, then **Request Group**.
22. Click on **AA_RADG**.
23. Verify Frequency is 15 minutes and Average box is checked.
24. Click on **OK** to accept download settings.
25. Verify settings in "Group Confirmation" window. Click on **Yes** to accept & begin download.
26. When downloading is complete, the "REDAS-NIS" window will be displayed.
27. Click on **OK** in the "REDAS-NIS" screen.

IV USING LOTUS TO IMPORT REDAS DATA

The AA_DOSE.WK3 spreadsheet used for dose assessment contains three pages. Page 1 is reserved for documenting all macros; Page 2 is reserved for importation of downloaded data; Page 3 is used for tables (created by the Table macros).

1. Start Lotus 3.1.
2. Press the [/] key.
3. Select **File**, then **Retrieve**.
4. Select spreadsheet **AA_DOSE.WK3**.

The Dose Assessment Main Menu choices will be listed horizontally at the top of the screen:

IMPORT CLEAR Save_File RAD-Data MET-Data ENG-Data Quit

5. Select **IMPORT** option to import the four .prm files.
6. Select: **RAD-Data**, **MET-Data**, or **ENG-data**

This will display a list of options:

VIEW-GRAPHS PRINT-GRAPHS VIEW-TABLES PRINT-TABLES Quit

7. After one of these options is selected, a list of the graph or table macros is given.

Quit will bring up the main menu.

8. The File_Save option is used to save the spreadsheet after data have been imported. **DO NOT SAVE THE SPREADSHEET AS AA_DOSE.WK3.** This will erase the original spreadsheet. The recommended names are DATA1.WK3, DATA2.WK3, etc.

NOTE

Esc from the Dose Assessment Main Menu will end the dose assessment macro. To return to the Dose Assessment Main Menu, press [Alt][F3], then [End], ensure \O is selected, then press [Enter].

V SWITCHING BETWEEN LOTUS AND REDAS

1. To switch from Lotus without closing the Lotus spreadsheet press [Alt][Tab]. If the REDAS window is not visible, press [Alt][Tab] until it appears.
2. To switch from REDAS, double click on the LOTUS icon at the bottom of the screen.

VI USING EXCEL TO IMPORT REDAS DATA

1. Start Excel.
2. Open the output file desired (normally c:\T123\Aa_eng.prm, Aa_met.prm, Aa_radai.prm, Aa_radg.prm).

3. Text Import Wizard Step 1 of 3:
In the Original Data Type, select Delimited then click Next.
4. Text Import Wizard Step 2 of 3:
In the Delimiters, select Comma then click Next.
5. Text Import Wizard Step 3 of 3:
In the Column data format, select General then click Finish.

METEOROLOGICAL INPUT SHEET FOR RADDISE-IV

DATE/TIME OF TRIP: _____

DATE/TIME OF RELEASE: _____

Sources listed by priority

1. 33□ Primary Tower
2. 175□ Primary Tower
3. 33□ Alternate Tower
4. Other_____

METEOROLOGICAL DATA

[illegible]

COPYING RADD0SE-IV DATA FILES

- 1.0 To copy an incident from the hard disk to formatted floppy diskettes, select "SAVE DATA TO DISK" from the startup menu. This may require several diskettes.
- 1.1 Insert a diskette in drive A when prompted. Label each diskette with the files it contains (e.g., MET and Source Data), so the files can be restored correctly to the hard disk later. Any files on the diskette will be overwritten.
- 2.0 To copy an incident from diskettes to the hard disk, type "RETRIEVE" from the C:\RD4V2\> prompt.
- 2.1 Insert the diskettes into drive A when prompted. Any files on the hard disk with the same name will be overwritten.

ALTERNATE METHODS FOR DETERMINING
METEOROLOGICAL DATA

1. Wind direction, wind speed, and wind range can be estimated by observing cooling tower vapor, flags, fossil stack smoke, etc.
2. Stability class can be estimated using wind range if a wind direction recorder is available. Wind range is the difference (in degrees) between the highest and lowest wind direction tracing on the recorder for a 15 minute period. Use this difference and the following table to determine stability class. DO NOT ENTER WIND RANGE INTO THE SIGMA-THETA FIELD.

<u>WIND RANGE DEGREES</u>	<u>STABILITY CLASS</u>
□ 135	A (disperses rapidly)
134 to 105	B
104 to 75	C
74 to 45	D
44 to 23	E
22 to 13	F
≤12	G (disperses slowly)

3. Enter the stability class into the CLS field of the Meteorological Data Input screen
4. Wind direction is determined by estimating the average value of the tracing for a 15 minute period.
5. Meteorological data may also be obtained from the following, however, non-local backup sources may not be representative.

Primary Backup - FAA Flight Service Station in Gainesville, FL.
Secondary Backup - Tampa Weather Service in Ruskin, FL.

See EM-206, Emergency Plan Roster and Notification, Enclosure 4.

SELECTION OF ACCIDENT TYPE

This enclosure lists four methods of selecting accident type based on the level of core damage. Each method has advantages and disadvantages. Use the most appropriate method (or combination) to predict the level of core damage.

Based on RM-G29 and RM-G30 readings:	Page 1 of 4
Based on Xe-133 Percentage:	Page 2 of 4
Based on Iodine and Noble Gas ratio:	Page 3 of 4
Based on RCS pressure and temperature:	Page 4 of 4

BASED ON RM-G29 AND RM-G30:

This method can be performed quickly but requires a breach of the Reactor Coolant System and that the Reactor Building atmosphere be thoroughly mixed (which may take several hours).

Obtain RM-G29 and RM-G30 readings. Ignore spikes and estimate the sustained monitor reading. Use this value with the following data to determine accident type.

<u>RM-G29/30 R/HR</u>	<u>ACCIDENT TYPE</u>
<100	LOCAN
100 - 25000 WITH RB SPRAY	LOCAG
100 - 75000 WITHOUT RB SPRAY	LOCAG
>25000 WITH RB SPRAY	LOCAC
>75000 WITHOUT RB SPRAY	LOCAC

SELECTION OF ACCIDENT TYPE

BASED ON Xe-133 PERCENTAGE

This method requires a sample and analysis and cannot be quickly obtained.

The percent estimate is based on information in Section 14 of the FSAR and the NRC Response Technical Manual.

LOCAN: Xe-133 approximately 90% of total noble gases.

LOCAG, LOCAC: Xe-133 approximately 30% of total noble gases.

SELECTION OF ACCIDENT TYPE

BASED ON IODINE AND NOBLE GAS RATIOS:

The tables below list iodine and noble gas ratios that may be used to develop source terms when isotopic distribution data are not available. Sampling and analysis may be required so this method may not be quickly available. Ratio estimates are based on information in Section 14.0 of the FSAR and the NRC Response Technical Manual.

	NG/I	I/NG
LOCAN	241	4.14E-03
FHA	146	6.83E-03
WGDT	2000	5E-04
SGTRN	4320	2.31E-04

The following table lists ratios for LOCAG and LOCAC with RB Spray ON and RB Spray OFF. However, distinguishing between LOCAG and LOCAC using iodine and noble gas ratios will be difficult.

	RB SPRAY ON		RB SPRAY OFF	
	NG/I	I/NG	NG/I	I/NG
LOCAG	24	0.04	0.97	1.03
LOCAC	36	0.03	1.45	0.69

SELECTION OF ACCIDENT TYPE


BASED ON RCS PRESSURE AND TEMPERATURE:

This method can be performed quickly but will not indicate mechanically-induced core damage. The intersection of pressure from the Y axis and temperature from the X axis is the level of core damage. (Regions are from the Inadequate Core Cooling procedure used by Operations.)

Regions 1 and 2 indicate no fuel damage (normal RCS activity).

Region 3 indicates possible gas gap failure.

Severe Accident Region indicates possible core melt.



**NOBLE GAS AND IODINE
METHODS DESCRIPTIONS****1. RM-A1 or RM-A2 - Effluent monitor cpm/Flowrate**

The user must enter a specific RM-A1 monitor reading in cpm and a flow rate in SCFM in the Reactor Building vent or a specific RM-A2 monitor reading in cpm and a flow rate in SCFM in the Auxiliary Building vent. The release rate in Ci/sec is then calculated and displayed on the screen. It may be used for Noble Gas and/or Iodine. If the iodine filter has not been changed, the filter μCi for the previous step is subtracted from the current value. On the first step, the model assumes previous filter μCi is zero.

2. CONC - Concentration/Flowrate

The user must enter $\mu\text{Ci/cc}$ from a grab sample or an estimated $\mu\text{Ci/cc}$ and a flowrate measurement or estimate (in SCFM) at the release point. It may be used for Noble Gas and/or Iodine. If this method is used for Iodine, the program asks if the concentration is I-131 only. If I-131 only, the program adds other Iodine isotopes in appropriate proportions. The release rate in Ci/sec is then calculated and displayed on the screen.

3. EFFL - Effluent Isotope Entry

The Isotope Screen is displayed and the user must enter isotopic concentrations in $\mu\text{Ci/cc}$ from a grab sample or from the Post Accident Sampling System. Press the [Enter] key to input the concentration and to move to the next isotope. At least one noble gas and one iodine isotope must be entered. The release rate in Ci/sec is then calculated and displayed on the screen. Once a distribution has been entered, the program will retain it until a new distribution is entered or until the accident type is re-entered.

4. DIRECT - Direct Input

The user must enter a calculated release rate in Ci/sec for Noble Gas and/or Iodine.

5. DEFLT - Default

The program enters the default value in Ci/sec for a particular accident type. It may be used for Noble Gas and/or Iodine. Default values should be used only as a last resort to calculate an upper limit dose rate. Protective Action Recommendations should not be based on a default calculation.

6. RATIO - Ratio of Noble Gas to Iodine (LOCA ONLY)**NOTE**

This method is available for Iodine only with a LOCA accident type. For Iodine ratios in other accident types, see Enclosure 13.

For Iodine only: The program calculates and enters the Iodine release rate in Ci/sec based on the Noble Gas to Iodine release rate ratio from the previous step. If RATIO is selected in the first step, default ratios are used. If an accident type change occurs between the steps, a correction factor is applied. Refer to Enclosure 13 for more information.

STEAM GENERATOR TUBE RUPTURE EVALUATION

Instructions: Determine whether the leaking OTSG is steaming to the condenser, steaming to the atmosphere, or isolated. Then refer to the appropriate section below and on the next page to develop source terms.

Background Information: Emergency Operating Procedures direct operators to continue to use both steam generators for RCS cooling until mode 5 is reached unless specific parameters are exceeded. These parameters are part of the Tube Rupture Alternate Control Criteria (TRACC) and involve RCS activity, BWST level, and OTSG level. If the condenser is available (vacuum established), steam will be directed there. Noble gases will be discharged from the condenser through the Auxiliary Building Ventilation and RM-A2. If the condenser is not available, steam will be discharged through the Atmospheric Dump Valves. Periodic steam releases through the Main Steam Safety Valves may occur immediately after a reactor trip.

I. LEAKING OTSG STEAMING TO THE CONDENSER

As long as condenser vacuum is established, Noble Gas releases from intermittent pressure reliefs to the atmosphere from the MSSVs/ADVs are not significant as at least 90% will be released through the condenser and Auxiliary Building Vent (RM-A2). Iodines and particulates will probably not be released through the condenser and Auxiliary Building Vent, but will be retained in the condenser and condensate demineralizers and released only when MSSVs/ADVs are open.

NOBLE GAS:

- o Use RMA2 Release Method for RM-A2 low-range or CONC Release Method for mid or high-range.
- o Enter RM-A2 low-range monitor cpm or mid or high-range $\mu\text{Ci/cc}$ and the Auxiliary Building Vent CFM.

IODINE:

- o If there are iodine channel indications, use RMA2 Release Method.
- o Enter RM-A2 iodine channel cpm and the Auxiliary Building Vent CFM.
- o If the iodine channel is off-scale, use the I/NG ratio in Enclosure 8 to calculate Ci/sec using the following equation and enter using the DRECT Release Method.
- o $\text{Ci/sec} = (\text{NG Ci/sec}) (\text{I/NG ratio})$
- o If there are intermittent pressure reliefs to the atmosphere, use the following equation. The release rate is 10% of the primary-to-secondary Ci/sec for the duration the MSSVs/ADVs are open. (See information about computer points in section III on next page.) Curies from a short release are averaged over a 30-minute time step. For example, 1 Ci/sec for 30 seconds converts to 30 Ci over 30 minutes or 0.017 Ci/sec.
- o $\text{Ci/sec} = (\text{ } \mu\text{Ci/cc Total I in RCS}) (\text{ } \text{gpm P} \rightarrow \text{S Leak Rate}) (\text{ } \text{minutes MSSVs/ADVs open}) (2.1\text{E-}9)$

II. LEAKING OTSG STEAMING TO THE ATMOSPHERE CONTINUOUSLY

NOBLE GAS:

- o Use DRECT Release Method.
- o $\text{Ci/sec} = (\text{ } \mu\text{Ci/cc NG in RCS}) (\text{ } \text{gpm P} \rightarrow \text{S Leak Rate}) (6.3\text{E-}7)$
- o In the above equation, the release rate equals the primary-to-secondary Ci/sec.

IODINE:

- o Use DRECT Release Method.
- o $\text{Ci/sec} = (\text{ } \mu\text{Ci/cc Total I in RCS}) (\text{ } \text{gpm P} \rightarrow \text{S Leak Rate}) (6.3\text{E-}7)$
- o In the above equation, the release rate equals the primary-to-secondary Ci/sec.

CONTINUED ON NEXT PAGE.

STEAM GENERATOR TUBE RUPTURE EVALUATION

III. LEAKING OTSG WAS STEAMING TO THE ATMOSPHERE BUT IS NOW ISOLATED

Use these equations if dose projections begin after the release was terminated (e.g., MSSVs open briefly after reactor trip or stuck open, but now repaired). Computer points W354, W355, RECL114, RECL115 track ADVs percent open. Downloading intervals of 1 minute or less over the period of the time step may be useful in determining minutes that the ADVs are open in the equations below.

NOBLE GAS:

- o Use DIRECT Release Method.
- o $\text{Ci/sec} = (\text{ } \mu\text{Ci/cc NG in RCS}) (\text{ } \text{gpm P} \rightarrow \text{S Leak Rate}) (\text{ } \text{minutes MSSVs/ADV open}) (2.1\text{E}-8)$
- o In the above equation, the release rate equals the primary-to-secondary Ci/sec for the duration the MSSVs/ADV are open. Curies released are averaged over a 30 minute time step. For example, 30 Ci over 30 minutes converts to 0.017 Ci/sec.

IODINE:

- o Use DIRECT Release Method.
- o $\text{Ci/sec} = (\text{ } \mu\text{Ci/cc Total I in RCS}) (\text{ } \text{gpm P} \rightarrow \text{S Leak Rate}) (\text{ } \text{minutes MSSVs/ADV open}) (2.1\text{E}-8)$
- o In the above equation, the release rate equals the primary-to-secondary Ci/sec for the duration the MSSVs/ADV are open. Curies released are averaged over a 30 minute time step. For example, 30 Ci over 30 minutes converts to 0.017 Ci/sec.

ADDITIONAL INFORMATION

- o All constants below include a factor of 0.01 which reduces the effective source term to account for additional plume dispersion due to heat energy and release velocity. This factor was determined after comparing RADDose-IV output to calculations published in 1992 by B&W Nuclear Technologies. To determine the actual total curies released, it will be necessary to multiply the cumulative curies on the RADDose-IV header page by 100.
- o RM-G26 and RM-G27 are N-16 monitors calibrated to read in gallons per day at 100% power.
- o It is assumed that all noble gas activity leaking into the OTSG will be released via the AB stack (RM-A2), MSSVs/ADV, or EFP-2.
- o If core integrity is maintained, activity is based on the most recent RCS activity. RM-L1 may be used to scale this value as transients cause spikes in RCS activity.
- o 1 gpm = 63 cc/s
- o Maximum Leak Rate = 400 gpm (for one tube)
- o Default Flow Rate through stuck open MSSV/ADV = 5900 cfm

DERIVATION OF CONSTANTS USED IN THE SOURCE TERM EQUATIONS

$$6.3\text{E}-7 = \left[\frac{1\text{Ci}}{1\text{E}6\mu\text{Ci}} \times \frac{3780 \text{ cc}}{1 \text{ Gal}} \times \frac{1 \text{ min}}{60 \text{ sec}} \right] \times 0.01 \qquad 2.1\text{E}-9 = \left[\frac{\text{Ci}}{1\text{E}6\mu\text{Ci}} \times \frac{3780 \text{ cc}}{1 \text{ Gal}} \right] + 1800 \text{ sec} \times 10\% \times 0.01$$

$$2.1\text{E}-8 = \left[\frac{1\text{Ci}}{1\text{E}6\mu\text{Ci}} \times \frac{3780 \text{ cc}}{1 \text{ Gal}} \right] + 1800 \text{ sec} \times 0.01$$

Performed by: _____ Verified by: _____

REFERENCE DOSE RATES FOR A STEAM GENERATOR TUBE RUPTURE [NOCS 40771]

The following dose rates should be used as reference points. Projected dose rates for an actual SGTRN (no fuel damage) released through a stuck open MSSV/ADV should be similar assuming the other release conditions are similar. Offsite doses for a SGTRN should not exceed 1 REM TEDE or 5 REM Thyroid.

DOSE RATES AT 0.83 MILES

0 mR/hr - DDE
4.2 mR/hr - Thyroid (CDE):
0.2 mR/hr - TEDE

RELEASE CONDITIONS

Reactor Coolant Activity (Normal)

1.0 $\mu\text{Ci/ml}$ Total NG

1.0 $\mu\text{Ci/ml}$ Total Iodines

100 GPM primary-to-secondary leak rate

Leaking OTSG isolated

Noble Gas Ci/sec = $6.3\text{E-}5$ *

Iodine Ci/sec = $6.3\text{E-}5$ *

30 minute release through stuck open pressure relief valve.

Meteorological Conditions:

Wind Speed - 1 m/s (2.2 mph)

Stability Class - E (stable)

Rain - 0 inches/15 minutes

Temperature - 80°F

Wind Direction - 270° (from due West)

* Source Terms derived using equations in Section II of this Enclosure.

**SOURCE TERM DETERMINATION FOR
LOCA IN CONTAINMENT**

Basing dose estimates on unconfirmed Design Basis Leakage is not recommended. If Containment Building pressure and radiation levels are elevated, field measurements should easily confirm a significant release. Consider monitoring the Intermediate Building roof vent, personnel and equipment hatches and downwind berm areas.

1. Obtain RM-G29 and RM-G30 readings. Ignore spikes and estimate the sustained monitor reading. Use this value with the following data to determine accident type (refer to Enclosure 8 for other methods of determining accident type).

RM-G29 & RM-G30 Reading (R/hr)	Accident Type
<100	LOCAN
100 - 75,000 (without RB Spray) 100 - 25,000 (with RB Spray)	LOCAG
> 75,000 (without RB Spray) > 25,000 (with RB Spray)	LOCAC

2. Determine the RB atmosphere concentration of Iodine or Noble Gas with the following relationship:

$$\mu\text{Ci/cc} = (\text{RG-29 \& 30 reading in R/hr}) / \text{Factor}$$

where "Factor" is taken from the following table.

	LOCAN		LOCAG		LOCAC	
	w/o Spray	w/ Spray	w/o Spray	w/ Spray	w/o Spray	w/ Spray
Noble Gas Factor	3	1	190	60	180	60
Iodine Factor	720	5700	180	1400	270	2100

3. Determine the flow rate using step 3a or 3b below.

- a. If the hole size and containment pressure are known, use the following formula to calculate flow rate in CFM:

$$\text{CFM} = 145 * \sqrt{\text{PSIG}} * \text{HOLE SIZE (in square inches)}$$

- b. If Design Basis Leakage is indicated, select the flowrate based on RB pressure from the following table:

PSIG	5	10	15	20	25	30	35	40	45	50
CFM	1.9	2.7	3.3	3.9	4.3	4.7	5.1	5.4	5.8	6.1

4. Input the $\mu\text{Ci/cc}$ from step 2 above and the flow rate from step 3a or step 3b into RADDSE-IV using the CONC Release Method.

Performed by: _____ Verified by: _____

**INSTRUCTIONS FOR ENTERING MULTIPLE
ACCIDENTS AND RELEASE POINTS**

Source terms from three different release points (from one or more accidents) may be entered in each step. Multiple release points could be associated with the same accident (e.g., from RM-A2 and safety relief valves during SGTR) or multiple accidents could cause releases from different points (e.g., LOCA from Containment and WGDTR from RM-A2).

1.0 Entering Multiple Accidents

- 1.1 After all source term data on line 1 of the current step have been entered, press the down arrow key to move to line 2.
- 1.2 Press [F2] to access the Accident Menu.
- 1.3 Select another accident and press [ENTER].
- 1.4 Enter all source term data for the new accident.
- 1.5 If a release terminates, enter "NONE" in the Accident Type field.
- 1.6 Up to three different accidents may be entered in the current step. When all data are correct, press [F9].

2.0 Entering Multiple Release Points for the Same Accident

- 2.1 After all source term data on line 1 of the current step have been entered, press the down arrow key to move to line 2.
- 2.2 Press [F2] to access the Accident Menu.
- 2.3 To enter another release point, select the same accident type again and press [ENTER].
- 2.4 Enter all source term data for the new release point.
- 2.5 If a release terminates, enter "NONE" in the Accident Type field.
- 2.6 Up to three separate release points may be entered in the current step. When all data are correct, press [F9].

IODINE RATIO METHOD

This technique may be used to determine the total release rate of Iodines when the effluent monitor is off scale. (RADDose-IV can perform these calculations automatically using the Ratio Release Method discussed in Enclosure 9). Field team ratio may also be used.

The ratio approach which follows derives the current Iodine release rate from the previous step's Iodine to Noble Gas ratio and the current noble gas release rate. An additional factor (Atratio) is applied when the accident type changes from the previous step.

Accident Type Unchanged From Previous Step

$$\text{Iodine Ci/sec} = (\text{NG Ci/Sec})_{\text{current}} \times \left[\frac{\text{Iodine Ci/sec}}{\text{NG Ci/sec}} \right]_{\text{previous}}$$

Accident Type Changed From Previous Step

$$\text{Iodine Ci/sec} = (\text{NG Ci/Sec})_{\text{current}} \times \left[\frac{\text{Iodine Ci/sec}}{\text{NG Ci/sec}} \right]_{\text{previous}} \times (\text{Atratio})$$

Accident Type Change	Atratio RB Spray On	Atratio RB Spray Off
LOCA Normal to Gas Gap	10	250
LOCA Normal to Core Melt	7	167
Gas Gap to Core Melt	0.67	0.67

Use the DIRECT method to enter Ci/sec into RADDose-IV.

Performed by: _____ Verified by: _____

**INSTRUCTIONS FOR CORRECTING AND
RECALCULATING A TIME STEP**

To correct an error in a previous time step, it is necessary to return to both the meteorological data screen and the source term data screen. To recalculate the time step, perform the following:

1. From the Main Menu, select "Enter Meteorological Data," even if all data are correct.
2. If all meteorological data are correct, press [F9]. Go to 6 below.
3. Use the Up Arrow Key to return to the incorrect time step.
4. Use the Right and Left Arrow Keys to return to the incorrect data.
5. Re-enter the data, press [F9].
6. From the Main Menu, select "Enter Source Term Data," even if all source term data are correct.
7. If all source term data are correct, press [F9]. Go to number 11 below.
8. Use the [Shift][Tab] keys to return to the incorrect time step.
9. Use the Right and Left Arrow Keys and/or the Up and Down Arrow Keys to return to the incorrect data. (Use the Up and down Arrow Keys to access multiple accidents within the time step.)
10. Re-enter the data and press [F9].
11. RADDose-IV may have added a new time step to both the meteorological and source term data screens by copying the data from the last calculated time step. Ensure this new data are correct then press [F9]. If the data for the new time step are not available yet, it can be corrected when obtained.
12. From the Main Menu, select "Perform Calculations." The program will now recalculate the incorrect time step and display the plume map.
13. It is necessary to recalculate all time steps after the error. Reprint reports as necessary and continue to select "Perform Calculations" or "Continue with calculations" until program returns to the current time step.

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0204B

New Rev: 28

PRR#: 19925

Title: OFF-SITE DOSE ASSESSMENT DURING RADIOLOGICAL EMERGENCIES (USER INSTRUCTIONS FOR RADDOSE-IV)

MINOR CHANGES

If Minor Changes are included, check the applicable box(es) and provide a list of affected steps.
The following corrections are incorporated throughout:

- | | |
|---|---|
| <input type="checkbox"/> Sentence Structure | <input type="checkbox"/> Redundant words or phrases |
| <input type="checkbox"/> Punctuation | <input type="checkbox"/> Abbreviations |
| <input type="checkbox"/> Capitalization | <input type="checkbox"/> Obviously incorrect units of measure |
| <input type="checkbox"/> Spelling | <input type="checkbox"/> Inadvertently omitted symbols (#, %, etc.) |
| <input type="checkbox"/> Organizational Changes: position titles,
department names, or telephone numbers | <input type="checkbox"/> Obvious step numbering discrepancies |
| | <input type="checkbox"/> Format |

The following corrections are incorporated in the step(s) indicated: "Throughout" is used in lieu of Step# if a specific change affects a large number of steps.

Correcting equipment nomenclature that does not agree
with field labels or balance of procedure

Changing information that is obviously incorrect and
referenced correctly elsewhere

Misplaced decimals that are neither setpoint values nor
tolerances

Reference to a procedure when an approved procedure
has taken the place of another procedure

Fixing branching points when it is clear the branching
steps were originally intended but were overlooked or
incorrectly stated due to step number changes

Adding clarifying information such as NOTES and CAUTIONS

Adding words to clarify steps, NOTES, or CAUTIONS which
clearly do not change the methodology or intent of the
steps

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0204B

New Rev: 28

PRR#: 19925

Title: OFF-SITE DOSE ASSESSMENT DURING RADIOLOGICAL EMERGENCIES (USER INSTRUCTIONS FOR RADD0SE-IV)

NON-INTENT CHANGES

Changes are incorporated for the reasons provided. "Throughout" is used in lieu of Step # if a specific change affects a large number of steps. For new or cancelled procedures the reason is provided.

4.1.1, 4.1.1.1 These steps assumed the TSC team would initiate dose assessment activities. Reworded to make appropriate for either the TSC or EOF team to initiate communications.

4.2.1 Reworded contingencies for computer failure to allow dose projection data to originate in either facility regardless of which team has primary responsibility at the time.

4.4.7.1, 4.4.7.2 Added two new steps for a comparison of dose projection data to field team data and a reference to EM-219 for situations where dose projections seem inconsistent with field team data (PC#00-2908 CA1).

Enclosure 4 Fixed typo in first paragraph. Added RM-L1 to list of monitors available on SPDS Alpha pages.

Enclosure 4 Added a missing step in the instructions for opening the Dynamic Data Exchange Excel spreadsheet. Also corrected capitalization in the folder and file names and added the folder My Documents to the location due to the Desktop Standardization project.

Enclosure 4 Added an instruction to include computer point EVI-1 when downloading computer points with the PICS Archive Retrieval.

Enclosure 4 Added instructions for importing REDAS data into an Excel spreadsheet.

Enclosure 10

Revised a large part of the instructions for steam generator tube rupture evaluation per recommendations from an Accident Assessment Team Coordinator. Release options are now steaming to the condenser, steaming to the atmosphere, and previous steaming to the atmosphere. Also added background information on tube rupture coping strategy in the EOPs.

Throughout

Used Progress Energy Nuclear Generation Group procedure format.

4.3.4.5

Clarify that wind speed and wind direction should be 15-minute averages (PC#00-2890 CA1).

Page 2

Noted that Enclosures 11 and 13 are Optional Records Non-Quality.

Enclosures 10, 11, 13

Added Performed by and Verified by signoffs.



FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
PLANT OPERATING MANUAL

EM-213
MEDICAL EMERGENCY RESPONSE

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 PURPOSE	3
2.0 DEVELOPMENTAL REFERENCES.....	3
3.0 PERSONNEL INDOCTRINATION	3
3.1 Definitions	3
3.2 Responsibilities	4
3.3 Limits and Precautions	4
4.0 INSTRUCTIONS	4
4.1 Emergency Notification	4
4.2 Emergency Medical Technician - Basic	5
4.3 Control Room.....	6
4.4 Superintendent Shift Operations	6
4.5 The FTL or designee at the scene	7
4.6 Transportation of Possible Contaminated Patient	7
4.7 Documentation.....	8

ENCLOSURES

1	Checklist For Medical Emergencies	9
2	Route to Seven Rivers Community Hospital (Optional Records Non-Quality)	11
3	Route to Inverness and Citrus Memorial Hospital (Optional Records Non-Quality)	12

1.0

PURPOSE

Provides actions to be taken by personnel in response to a radiological or non-radiological medical emergency.

Implement this procedure for medical emergencies within the Protected Area, and other medical emergencies outside the Protected Area where the Superintendent Shift Operations determines it appropriate, such as when the EMT-B is dispatched, or the Control Room requests an ambulance.

Minor injuries do not warrant the implementation of this procedure. Non-contaminated individuals with minor injuries are treated in the individual shops using first aid kits or are directed to Allen Ridge Medical Center or Seven Rivers Community Hospital for treatment.

2.0

DEVELOPMENTAL REFERENCES

- 2.1.1 10 CFR 50.47 Emergency Plans
- 2.1.2 10 CFR 50, Appendix E, Emergency Planning and Preparedness for Production and Utilization Facilities
- 2.1.3 AI-801, Utilization of Contract Security Emergency Medical Technicians (EMT)
- 2.1.4 HPP-104, Personnel Monitoring and Decontamination
- 2.1.5 NUREG-0654, Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants
- 2.1.6 Radiological Emergency Response Plan
- 2.1.7 RSP-600, ALARA Program

3.0

PERSONNEL INDOCTRINATION

3.1

Definitions

NOTE

A Safety Assessment was performed for this procedure. A determination was made that this procedure is outside the scope of 10CFR50.59.

- 3.1.1 **Emergency Medical Technician - Basic (EMT-B)** - An individual trained in basic medical procedures and certified by the Department of Health to perform these procedures in emergency situations. An EMT- B is the senior medical person of a medical emergency until arrival of advanced life support personnel.
- 3.1.2 **Emergency Response Coordinator (ERC)** – Individuals from Crystal River Site Support specially trained and equipped to handle emergencies such as high angle rescue, medical emergencies, burns, crushing injuries and rescues that require heavy lifting.
- 3.1.3 **Medical Emergency** – An incident or condition where personnel injury occurred and requires immediate medical attention. Medical attention is standard first aid or advanced medical care.

3.2 Responsibilities

- 3.2.1 Individual responsibilities when discovering an injured/ill person(s) are implemented in Section 4.1.
- 3.2.2 The EMT-B provides the primary medical response upon arrival at a medical emergency scene and implements Section 4.2.
- 3.2.3 The Superintendent Shift Operations (SSO) coordinates the onsite response and implements Section 4.3 and 4.4.
- 3.2.4 The Fire Team Leader (FTL) or designee establishes overall scene control and implements Section 4.5.
- 3.2.5 The Health Physics Technician or Radiation Monitoring Team (RMT) member maintains appropriate radiological control and implements Section 4.6.5.
- 3.2.6 The Emergency Coordinator (EC), at the TSC/OSC, assists in the coordination of the medical response as requested by the SSO and dispatches a RMT member to the scene.
- 3.2.7 The Superintendent, Radiation Protection ensures results of bioassays performed by the offsite medical facility for personnel radiologically exposed at CR-3 are obtained by Florida Power.
- 3.2.8 Security establishes scene control as needed.
- 3.2.9 The Supervisor of the injured individual ensures notification to the family is made.

3.3 Limits and Precautions

- 3.3.1 In an accident situation, exercise care not to aggravate the injury. Immediate medical treatment is the highest priority and radiological control is secondary. In such cases, radiological control procedures are not permitted to adversely affect the condition of the victim. However, in most cases, injuries are of a nature that radiological safety need not be compromised.
- 3.3.2 In situations where radiation or contamination exists, consider ALARA and radiological safety of the patient and those aiding the patient to the greatest extent possible under the existing conditions.
- 3.3.3 In most cases, the Citrus County Sheriff's Department performs an investigation of an accident scene to determine if foul play was involved. Therefore, if the patient is obviously deceased, the patient should not be moved until the Sheriff's Deputy reporting to the scene has declared it is not a crime scene.

4.0 INSTRUCTIONS

4.1 Emergency Notification

- 4.1.1 IF an individual becomes ill or is injured outside the Protected Area and an ambulance is called, THEN NOTIFY the Control Room by dialing 3-1-1. This alerts the Control Room that an ambulance is arriving at CR-3. The SSO determines if EM-213 is implemented.
- 4.1.2 Individuals discovering a medical emergency inside the Protected Area, **PERFORM** the following:

- 4.1.2.1 CHECK the scene and the victim.
- 4.1.2.2 NOTIFY the Control Room by dialing 3-1-1 on phone or PAX or by plant radio, if in direct contact with the Control Room, and PROVIDE the following information:
- Location of emergency
 - Caller's name
 - Caller's phone number
 - What happened
 - Number of victims, names and badge numbers
 - Conditions of victim(s)
 - Help being given
- 4.1.2.3 PROVIDE any medical assistance qualified to perform on the victim.
- 4.1.2.4 WHEN EMT-B arrives,
THEN PROVIDE brief summary of the situation and actions taken.
- 4.1.2.5 REMAIN in safe area until monitored if the possibility of personnel contamination exists.
- 4.1.2.6 FOLLOW instructions from the person in charge at the emergency scene.

4.2 Emergency Medical Technician - Basic

- 4.2.1 RESPOND when requested to medical emergencies within the CR-3 Protected Area and at other points within the Crystal River Energy Complex.
- 4.2.2 RESPOND to the scene when the Fire Brigade, Haz Mat or Site Support ERC is dispatched.
- 4.2.3 REPORT to the FTL or designee during radiological and non-radiological medical emergencies and keep the FTL updated on the condition of the injured.

NOTE

If obviously deceased, do not move the victim until the Sheriff's Deputy reporting to the scene has declared it is not a crime scene. The 9-1-1 call placed by the Control Room will automatically notify the sheriff's office.

- 4.2.4 EVALUATE the urgency of moving the patient(s) according to their medical condition and the radiation levels.
- 4.2.5 EVALUATE conditions and PROVIDE basic life support as appropriate upon arrival at the scene of a medical emergency.
- 4.2.6 IF the nature of an injury/illness threatens the life of the patient, or is an obvious severe injury,
THEN REQUEST an ambulance.
- 4.2.7 IF the patient experiences chest discomfort, loses consciousness, complains of severe abdominal pain, severe respiratory distress or is experiencing a heat stroke,
THEN REQUEST an ambulance.

- 4.2.8 IF patient conditions exist such that a Trauma Alert is warranted,
THEN REQUEST Control Room to initiate Trauma Alert during 9-1-1 call.
- 4.2.9 COMPLETE the Emergency Patient Treatment Record (EPTR) located in the Jump Kit, as time permits.
IF time does not permit,
THEN REQUEST someone standing near-by to fill out the form as the EMT-B PROVIDES the information.
- 4.2.10 PROVIDE turnover to the Emergency Medical Service (EMS) personnel as appropriate and give the original EPTR for each person to EMS personnel.
- 4.2.11 FORWARD the remaining copy of the completed EPTR to Emergency Preparedness.
- 4.2.12 INVENTORY AND RESTOCK Jump and Trauma Kits as needed.
- 4.3 Control Room**
- 4.3.1 COMPLETE Enclosure 1 Checklist.
- 4.3.2 IF the TSC/OSC is operational,
THEN NOTIFY the Emergency Coordinator of the medical emergency.
- 4.3.3 IF numerous injuries occur,
THEN REQUEST support and follow-up from the Emergency Coordinator
- 4.4 Superintendent Shift Operations**

NOTE

Radiological conditions should be taken into account before sending the FTL.

- 4.4.1 DISPATCH the FTL or designee to the emergency scene to establish scene control.
- 4.4.2 COMPLETE notifications and actions listed in Enclosure 1.
- 4.4.3 MAINTAIN communication with the FTL and COORDINATE the onsite medical response.
- 4.4.4 ENSURE Security is aware an ambulance and/or Site Support ERC are arriving onsite, if applicable.

NOTE

All patients (contaminated or non-contaminated) are transported to Seven Rivers Community Hospital. If Seven Rivers is being evacuated or is unavailable, Citrus Memorial Hospital is the alternative hospital.

- 4.4.5 DETERMINE the hospital the patient is transported to. If an ambulance is requested, Emergency Medical Services (EMS) makes the ultimate decision on where patients are transported. Enclosures 2 and 3 provide directions to Seven Rivers Community Hospital and Citrus Memorial Hospital, respectively.

4.5 The FTL or designee at the scene

- 4.5.1 ESTABLISH communications with Control Room.
- 4.5.2 ESTABLISH communications with the EMT-B.
- 4.5.3 ESTABLISH scene control and IDENTIFY responding members:
 - o COORDINATE medical response.
 - o ESTABLISH contamination control if required.
 - o ENSURE Security is controlling access to the emergency scene.
- 4.5.4 EVALUATE available information concerning the patient and other conditions (radiation, contamination, equipment malfunction) and REPORT information to the SSO.
- 4.5.5 ESTABLISH exit route and ambulance pickup point (if required). Primary exit route from the Auxiliary Building and Reactor Building with a patient is through the Hot Machine Shop Rollup Door.
- 4.5.6 ENSURE ambulance is enroute, if applicable.
- 4.5.7 COORDINATE requests for additional equipment and personnel.
- 4.6 Transportation of Possible Contaminated Patient**

CAUTION

All personnel, including assisting personnel, are suspect of carrying radioactive contaminants until proven otherwise.

NOTE

In case of serious injury/illness, consideration of life and health overrule other requirements.

- 4.6.1 IF transportation of the patient is required, THEN consider the removal of the protective clothing. The severity of the injury/illness and degree of contamination dictate the specific steps taken, such as cutting off the protective clothing, the necessity of a stretcher, or wrapping in a blanket.
- 4.6.2 IF the patient is completely decontaminated, THEN consider transporting by private vehicle.
- 4.6.3 ENSURE a Health Physics Technician or RMT member accompanies contaminated patients to the off-site medical facility.
- 4.6.4 Upon arrival at the prescribed hospital entrance, WAIT until assistance arrives.

4.6.5 The Health Physics Technician or RMT member ASSIST ambulance and hospital personnel as required, and: [NOCS 1130]

- o PROVIDE the medical facility pertinent information necessary to treat the patient(s).
- o PREVENT the spread of contamination.
- o PROVIDE dosimetry to EMS/hospital personnel.
- o PROVIDE survey instruments, as required.
- o PROVIDE plastic bags to collect remaining protective clothing and irrigation washings containing radioactive contamination, seal and return to plant.
- o ESTABLISH communications with SSO or Emergency Coordinator to keep informed of status.
- o ENSURE vehicles used to transport patients are cleared of contamination before releasing it for other service.
- o OBTAIN results of bioassay performed by offsite medical facilities for radiological exposed CR-3 personnel.

4.7 Documentation

4.7.1 SSO TRANSMIT copies of Enclosure 1 to Records Management.

Checklist for Medical Emergencies
[NOCS 1591]

A. INITIAL REPORT (obtain information from initial call to fill in after notification of EMT-B, Item B)

1. Location of Emergency: _____
2. Caller's Name: _____ Phone # _____
3. Patient's Name: _____ Badge # _____
4. Type of Injury/Illness: _____
(If deceased, inform caller not to move individual)
5. Hazards in Area (Radiological, Steam, etc.) _____

6. Help given to patient: _____
7. Date/Time: _____

B. EMT-B/SECURITY NOTIFICATION

Ext. 3132 (REQUEST EMT-B TO BE DISPATCHED TO SCENE) TIME _____

C. ADDITIONAL SUPPORT NOTIFICATION

TIME _____ NA ☐

Contact Emergency Response Coordinator on radio channel 7, as needed,
for serious medical, injury, Hazmat, fire, high angle or confined
space incident.

D. HEALTH PHYSICS NOTIFICATION Ext. 3150

TIME _____

E. REPORT AT SCENE

1. Transport to hospital via: ☐ Ambulance ☐ Other ☐ N/A
2. Type of injury/illness: _____
3. Condition (identify if Trauma Alert): _____
4. Contamination Present: ☐ No ☐ Yes Level: _____
5. Ambulance pickup point: ☐ Hot Machine Shop ☐ Other (Specify) _____

Checklist for Medical Emergencies

F. AMBULANCE SERVICE NOTIFICATION

1. Call 9-1-1. (This also notifies the Sheriff's Office)
IF EMT-B requests Trauma Alert,
THEN notify 9-1-1 to initiate Trauma Alert. Time: _____
2. Give your name and title.
3. Request ambulance at Crystal River Nuclear Plant.
4. Give them patient information from Section E. (Items 2, 3, 4)
5. Advise dispatcher that Security will direct ambulance upon arrival on Site.
6. Notify Security at Ext. 3132 ambulance is enroute and request them to notify Corporate Security.

G. HOSPITAL NOTIFICATION

Primary: Seven Rivers Community Hospital - 795-8335/795-6560

Secondary: Citrus Memorial Hospital - 344-6569/726-1551 (If primary not available)

1. Time: _____ 2. Person Contacted: _____
3. Give name and title. Tell them you are transporting a patient(s) to their facility.
4. Give them patient information from Section E.
5. If contamination is present, tell them a Health Physics Technician will accompany the patient.

H. SUPERVISOR NOTIFICATION

Notify injured person's supervisor to contact family. TIME _____ ☐ NA

Supervisor's Name: _____

I. AMBULANCE ARRIVES ON SITE

TIME _____ ☐ NA

J. AMBULANCE LEAVES SITE

TIME _____ ☐ NA

Completed By

Title


Date/Time

Reviewed By SSO

Date/Time

DISTRIBUTION: Records Management – (PATS)


ROUTE TO SEVEN RIVERS COMMUNITY HOSPITAL
[NOCS 16070]



Turn right at the end of West Powerline road. Turn into Seven Rivers Community Hospital at the second entrance on the left off Highway 19. Follow signs to the Emergency Room entrance.

ROUTE TO INVERNESS AND CITRUS MEMORIAL HOSPITAL
[NOCs 16070]

Take State Road 44 from Crystal River to Inverness. Go past Citrus High School and turn right on South Line Avenue. Go past Grace Street and turn left at the ambulance entrance. Proceed to the marked ambulance entrance.



PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0213

New Rev: 28

PRR#: 20029

Title: MEDICAL EMERGENCY RESPONSE

MINOR CHANGES

If Minor Changes are included, check the applicable box(es) and provide a list of affected steps.
The following corrections are incorporated throughout:

- | | |
|---|---|
| <input type="checkbox"/> Sentence Structure | <input type="checkbox"/> Redundant words or phrases |
| <input type="checkbox"/> Punctuation | <input type="checkbox"/> Abbreviations |
| <input type="checkbox"/> Capitalization | <input type="checkbox"/> Obviously incorrect units of measure |
| <input type="checkbox"/> Spelling | <input type="checkbox"/> Inadvertently omitted symbols (#, %, etc.) |
| <input type="checkbox"/> Organizational Changes: position titles,
department names, or telephone numbers | <input type="checkbox"/> Obvious step numbering discrepancies |
| | <input type="checkbox"/> Format |

The following corrections are incorporated in the step(s) indicated: "Throughout" is used in lieu of Step# if a specific change affects a large number of steps.

Correcting equipment nomenclature that does not agree
with field labels or balance of procedure

Changing information that is obviously incorrect and
referenced correctly elsewhere

Misplaced decimals that are neither setpoint values nor
tolerances

Reference to a procedure when an approved procedure
has taken the place of another procedure

Fixing branching points when it is clear the branching
steps were originally intended but were overlooked or
incorrectly stated due to step number changes

Adding clarifying information such as NOTES and CAUTIONS

Adding words to clarify steps, NOTES, or CAUTIONS which
clearly do not change the methodology or intent of the
steps

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0213

New Rev: 28

PRR#: 20029

Title: MEDICAL EMERGENCY RESPONSE

NON-INTENT CHANGES

Changes are incorporated for the reasons provided. "Throughout" is used in lieu of Step # if a specific change affects a large number of steps. For new or cancelled procedures the reason is provided.

Throughout	Reformatted procedure in accordance with AI-400A and AI-402B. Reformatted and changed action words to meet requirements of AI-402B and AI-400G. Deleted reference to Medical Services as they are no longer on-site. Changed the title for Nuclear Shift Manager to Superintendent Shift Operations. Used the term "victim" and "patient" interchangeably throughout procedure
1.0	Changed "guidance for personnel" to "Actions to be taken by personnel" in Purpose section to address information for EM-201. Clarified non-contaminated individuals with minor injuries are treated in the shops using first aid or directed to Seven Rivers Community Hospital or Allen Ridge Medical Center for treatment.
2.0	Deleted reference to EM-201. Added references to 10CFR50. 47, 10CFR50 Appendix E and NUREG 0654.
3.1.3 3.2.1	Added definition for Medical Emergency. Changed reference from EM-201 to Section 4.1. Relocating information contained in EM-201 concerning medical emergencies to EM-213.
3.2.7	Changed the title of Manager, Radiation Protection to Superintendent Radiation Protection to meet new title under Progress Energy Florida Power
3.3.1 and 3.3.2	Clarified and combined the two previous Limits and Precautions into one. Deleted Limit and Precaution pertaining to confined space rescue as it is addressed in Enclosure 1. Renumbered accordingly.
4.1.2 - 4.1.2.5	Rewrote section to include information contained in EM-201 on what to do when a medical emergency is discovered. EM-201 is trained on in GET, however, is not normally referenced during medical emergencies.
4.2.9	Deleted Emergency Patient Treatment Record (EPTR) from EM-213. Referenced the Emergency Patient Treatment Record as maintained in EMT Jump Kit. AI-801 contains the EPTR and is used by Security personnel. There is no need to include a copy of the form in EM-213. Reworded for clarification.
4.2.11	Revised step to provide the remaining copy of the EPTR to Emergency Preparedness instead of Medical Services.
4.3.1 4.4.2	Changed reference to Enclosure 2 to Enclosure 1. Deleted EPTR which was Enclosure 1.
4.4.1	Added Caution to consider radiological conditions prior to dispatching the FTL.
4.4.5	Clarified that the offsite EMS makes the ultimate decision on where to transport patients.
4.6.5	Clarified that the HP Tech assists both the ambulance and hospital personnel.

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0213

New Rev: 28

PRR#: 20029

Title: MEDICAL EMERGENCY RESPONSE

4.7 Deleted distribution of EPTR. Renumbered accordingly.

Enclosure 1

Item A - Changed location of victim to location of emergency; Clarified the initial report information should be entered on the checklist after notifying the EMTs. Information is taken on the 3-1-1 call and can be later filled in. The important thing is to notify EMT-Bs as soon as possible. Comment from medical drill.


Deleted reference to Medical Services Department. No longer on-site. Item E - added reference to Hot Machine Shop roll-up door. Item H - added space to put name of supervisor contacted and time contacted.

Title Page - Enclosure 1

Changes title to agree with Enclosure 1

4.2.2

Changed name from Rescue Services to Site Support ERC to designate Rescue Services is the Emergency Rescue Coordinator



**FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
PLANT OPERATING MANUAL**

EMERGENCY PLAN IMPLEMENTING PROCEDURE

EM-219

DUTIES OF THE DOSE ASSESSMENT TEAM

TABLE OF CONTENTS

SECTION	PAGE
1.0 PURPOSE	3
2.0 REFERENCES	3
2.1 Developmental References	3
3.0 PERSONNEL	3
3.1 Definitions	3
3.2 Responsibilities	4
3.3 Limits and Precautions	4
3.4 Equipment & Materials	4
4.0 INSTRUCTIONS	5
4.1 Formation of the DAT	5
4.2 Obtaining Equipment.....	5
4.3 Information from the Control Room	5
4.4 Performing Dose Assessment	6
4.5 Field Team Interface	6

ENCLOSURES

1 COMPARISON OF ESTIMATED DOSE RATES WITH FIELD MEASUREMENTS	7
Table 1 - Comparison of Noble Gas (Gamma) Field Measurements and Calculated Deep Dose Equivalent (DDE) Dose Rate Estimates (Optional Records Non-Quality)	11
Table 2 - Comparison of Field Measurements and Calculated Thyroid Dose Rate Estimates (Optional Records Non-Quality)	12
Table 3 - Comparison of Noble Gas to Iodine Ratios Field and RADDose-IV (Optional Records Non-Quality)	13
2 FIELD TEAM DATA (Optional Records Non-Quality)	14

1.0 PURPOSE

- 1.1** The primary purpose of the Dose Assessment Team (DAT) is to provide dose assessment information for the Emergency Coordinator (EC).

Dose assessment is a component of determining both emergency classification and protective action recommendations.

This procedure provides guidance to the DAT for setting up operations in the Technical Support Center (TSC) (in conjunction with EM-204B), interface with the Dose Assessment Coordinator and the EC, and compare dose projections with actual data collected by the Off-site Radiation Monitoring Team.
[NOCS 01582, 01870]

2.0 REFERENCES

2.1 Developmental References

- 2.1.1** Radiological Emergency Response Plan (RERP)
- 2.1.2** RADDOSE IV Operator's Manual
- 2.1.3** Manual of Protective Action Guides and Protective Actions for Nuclear Incidents, EPA-400-R-92-001, Environmental Protection Agency (October, 1991).

3.0 PERSONNEL

NOTE

A safety assessment was performed for this procedure. A determination was made that this procedure is outside the scope of 10 CFR 50.59.

3.1 Definitions

- 3.1.1 Committed Dose Equivalent (CDE)** - Dose to an organ due to the intake of radioactive materials.
- 3.1.2 Deep Dose Equivalent (DDE)** - External whole body dose.
- 3.1.3 Dose Assessment Coordinator** - Lead TSC Chemistry or Radiation Protection designee directing Chemistry and Radiological Assessment personnel and advising the EC of these issues.
- 3.1.4 Off-Site RMT** - The portion of the Radiation Monitoring Team (RMT) that performs environmental sampling within the Crystal River Energy Complex and within the 10 mile Emergency Planning Zone (EPZ). The Off-Site RMT is also referred to as the Environmental Survey Team (EST).
- 3.1.5 Plume Tracking** - Locating, tracking, and monitoring radiological characteristics of an off-site release.
- 3.1.6 Replacement Emergency Dose Assessment System (REDAS)** - System to retrieve and archive the meteorological, radiological, and operational data required for emergency dose assessment purposes.
- 3.1.7 Thyroid Dose** - Dose to the thyroid due to intake of radioactive iodine.

3.1.8 **Total Dose (TEDE)** - The sum of external dose (DDE) and the equivalent amount of whole body dose due to individual organ uptakes.

3.2 Responsibilities [NOCS 13040]

3.2.1 The TSC DAT assumes primary responsibility for dose assessment from the time the TSC is operational until the Emergency Operations Facility (EOF) is operational and assumes the primary responsibility. However, prior to the EOF being declared operational, the EOF Dose Assessment Team may function as an extension of the TSC team and supply dose assessment information to the TSC. After the EOF team has assumed primary responsibility, the TSC team may function as an extension of the EOF team and supply dose assessment information to the EOF. [NOCS 10519]

3.2.2 The Dose Assessment Status Board Keeper updates the appropriate TSC Dose Assessment Status Boards and plume tracking maps. [NOCS 10519]

3.2.3 The DAT provides the Dose Assessment Coordinator with the appropriate dose assessment information necessary for the EC to determine emergency classification and/or protective action recommendations (PARs). [NOCS 10519]

3.2.4 When the EOF is operational, responsibility for PARs transfers from the EC to the EOF Director. The Corporate Health Physicist will then ensure the EOF Director is provided with the necessary dose assessment information.

3.2.5 The Dose Assessment Coordinator designates a DAT Leader from the responding DAT members.

3.2.6 The DAT Leader assigns personnel to the Dose Assessment Computer and REDAS Terminal.

3.2.7 The Environmental Survey Team Dispatcher establishes communications with the Off-Site RMT.

3.2.8 The Environmental Survey Team Dispatcher directs the Off-Site RMT to appropriate locations.

3.2.9 The DAT has the authority to carry out all instructions issued by the EC or the Chemistry or Radiation Protection leadership. [NOCS 10519]

3.3 Limits and Precautions

3.3.1 The estimated dose rates and measured dose rates will probably not be equal due to the conservatism present in the calculated dose rate models, uncertainty in source terms and/or meteorology under specific accident conditions, and difficulties in locating plume centerlines. All available data should be analyzed for credibility.

3.3.2 Emergency Team Rosters must be reviewed to assure individuals assigned to the Dose Assessment Team are on current Emergency Team Rosters. A hard copy of current Team Rosters is available in the Operational Support Center or can be obtained in accordance with EM-206 section 4.3.

3.4 Equipment & Materials

3.4.1 Hand-held calculator

3.4.2 Equipment identified in EM-204(B), Off-Site Dose Assessment During Radiological Emergencies (Computer Method).

4.0 INSTRUCTIONS

4.1 Formation of the DAT

4.1.1 FORM the DAT at an Alert, Site Area Emergency or General Emergency classification as directed by the Dose Assessment Coordinator.

4.1.2 ENSURE a DAT Leader is designated.

4.1.3 ENSURE a Dose Assessment Communicator is available in the Control Room to monitor radiological and meteorological instruments and relay data to the DAT as necessary.

4.1.4 ENSURE personnel are assigned to the Dose Assessment Computer and the REDAS Terminal.

4.2 Obtaining Equipment

NOTE

Procedures, enclosures, and supplies are available in the supply cabinet and procedure files in the Dose Assessment Room.

4.2.1 OBTAIN the following:

- a. Hand-held calculator
- b. Controlled Copies of EM-204(B) and additional copies of Enclosure 5, (input data sheets for RADDose-IV.)
- c. Controlled Copy of EM-210B and additional copies of Enclosure 4, "Emergency Monitoring Sheet."

4.3 Information from the Control Room

4.3.1 ESTABLISH communications with Dose Assessment Communicator in the Control Room and the EOF DAT by use of the Dose Assessment Ringdown phone. REFER TO EM-204(B) Enclosure 2 for conference call instructions if necessary. [NOCS 00387]

4.3.2 ENSURE that the REDAS Terminal Operator is aware of any radiation monitors or meteorological instruments that are out of service.

4.3.3 OBTAIN meteorological and radiological data from REDAS and the Control Room (as needed). [NOCS 00387]

4.3.4 IF EM-204(A) dose assessment calculations were performed by Control Room personnel,
THEN OBTAIN results.

4.3.5 REVIEW EM-204A data inputs and calculations performed in the Control Room to assist in formulating initial inputs into the computer dose assessment model.

4.4 Performing Dose Assessment

- 4.4.1 PERFORM off-site dose assessment projections using guidance in EM-204(B).
- 4.4.2 PROVIDE off-site dose projections to the Dose Assessment Coordinator.
- 4.4.3 KEEP the appropriate Dose Assessment status boards and plume tracking maps up-to-date.
- 4.4.4 CONTINUE to perform dose assessment operations in accordance with this procedure, unless otherwise directed.
- 4.4.5 KEEP Control Room personnel informed of release calculation results as necessary via the Dose Assessment Communicator in the Control Room or the Accident Assessment Ringdown communicators.

4.5 Field Team Interface

- 4.5.1 ESTABLISH contact with the Environmental Survey Team (EST) Dispatcher.
- 4.5.2 PROVIDE information to the EST Dispatcher to aid in plume location and tracking,
- 4.5.3 OBTAIN local area dose rates, airborne activity levels, and any other pertinent information, such as, unusual weather conditions and wind shifts from the EST as needed.
- 4.5.4 COMPARE field measurements received from the Off-Site RMT with the calculated values (i.e., Noble Gas/Iodine ratios, doserates, dose, etc.) obtained from the computer model. REFER TO Enclosure 1.
- 4.5.5 IF the calculated values seem inconsistent with the field data,
THEN INFORM the Dose Assessment Coordinator immediately,
AND VERIFY all calculations and Off-Site RMT data.
- 4.5.6 USE Enclosure 2 to record additional field team data as necessary for review by the Dose Assessment Coordinator or for documentation purposes.

COMPARISON OF ESTIMATED DOSE RATES WITH FIELD MEASUREMENTS

INTRODUCTION:

Comparison of field measurements with RADDose-IV estimates of dose rates are made to assess the validity of the calculated dose projections and determine whether the source term being used for the dose rate calculations should be adjusted. This comparison is done to assist in validating dose projections which would be considered when making protective action recommendations.

The results obtained from this enclosure should be considered guidance. Revisions to the calculated source term should be made only after careful consideration of all factors involved with the release. Factors include, but are not limited to, reliability of the source term, meteorological conditions, and location of field team readings.

PRECAUTIONS:

1. Because of uncertainty in source terms and/or meteorology under specific accident conditions, and the difficulties in locating a plume, RADDose-IV and other mathematical models used to estimate dose rates generally are conservative and should give dose rates larger than those actually existing in the field. Thus, the ratios of field measured to calculated dose rates are expected to be less than 1 under known source term release conditions.
2. The Deep Dose Equivalent (DDE) dose calculations assumes that an individual is immersed in a semi-infinite cloud of radioactive gases. This assumption may be conservative (leading to a higher dose) if the plume has not dispersed sufficiently to immerse an individual.
3. If possible, field measurements should be made at three or more distances downwind before any comparisons are made. Field measurements should include the highest values recorded in the plume since the calculated dose rates are the maximum doses for plume centerline gas concentrations.
4. Comparison of computer generated deposition values with Off-Site RMT contamination surveys requires a conversion from $\mu\text{Ci}/\text{m}^2$ to $\text{dpm}/100\text{ cm}^2$. To convert, use the following formula:

$$\mu\text{Ci}/\text{m}^2 \times 2.22\text{E}4 = \text{dpm}/100\text{ cm}^2$$

COMPARISON AND ADJUSTMENT METHODS:

NOTE

RADDOSE-IV calculates plume centerline dose rates at 0.83, 2, 5, and 10 miles. If estimated dose rates are required at additional distances for comparison purposes, RADDOSE-IV can calculate dose rates at user-defined locations.

There are two methods of comparison and source term adjustment:

Method A may be used for both noble gas and iodine source terms and determines the ratios between the field measurements and RADDOSE-IV dose rates. (Complete Steps A.1 through A.7)

Method B is for use on iodine source term only and determines the ratio of Noble Gas $\mu\text{Ci/cc}$ to Iodine $\mu\text{Ci/cc}$ measured in the field and compares it to the ratio of Noble Gas Ci/sec and Iodine Ci/sec used in RADDOSE-IV. (Complete steps B.8 through B.16)

Method A (Noble Gas and Iodine Source Terms):

- A.1.
 - a. Record the noble gas (gamma) dose rate measurements from the Off-Site RMT on Table 1. The location (distance and sector) and time are also recorded.
 - b. Enter the RADDOSE-IV DDE dose rate estimates for the corresponding location (distance and sector) and time.
 - c. Divide the noble gas field measurement value (mRem/hr) by the RADDOSE-IV DDE dose (mRem/hr) and record this ratio in Table 1.
 - d. Perform A.1.a through A.1.c for each location.
- A.2.
 - a. Record the air concentrations for total iodine from the field measurements on Table 2. The location (distance and sector) and time are also recorded.
 - b. Convert iodine air concentration to a thyroid dose rate by multiplying the iodine air concentration ($\mu\text{Ci/cc}$) by the appropriate thyroid dose conversion factor (DFI, mRem/hr/ $\mu\text{Ci/cc}$) given at the bottom of Table 2. If the type of accident is unknown or cannot be estimated, use the largest DFI value given in Table 2. Calculate the thyroid dose for each measured iodine air concentration given and record on Table 2.
 - c. Enter the RADDOSE-IV thyroid dose rate estimate (mRem/hr) for the corresponding location (distance and sector) and time.
 - d. Divide the thyroid dose rate based on field measurement air concentrations by the RADDOSE-IV thyroid dose rate estimates and record on Table 2.
 - e. Perform A.2.a through A.2.d for each location.

- A.3. Calculate the average of the ratios of measured to calculated DDE dose rates by summing the ratios in Table 1 and dividing by the number of ratios entered (e.g., if 3 ratios of 0.1, 0.4, and 0.7 are entered, the average is $(0.1 + 0.4 + 0.7)/3 = 0.4$). Enter the average of the ratios in the box provided below Table 1.
- A.4. Repeat A.3 above for the Thyroid dose rate ratios in Table 2. Enter the ratio average in the box below Table 2.
- A.5. The differences between the individual ratios and the ratio-average for the DDE dose rates (Table 1) and the Thyroid dose rates (Table 2) can now be compared. All data should be provided to the Dose Assessment Coordinator.
- A.6. IF the ratio average > 1.0 ,
THEN GO TO Step A.7.
- IF the ratio average between 0.1 and 1.0,
THEN source terms should not be adjusted.
- IF the ratio average < 0.1 ,
THEN CONSIDER the following before making adjustments:
- a. IF source terms are thought to be well known (i.e., all emissions are from monitored vents),
THEN source terms should not be changed without consistent differences from field data.
 - b. IF source terms are not well known (i.e., default values are being used),
THEN use of field data can be justified more readily.
 - c. IF wind speed is above 5 mph and wind direction is steady and the plume center line is well defined,
THEN field data should be considered credible.
 - d. IF wind speed is less than 5 mph or wind direction is variable or the plume center line is not clearly defined,
THEN field data may be unreliable.
 - e. IF the ratios of field measurements to RADDose-IV estimates are consistent,
THEN field measurements should be considered credible. This is particularly true as more field measurements are collected.
- A.7. IF the Dose Assessment Coordinator authorizes changing the source terms being used in the dose rate calculations,
THEN the DDE source term can be modified by multiplying the existing source term by the average of the ratios determined in Table 1. The Iodine source term can be modified by multiplying the existing source term by the average of the ratios determined in Table 2.

Method B (Iodine Source Term Only):

If only the Iodine source term is questionable, this method may be used to make adjustments to it.

- B.8. Regardless of whether the field samples were taken at the highest dose rate in the plume, the Noble Gas to Iodine ratio should be representative.
Record on Table 3:
- time of field measurements
 - the location (distance/sector)
 - the Noble Gas (gamma) dose rate (DDE) measured in the field
 - the Iodine $\mu\text{Ci/cc}$ measured in the field (total Iodine).
- B.9. Convert the DDE to Noble Gas $\mu\text{Ci/cc}$ by dividing by the Noble Gas Dose Conversion Factor (DFNG) given at the bottom of Table 3. If the accident type is unknown, use the smallest DFNG.
- B.10. Calculate the field measurement (Noble Gas to Iodine) ratio by dividing the Noble Gas $\mu\text{Ci/cc}$ by the Iodine $\mu\text{Ci/cc}$ and record in the right hand column of Table 3.
- B.11. Perform steps B.8, B.9, and B.10 for each location.
- B.12. Calculate the average of the ratios by summing the ratios and dividing by the number of ratios. Enter into the appropriate formula below the Table 3.
- B.13. Determine the RADDose-IV ratio by dividing the Noble Gas Ci/sec by the Iodine Ci/sec from the time step corresponding to the field measurement time. Enter into the appropriate formula below Table 3.
- B.14. The Noble Gas to Iodine ratio in the field can now be compared to the Noble Gas to Iodine ratio used in RADDose-IV. All data should be provided to the Dose Assessment Coordinator.
- B.15. IF the RADDose-IV ratio is more than a factor of 2 high or low,
THEN consider adjusting the Iodine source term to correct the ratio.
For example, if the ratio of Noble Gas to Iodine in the field is 10, consider adjusting the RADDose-IV Noble Gas to Iodine ratio if it is less than 5 ($10/2$) or greater than 20 (10×2).
- B.16. Determine the new RADDose-IV Iodine source term by dividing the last RADDose-IV Noble Gas source term by the average ratio from Table 3.

TABLE 1

**COMPARISON OF NOBLE GAS (GAMMA) FIELD MEASUREMENTS AND CALCULATED
DEEP DOSE EQUIVALENT (DDE) DOSE RATE ESTIMATES**

	TIME	LOCATION DISTANCE/ SECTOR	NOBLE GAS (GAMMA) FIELD MEASUREMENT mRem/hr.	RADDOSE-IV CALCULATED DDE mRem/hr.	<u>FIELD</u> RADDOSE-IV
1.					
2.					
3.					
4.					
5.					
6.					
7.					
8.					
9.					
10.					

Average of Ratios = $\frac{\text{Sum of Ratios}}{\text{Number of Ratios Summed}}$ =

Performed by: _____ Verified by: _____

TABLE 2

COMPARISON OF FIELD MEASUREMENTS AND CALCULATED
THYROID DOSE RATE ESTIMATES

	TIME	LOCATION DISTANCE/ SECTOR	FIELD MEASUREMENT		RADDOSE IV THYROID DOSE RATE mRem/hr.	FIELD RADDOSE-IV
			IODINE $\mu\text{Ci/cc}$	THYROID DOSE RATE* mRem/hr.		
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
9.						
10.						

* THYROID mRem/HR = (IODINE $\mu\text{Ci/CC}$) X (DFI**)

Accident Type	**DFI (mRem/HR PER $\mu\text{Ci/CC}$)
FHA	1.0 E+9
WGDTR	3.51E+8
LOCAN	5.05E+8
LOCAG	2.16E+8
LOCAC	2.16E+8
SGTRN	5.12E+8
SGTRG	2.16E+8
SGTRC	2.16E+8

**DFI (DOSE FACTORS FOR IODINE) CALCULATED FROM EPA-400 TABLE 5.2. The DFI is a weighted average for total iodine based on the distribution of iodine isotopes in each accident type (DFI I-131 = 1.3E+9).

Average of Ratios = $\frac{\text{Sum of Ratios}}{\text{Number of Ratios Summed}}$ =

Performed by: _____ Verified by: _____

TABLE 3

COMPARISON OF NOBLE GAS TO IODINE RATIOS
FIELD AND RADDOSE-IV

	TIME	LOCATION DISTANCE/ SECTOR	FIELD MEASUREMENT			
			DDE mRem/HR	NG μCi/CC*	I μCi/CC	NG TO I RATIO
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						

AVERAGE FIELD TEAM RATIO = $\frac{\text{sum of the ratios}}{\text{number of ratios}} = \text{avg. field ratio}$

RADDOSE-IV RATIO = $\frac{\text{NG CI/SEC} + \text{I CI/SEC}}{\text{RADDOSE-IV RATIO}}$

Accident Type	DFNG** (mRem/HR PER μCi/CC)
FHA	1.97E+4
WGDTR	3.70E+4
LOCAN	3.72E+4
LOCAG	4.68E+5
LOCAC	4.68E+5
SGTRN	3.35E+4
SGTRG	4.68E+5
SGTRC	4.68E+5

*NG μCi/CC = (DDE mRem/HR) + (DFNG**)

**DFNG (DOSE FACTORS FOR NOBLE GAS) CALCULATED FROM
EPA-400 TABLE 5.3

Performed by: _____ Verified by: _____

Date: _____

[illegible]

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0219

New Rev: 14

PRR#: 19926

Title: DUTIES OF THE DOSE ASSESSMENT TEAM

MINOR CHANGES

If Minor Changes are included, check the applicable box(es) and provide a list of affected steps.
The following corrections are incorporated throughout:

- | | |
|---|---|
| <input type="checkbox"/> Sentence Structure | <input type="checkbox"/> Redundant words or phrases |
| <input type="checkbox"/> Punctuation | <input type="checkbox"/> Abbreviations |
| <input type="checkbox"/> Capitalization | <input type="checkbox"/> Obviously incorrect units of measure |
| <input type="checkbox"/> Spelling | <input type="checkbox"/> Inadvertently omitted symbols (#, %, etc.) |
| <input type="checkbox"/> Organizational Changes: position titles,
department names, or telephone numbers | <input type="checkbox"/> Obvious step numbering discrepancies |
| | <input type="checkbox"/> Format |

The following corrections are incorporated in the step(s) indicated: "Throughout" is used in lieu of Step# if a specific change affects a large number of steps.

Correcting equipment nomenclature that does not agree
with field labels or balance of procedure

Changing information that is obviously incorrect and
referenced correctly elsewhere

Misplaced decimals that are neither setpoint values nor
tolerances

Reference to a procedure when an approved procedure
has taken the place of another procedure

Fixing branching points when it is clear the branching
steps were originally intended but were overlooked or
incorrectly stated due to step number changes

Adding clarifying information such as NOTES and CAUTIONS

Adding words to clarify steps, NOTES, or CAUTIONS which
clearly do not change the methodology or intent of the
steps

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0219

New Rev: 14

PRR#: 19926

Title: DUTIES OF THE DOSE ASSESSMENT TEAM

NON-INTENT CHANGES

Changes are incorporated for the reasons provided. "Throughout" is used in lieu of Step # if a specific change affects a large number of steps. For new or cancelled procedures the reason is provided.

3.2.1 Clarified that regardless of whether the TSC or EOF DAT has primary responsibility, the other team can function as an extension and supply dose assessment information.

3.3.2 Added section number for EM-206 reference and reworded for clarification.

4.2.1 Moved first note to between sections 4.2 and 4.2.1 because it applies to 4.2.1, not the entire section 4.2. Removed unnecessary second note.

4.3.2 Converted a caution statement that no longer met Writer's Guide criteria to an instruction step and renumbered remaining steps in section 4.3. Also added meteorological instruments to the instruction to notify the REDAS operator of radiation monitors that are out of service.

4.4.5 Added the Accident Assessment Ringdown as a method to notify the Control Room of release calculation results.

4.5.4 Added examples of Noble Gas/Iodine ratios, doserate, dose for criteria to compare to field team data (PC#00-2908 CA1).

Enclosure 1 section A.1 and A.2 Added to record times for field team data and made the two sections consistent in the descriptions of the field location (distance and sector).

Enclosure 1 section B Converted a note to a description under the section header.

Enclosure 1 section B.8 Added time the parameters to be recorded.

Enclosure 1 Table 1	Added a time column.
Enclosure 1 Table 2	Added a time column and corrected an error in the SGTRN DFI factor.
Enclosure 1 Table 3	Added a time column. Clarified that average ratio calculated is from field team data and better aligned the equation labels with the blanks.
4.5.6, Enclosure 2	Added Enclosure 2 and an instruction reference to it. This enclosure can be used as desired to track additional field team data.
Throughout	Made Writer's Guide changes and used new Progress Energy Nuclear Generation Group procedure format.
Page 2	Noted that Enclosure 1 tables and Enclosure 2 are Optional Records Non-Quality.

PROCEDURE DEVELOPMENT AND REVISION RECORD

Procedure: EM0219

New Rev: 14

PRR#: 19926

Title: DUTIES OF THE DOSE ASSESSMENT TEAM

Enclosure 1

Added Performed by and Verified by signoffs to Tables 1, 2, and 3.
