



Monticello Nuclear Generating Plant
2807 West County Road 75
Monticello, MN 55362-9637

Operated by Nuclear Management
Company LLC

February 12, 2001

Technical Specification 6.7.A.6

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Revised Annual Report of Safety Relief Valve Challenges
January 1 through December 31, 2000

On January 23, 2001, the Nuclear Management Company submitted to the NRC the Annual Report of Safety Relief Valve Challenges January 1 through December 31, 2000 for the Monticello Nuclear Generating Plant. A typographical error exists in the body of the January 23, 2001 letter. The sentence: "For the period of January 1, 2000 to December 31, 200" should have read: "For the period of January 1, 2000 to December 31, 2000" (emphasis added). The entire content of the January 23, 2001 letter is correctly repeated below.

In accordance with Monticello Technical Specification Section 6.7.A.6, and NUREG 0737 item II.K.3.3, the following Annual Report of Safety Relief Valve Failures and Challenges is provided:

Failures:

For the period of January 1, 2000 to December 31, 2000, no safety/relief valve (SRV) failures occurred.

Challenges:

2/28/2000 All eight SRVs were manually opened at reactor pressure of approximately 150 psig in accordance with a surveillance test performed during plant startup.

This letter contains no new NRC commitments, nor does it modify any prior commitments. Please contact Sam Shirey at (763) 295-1449 if you require additional information concerning this report.

Byron D. Day
Plant Manager
Monticello Nuclear Generating Plant

c: Next page

A001

cc: Director, Office of Nuclear Regulatory Research
Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
Minnesota Department of Commerce