



Crystal River Nuclear Plant
Docket No. 50-302
Operating License No. DPR-72

Ref: ITS 5.7.1.2

February 14, 2001
3F0201-05

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Monthly Operating Report

Dear Sir:

Florida Power Corporation hereby submits the Crystal River Unit 3 (CR-3) January 2001 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

Effective with the attached report, Line Item 2 of Appendix A, Operating Data Report has been revised to 834 in order to reflect CR-3's Summer Net Maximum Dependable Capacity (MWe-Net).

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

D. L. Roderick
Plant General Manager


DLR/ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

IE24

APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE February 5, 2001
COMPLETED BY L.J. Barbieri 
TELEPHONE (352) 795-6486 x3761

REPORTING PERIOD (Month/Year):

January 2001

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	825		
2 MAXIMUM DEPENDABLE CAPACITY (Mwe-Net)	834		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	744.0	142,334
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	744.0	140,082
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	634,065	634,065	108,089,136

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-302

UNIT NAME FLCRP-3

DATE February 5, 2001

COMPLETED BY L.J. Barbieri

TELEPHONE (352) 795-6486 x3761

REPORTING PERIOD: January 2001

No.	Date	Type	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
		F: Forced S: Scheduled				Comments
None						

SUMMARY:

Crystal River Unit 3 operated at full power for the entire month of January

(1) Reason:

A-EQUIPMENT FAILURE (Explain)
 B-MAINTENANCE OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING / LICENSE EXAMINATION
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR (Explain)
 H-OTHER (Explain)

(2) Method

1-MANUAL
 2-MANUAL TRIP / SCRAM
 3-AUTO TRIP / SCRAM
 4-CONTINUATION
 5-OTHER (Explain)