

Dr. Robert C. Mecredy  
Vice President, Nuclear Operations  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, NY 14649

il 24, 1997

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION  
DETERMINATION, AND OPPORTUNITY FOR A HEARING, R.E. GINNA NUCLEAR  
POWER PLANT (TAC NO. M95759)

Dear Dr. Mecredy:

The Commission has requested the Office of the Federal Register to  
publish the enclosed "Notice of Consideration of Issuance of Amendment to  
Facility Operating License, Proposed No Significant Hazards Consideration  
Determination, and Opportunity for a Hearing." This notice relates to your  
application for amendment dated March 31, 1997, which would revise the Ginna  
Station Improved Technical Specifications (ITSs) to reflect a planned  
modification to the spent fuel pool storage racks.

Sincerely,

/s/

Guy S. Vissing, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure: Notice of Consideration

cc/wencls: See next page

**DISTRIBUTION:**

Docket File	S. Varga	OGC
PUBLIC	S. Bajwa	ACRS
PDI-1 R/F	G. Vissing	C. Cowgill, RI

010108

**NRC FILE CENTER COPY**

1/1  
DF01

DOCUMENT NAME: G:\GINNA\M95759.IND

To receive a copy of this document, indicate in the box: "C" = Copy without  
attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E	LA:PDI-1	D:PDI-c				
NAME	GVissing/rsl		SLittle	SBajwa				
DATE	04/24/97		04/24/97	04/24/97				

Official Record Copy

9705010306 970424  
PDR ADOCK 05000244  
P PDR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 24, 1997

Dr. Robert C. Mecredy  
Vice President, Nuclear Operations  
Rochester Gas and Electric Corporation  
89 East Avenue  
Rochester, NY 14649

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION  
DETERMINATION, AND OPPORTUNITY FOR A HEARING, R.E. GINNA NUCLEAR  
POWER PLANT (TAC NO. M95759)

Dear Dr. Mecredy:

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing." This notice relates to your application for amendment dated March 31, 1997, which would revise the Ginna Station Improved Technical Specifications (ITSs) to reflect a planned modification to the spent fuel pool storage racks.

Sincerely,

A handwritten signature in cursive script, reading "Guy S. Vissing", is positioned above the typed name.

Guy S. Vissing, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure: Notice of Consideration

cc/wencls: See next page

Dr. Robert C. Mecredy

R.E. Ginna Nuclear Power Plant

cc:

Peter D. Drysdale, Senior Resident Inspector  
R.E. Ginna Plant  
U.S. Nuclear Regulatory Commission  
1503 Lake Road  
Ontario, NY 14519

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. F. William Valentino, President  
New York State Energy, Research,  
and Development Authority  
Corporate Plaza West  
286 Washington Avenue Extension  
Albany, NY 12203-6399

Charlie Donaldson, Esq.  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Nicholas S. Reynolds  
Winston & Strawn  
1400 L St. N.W.  
Washington, DC 20005-3502

Ms. Thelma Wideman  
Director, Wayne County Emergency  
Management Office  
Wayne County Emergency Operations Center  
7336 Route 31  
Lyons, NY 14489

Ms. Mary Louise Meisenzahl  
Administrator, Monroe County  
Office of Emergency Preparedness  
111 West Fall Road, Room 11  
Rochester, NY 14620

Mr. Paul Eddy  
New York State Department  
of Public Service  
3 Empire State Plaza, Tenth Floor  
Albany, NY 12223

UNITED STATES NUCLEAR REGULATORY COMMISSIONROCHESTER GAS AND ELECTRIC CORPORATIONDOCKET NO. 50-244

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS  
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DRP-18 issued to Rochester Gas & Electric Corporation for operation of the R. E. Ginna Nuclear Power Plant located in Wayne County, New York.

The proposed amendment would revise the Ginna Station Improved Technical Specifications (ITS) to reflect a planned modification to the spent fuel pool (SFP) storage racks. Specifications associated with SFP boron concentration, fuel assembly storage, and the maximum limit on the number of fuel assemblies which can be stored in the SFP would be revised.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee

9705010313 970424  
PDR ADOCK 05000244  
P PDR

has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Operation of Ginna Station in accordance with the proposed changes does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The design basis events considered for the spent fuel pool include both external events and postulated accidents in the pool. The external events considered are tornado missiles and seismic events. The evaluation of the postulated impact of a tornado missile is detailed in Sections 3, 4, and 6 of Reference 1 [see application dated March 31, 1997]. The structural evaluation indicates that there are no gross distortions of the racks or any adverse effects upon plant structures or equipment. The radiological consequences of this event indicate that offsite doses are "well within" the 10 CFR 100 limits.

The structural evaluation is detailed in Section 3 of Reference 1 [see application dated March 31, 1997]. Current state of the art methods are used in the structural analysis. The evaluation of the storage racks is based on a conservative interpretation of the ASME [American Society of Mechanical Engineers] Boiler and Pressure Vessel Code. The evaluation of the spent fuel pool is based on a conservative interpretation of requirements set forth in the American Concrete Institute, Code Requirements for Nuclear Safety Related Concrete Structures, and American Institute of Steel Construction, Specification for Structural Steel Buildings. The spent fuel storage system was designed to meet all applicable structural criteria for normal (Level A), upset (Level B), and faulted (Level D) conditions as defined in NUREG-0900, SRP [Standard Review Plan] 3.8.4, Appendix D. The following loadings were considered: dead weight, seismic, thermal, stuck fuel assembly, drop a fuel assembly, and tornado missile impact. Load combinations were performed in accordance with SRP 3.8.4, Appendix D. Given the evaluated seismic events, the changes in the final position of the racks are small as compared to the initial position prior to the seismic event. The maximum closure of gaps is such that no significant changes in gaps result during any single seismic event. Furthermore, the combined gap closures resulting from a combination of 5 OBEs [Operating Basis Earthquakes] and 1 SSE [Safe Shutdown Earthquake] show that there are no rack-to-rack or rack-to-wall impacts. These evaluations conclude that under these postulated events the stored fuel assemblies are maintained in a stable, coolable geometry, and a subcritical configuration.

As described in the bases for LCO [Limiting Condition for Operation] 3.7.12 and 3.7.13, the postulated accidents in the spent fuel pool are divided into two categories. The first are those involving a loss of cooling in the spent fuel pool. The

thermal-hydraulic analysis for the maximum expected decay heat loads is described in Section 5 of Reference 1 [see application dated March 31, 1997]. The proposed modification does not change the configuration of the available spent fuel cooling systems, the limiting design conditions for maximum decay heat load which occurs during a full core offload, or the existing requirement to maintain pool temperature below 150°F. Utilizing the three available spent fuel cooling systems, Ginna Station maintains full redundancy during high heat load conditions. The decay heat load to the spent fuel pool is maintained within the capacity of the operating cooling system by appropriately delaying fuel offload from the reactor. Should a failure occur on the operating cooling system, the resulting heat rates allow sufficient time to place a standby cooling system in service before the pool design limit temperature is exceeded. Increases in spent fuel pool temperature, with the corresponding decrease in water density and void formation from boiling, will result in a decrease in reactivity due to the decrease in moderation effects. In addition, the analysis demonstrates that the storage rack geometry and required fuel storage configurations result in a  $K_{eff} \leq$  [less than or equal to] .95 assuming no soluble boron allowing for the potential of makeup to the pool with unborated water.

The second category is related to the movement of fuel assemblies and other loads above the spent fuel pool. The limiting accident with respect to reactivity is the fuel handling accident which is analyzed in Section 4 of Reference 1 [see application dated March 31, 1997]. For both the incorrectly transferred fuel assembly (placed in an unauthorized location) or a dropped fuel assembly, the positive reactivity effects resulting are offset by the negative reactivity from the required minimum soluble boron concentration. The resulting  $K_{eff}$  is shown to be less than 0.95. The radiological consequences of a fuel assembly drop remain as described in Section 15.7.3 of the UFSAR [Updated Final Safety Analysis Report] and as discussed in Section 6 of Reference 1 [see application dated March 31, 1997]. Loads in excess of a fuel assembly and its handling tool are administratively prohibited from being carried over spent fuel. There are no changes anticipated for either the fuel handling equipment or the auxiliary building overhead crane due to the proposed modification to the fuel storage racks. The modification is scheduled for the Year 1998 to be performed while Ginna Station is operating. Movement of heavy loads around the spent fuel pool are controlled by the requirements of NUREG-0612 and the regulatory guidelines set forth in NRC Bulletin 96-02 (see Section 3 of Reference 1). [see application dated March 31, 1997]. Spent fuel casks and storage racks (during removal and installation) will be moved using the auxiliary building crane and lifting attachments satisfying the single failure proof criteria of NUREG-0554, obviating the need to determine the consequences for this accident.

Based on the above, it is concluded that the proposed changes do not significantly increase the probability or consequences of any accident previously analyzed.

2. Operation in accordance with the proposed changes does not create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed modification does not alter the function of any system associated with spent fuel handling, cooling, or storage. The proposed changes do not involve a different type of equipment or changes in methods governing normal plant operation. The additional restrictions placed on the acceptable storage locations for spent fuel are consistent with the type of restriction that previously existed. The potential violation of these restrictions (incorrectly transferred fuel assembly) are analyzed as discussed above. The design, analysis, fabrication, and installation meet all the appropriate NRC regulatory requirements, and appropriate industry codes and standards.

Based on the above, the change does not create the possibility of a new or different kind of accident from any previously analyzed.

3. Operation of Ginna Station in accordance with the proposed changes does not involve a significant reduction in the margin of safety.

The Licensing Report enclosed as Reference 1 [see application dated March 31, 1997] addresses the following considerations: nuclear criticality, thermal-hydraulic, and mechanical, material, and structural. Results of these evaluations demonstrate that the changes associated with the spent fuel reracking do not involve a significant reduction in the margin of safety as summarized below:

#### Nuclear Criticality

The established regulatory acceptance criterion is that  $K_{eff}$  be less than or equal to 0.95, including all uncertainties at the 95/95 probability/confidence level, under normal and abnormal conditions. The methodology used in the evaluation meets NRC requirements, and applicable industry codes, standards, and specifications. In addition, the methodology has been reviewed and approved by the NRC in recent nuclear criticality evaluations. Specific conditions which were evaluated include misloading of a fuel assembly, drop of a fuel assembly (shallow, deep drops, and side drops), pool water temperature effects, and movement of racks due to seismic events. Results described in Section 4 of Reference 1 [see application dated March 31, 1997] document that the criticality acceptance criterion is met for all normal and abnormal conditions.

### Thermal-Hydraulic

Conservative methods and assumptions have been used to calculate the maximum temperature of the fuel and the increase of the bulk pool water temperature in the spent fuel pool under normal and abnormal conditions. The methodology for performing the thermal-hydraulic evaluation meets NRC regulatory requirements. Results from the thermal-hydraulic evaluation show that the maximum temperature of the hottest fuel assembly, intact or consolidated canister, is less than the temperature for nucleate boiling condition. The effects of cell blockage on the maximum temperature of intact fuel and consolidated canisters were evaluated. Results described in Section 5 of Reference 1 [see application dated March 31, 1997] show that adequate cooling of the intact or consolidated fuel is assured. In all cases the existing spent fuel pool cooling system will maintain the bulk pool temperature at or below 150°F by delaying core offload from the reactor.

### Mechanical, Material, and Structural

The primary safety function of the spent fuel pool and the racks is to maintain the spent fuel assemblies in a safe configuration through all normal and abnormal loads. Abnormal loadings which have been considered in the evaluation are: seismic events, the drop of a fuel assembly, the impact of a tornado missile, a stuck assembly, and the drop of a heavy load. The mechanical, material, and structural design of the new spent fuel racks is in accordance with NRC regulatory requirements (including the NRC OT Position dated April 14, 1978, [NRC letter to all power reactor licensees dated April 14, 1978] and addendum dated January 18, 1979), and applicable industry standards. The rack materials are compatible with the spent fuel pool environment and fuel assemblies. The material used as a neutron absorber (borated stainless steel) has been approved by the American Society for Testing and Materials (ASTM), and licensed previously by the NRC for use as a neutron absorber at Indian Point 3, Indian Point 2, and Millstone 2. The structural evaluation presented in Section 3 of Reference 1 [see application dated March 31, 1997] documents that the tipping or sliding of the free-standing racks will not result in rack-to-rack or rack-to-wall impacts during seismic events. The spent fuel assemblies will remain intact and the criticality criterion of  $k_{eff}$  less than or equal to 0.95 is met.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.



The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the FEDERAL REGISTER a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Rules Review and Directives Branch, Division of Freedom of Information and Publications Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this FEDERAL REGISTER notice. Written comments may also be delivered to Room 6D22, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By May 30, 1997 , the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Rochester Public Library, 115 South Avenue, Rochester, New York 14610. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition

should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the

opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to S. Singh Bajwa, petitioner's name and telephone number, date petition was mailed, plant name, and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Nicholas S.


Reynolds, Winston & Strawn, 1400 L Street, NW., Washington, DC 20005,  
attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated March 31, 1997, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Rochester Public Library, 115 South Avenue, Rochester, New York 14610.

Dated at Rockville, Maryland, this 24th day of April 1997.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "Guy S. Vissing".

Guy S. Vissing, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation