

March 9, 2001

Mr. Gary J. Toman, Project Manager
Plant Supporting Engineering
Science and Technology Division
EPRI
1300 W.T. Harris Blvd.
Charlotte, NC 28262

Dear Mr. Toman:

I am writing in response to your letter, dated October 30, 2000, in which you provide comments on the NRC staff's presentation to the Advisory Committee on Reactor Safeguards (ACRS), and other recent technical meetings about the environmental qualification (EQ) of electric cables.

First, I wish to thank you for your comments and for the interest that you have shown in our cable research program. We look forward to your continuing interaction as we explore resolution paths for GSI-168.

Clearly, you and the staff disagree on some of the information and we would welcome an opportunity to discuss these areas of disagreement in an effort to bring about a timely and definitive resolution to GSI-168.

With regard to the staff's concern about the single prototype test acceptability, this is an issue that has emerged as the staff has considered the test "failures" from our research. Clearly, single prototype testing has been used for many applications and will almost certainly be used for many future applications. However, the staff feels that the use of a single cable specimen for environmental qualifications warrants further discussion.

I suggest that we enter into a limited series of public meetings to fully discuss our respective views of the research results and cable qualification. I have asked my staff to begin preparation for these meetings.

Your continued interest in our research activities is appreciated.

Sincerely,

/RA/ approved by

Michael E. Mayfield, Director
Division of Engineering Technology
Office of Nuclear Regulatory Research

cc: Jim Lang, EPRI

Mr. Gary J. Toman, Project Manager
Plant Supporting Engineering
Science and Technology Division
EPRI
1300 W.T. Harris Blvd.
Charlotte, NC 28262

Dear Mr. Toman:

I am writing in response to your letter, dated October 30, 2000, in which you provide comments on the NRC staff's presentation to the Advisory Committee on Reactor Safeguards (ACRS), and other recent technical meetings about the environmental qualification (EQ) of electric cables.

First, I wish to thank you for your comments and for the interest that you have shown in our cable research program. We look forward to your continuing interaction as we explore resolution paths for GSI-168.

Clearly, you and the staff disagree on some of the information and we would welcome an opportunity to discuss these areas of disagreement in an effort to bring about a timely and definitive resolution to GSI-168.

With regard to the staff's concern about the single prototype test acceptability, this is an issue that has emerged as the staff has considered the test "failures" from our research. Clearly, single prototype testing has been used for many applications and will almost certainly be used for many future applications. However, the staff feels that the use of a single cable specimen for environmental qualifications warrants further discussion.

I suggest that we enter into a limited series of public meetings to fully discuss our respective views of the research results and cable qualification. I have asked my staff to begin preparation for these meetings.

Your continued interest in our research activities is appreciated.

Sincerely,

Michael E. Mayfield, Director
Division of Engineering Technology
Office of Nuclear Regulatory Research

cc: Jim Lang, EPRI

Distribution:

MEB r/f

M.Mayfield (Signature File)

DOCUMENT NAME:G:\Aggarwal\restoman2.wpd

OAR in ADAMS? (Y or N) Y

ADAMS ACCESSION NO.: ML010640016

TEMPLATE NO. RES-007

Publicly Available? (Y or N) Y

DATE OF RELEASE TO PUBLIC 03/19/2001

SENSITIVE? N

*See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	MEB/DET/RES	C	MEB/DET/RES		D/DE/NRR		D/DET/RES			
NAME	S. Aggarwal*		N. Chokshi*		J. Strosnider*		M. Mayfield			
DATE	03/04/01		03/05/01		03/08/01		03/09/01			

(RES File Code) RES _____

ROUTING AND TRANSMITTAL SLIP

DATE: March 12, 2001

TO:	INITIALS	DATE
1. S. Aggarwal - initial/concur		
2. F. Cherny - initial/concur		
3. N. Chokshi - initial/concur		
4. J. Strosnider- initial/concur		
5. M. Mayfield - initial/sign/concur		
6. R. Lambert - Dispatch		
7.		

	Action		File		Note and Return
X	Approval		For Clearance		Per Conversation
	As Requested		For Correction		Prepare Reply
	Circulate		For Your Info		See Me
	Comment		Investigate	X	Signature
	Coordination		Justify		Concurrence

LETTER TO: G. Toman, EPRI

FROM: M. Mayfield

RE: Response to October 30, 2000 letter, implication of unacceptable qualification practices for cables.

FROM: R. Lambert

Room No.
T-10-E-6
Phone No.
x5686