

2/10/00

Plugging NRE + Comm. TA's on SEP:

[Shouldn't insurance cost less if risk is less.]

[CT: → Reduce % large amount of R₁ could have a substantial impact on the consequences.]

TA1: Much better draft than June draft.

TA2: Fire in waste storage area?

[NRR: We are having a contractor look at it.]

[MACCS safety Run:
Errors in inventory, DCFs, etc. ?]

F1/24

TA3: Zr fire - 10 to 12 hours to get Zr fire.
Adiabatic heating?

Hubbard: No

TA3: Security -- how being dovetailed w/ Security Rulemaking?

Barrett: I do not know.

TA3: Late decommissioning?
Early decommissioning?

Barrett: Late decommissioning is after 5 years.

TA4: ~~Do~~ industry + NRC have tools to analyze TH

Kelton: we are sending a user need to RES on this.
Industry has used CFD, and have not been
very successful.