

Rec'd 5/11/99 from M. Check

Frequency of Fuel Uncovery (yr⁻¹)

DRAFT Based on 1 yr old fuel

	<u>"As Found"</u>	<u>"Minimal"</u>
Loss of offsite power	1E-5	6.3E-5
Internal Fire	2E-5	4E-5
Loss of Cooling	9E-7	2E-5
Loss of Coolant Inventory		
- thru connected systems and/or operator errors	1E-5	3.1E-4
- seismic	2E-6	2E-6
- cask drop	1.5E-5	1.5E-4
- aircraft impact	4E-8	4E-8
- tornado missile	1E-7	1E-7
	<u>5.8E-5/yr</u>	<u>5.9E-4/yr</u>

C/47