

March 13, 2001

Mr. Mark E. Warner
Vice President - TMI Unit 1
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

SUBJECT: TMI-1 - CORRECTION TO AMENDMENT NO. 229 RE: EXIGENT TECHNICAL SPECIFICATION CHANGE REQUEST NO. 309, NUCLEAR SERVICES RIVER WATER SYSTEM (TAC NO. MB1308)

Dear Mr. Warner:

The Commission issued Amendment No. 229 to Facility Operating License No. DPR-50 for the Three Mile Island Nuclear Station, Unit 1 (TMI-1), on February 23, 2001, in response to your application dated February 14, 2001, as supplemented February 16, and 19, 2001.

The amendment allowed a one-time exception to the system configuration and maintenance requirements in Technical Specification (TS) 3.3.2 related to the nuclear service river water (NR) system at TMI-1, in order to allow a proposed up to 14-day repair of a leaking underground concrete pipe. Compensatory actions 1-6 listed on page 5 of Enclosure 1 to your February 14, 2001, application were made a condition of Amendment No. 229.

On March 1, 2001, you provided a clarification of your intent with respect to implementing those compensatory actions. You stated that 2 of the 6 compensatory actions (items 1 and 2) listed under the heading, "Actions Required Prior to Cross Connecting SR [secondary service river water] and NR and Repairing Pipe," in your February 14, 2001, application, were intended to be prerequisites to repairing the pipe after cross-connecting the SR and NR systems, while the remaining 4 of 6 items were meant to be prerequisites to cross-connecting the systems. While this intent was clearly stated for the second compensatory action listed, it was not clearly stated for the first compensatory action listed. However, the preferable sequence of steps for implementing the first compensatory action demonstrates the intent of performing that compensatory action after the SR and NR systems are cross-connected, rather than before. In order to eliminate any potential confusion with respect to the sequence of performing the compensatory actions listed as conditions of approval of Amendment No. 229, we are reissuing the implementation page of the amendment with a corrected implementation date which is enclosed.

Additionally, your March 1, 2001, letter provided a clarification of the term "acceptably leak tight" with respect to your first compensatory action. You described the procedural inspections and verifications which would be performed both prior to and during the repairs to ensure that any leakage past the leak isolation valves would neither adversely impact the ability of the coolers supplied by NR to continue to be able to cool their components nor adversely impact

M. Warner

-2-

repairs or personnel safety. The above clarifications are accepted and are consistent with the intent of Amendment No. 229.

If you have any questions, please contact me at (301) 415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure: Corrected Implementation Page of Amendment No. 229

cc w/encl: See next page

M. Warner

-2-

March 13, 2001

repairs or personnel safety. The above clarifications are accepted and are consistent with the intent of Amendment No. 229.

If you have any questions, please contact me at (301) 415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure: Corrected Implementation Page of Amendment No. 229

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	ACRS	OGC	SWong	MGamberoni
PDI-1R/F	GHubbard	DJeng	WBeckner	GHill, (2)
DSkeen	BPlatchek, RI	MO'Brien (2)	KManoly	EAdensam
TColburn	MCaruso			

Accession Number: ML010710227

OFFICE	PDI-1\PM	PDI-2\LA	SPLB\SC	PDI-1\SC
NAME	TColburn	MO'Brien	GHubbard	MGamberoni
DATE	3/12/01	3/12/01	3/12/01	3/12/01

OFFICIAL RECORD COPY

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-50 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 229, are hereby incorporated in the license. The AmerGen Energy Company, LLC shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance. Compensatory actions 1 and 2 listed on page 5 of Enclosure 1 to the licensee's February 14, 2001, application shall be implemented after cross-connecting the nuclear services river water (NR) and secondary services river water (SR) systems but prior to performing repairs on the NR system pipe. Compensatory actions 3 through 6 listed on page 5 of Enclosure 1 to the licensee's February 14, 2001, application shall be implemented prior to cross-connecting the NR and SR systems and prior to performing repairs on the NR system pipe.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Marsha Gamberoni, Chief, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: February 23, 2001

Three Mile Island Nuclear Station, Unit No. 1

cc:

George H. Gellrich
Plant Manager
AmerGen Energy Company, LLC
P. O. Box 480
Middletown, PA 17057

James A. Hutton
Director - Licensing
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box 195
Wayne, PA 19087-0195

Edwin C. Fuhrer
Manager - Regulatory Engineering
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

Edward J. Cullen, Jr., Esquire
PECO Energy Company
2301 Market Street (S23-1)
Philadelphia, PA 19103

Jeffrey A. Benjamin
Licensing - Vice President
Exelon Corporation
1400 Opus Place, Suite 900
Downer's Grove, IL 60521

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, PA 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, PA 17057

Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
P.O. Box 219
Middletown, PA 17057

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Robert B. Borsum
B&W Nuclear Technologies
Suite 525
1700 Rockville Pike
Rockville, MD 20852

David J. Allard, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

John F. Rogge, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Eric Epstein
TMI Alert
4100 Hillsdale Road
Harrisburg, PA 17112