

March 16, 2001

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT(STP), UNIT 2 - CORRECTION OF AN
ADMINISTRATIVE ERROR REGARDING AMENDMENT FOR REVISION TO
THE TECHNICAL SPECIFICATIONS IMPLEMENTING 3-VOLT ALTERNATE
REPAIR CRITERIA FOR STEAM GENERATOR TUBE REPAIR
(TAC NO. MA8271)

Dear Mr. Cottle:

On March 8, 2001, the Nuclear Regulatory Commission issued Amendment No. 114 to Facility Operating License No. NPF-80 for the STP Unit 2. The amendment related to approval of the licensee request for application of 3-volt alternate repair criteria to the methodology for repair of steam generator tubes.

Through an administrative error, the "Attachment to license Amendment 114" listing the Technical Specification page replacements inadvertently included removal and insertion of pages 3/4-12, 3/4-14, and 3/4-15. Those pages are not to be removed or inserted. The page, showing the corrected list, is included for your use.

Sincerely,

/RA/

Mohan C. Thadani, Senior Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Corrected page

cc w/encl: See next page

ATTACHMENT TO LICENSE AMENDMENT NO. 114

FACILITY OPERATING LICENSE NO. NPF-80

DOCKET NO. 50-499

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

REMOVE

3/4 4-13
3/4 4-13a
3/4 4-16
3/4 4-16a
3/4 4-16b

3/4 4-18
3/4 4-18a
B 3/4 4-3

INSERT

3/4 4-13
3/4 4-13a
3/4 4-16
3/4 4-16a
3/4 4-16b
3/4 4-16c
3/4 4-18
3/4 4-18a
B 3/4 4-3

*Overleaf pages provided to maintain document completeness. No changes on these pages.

South Texas, Unit 2

cc:

Mr. Cornelius F. O'Keefe
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. M. T. Hardt
Mr. W. C. Gunst
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Mr. G. E. Vaughn/C. A. Johnson
Central Power and Light Company
P. O. Box 289
Mail Code: N5012
Wadsworth, TX 74483

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414

A. H. Gutterman, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

Mr. J. J. Sheppard, Vice President
Engineering & Technical Services
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

S. M. Head, Supervisor, Licensing
Quality & Licensing Department
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Jon C. Wood
Matthews & Branscomb
One Alamo Center
106 S. St. Mary's Street, Suite 700
San Antonio, TX 78205-3692

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326

February 2000

March 16, 2001

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT(STP), UNIT 2 - CORRECTION OF AN
ADMINISTRATIVE ERROR REGARDING AMENDMENT FOR REVISION TO
THE TECHNICAL SPECIFICATIONS IMPLEMENTING 3-VOLT ALTERNATE
REPAIR CRITERIA FOR STEAM GENERATOR TUBE REPAIR
(TAC NO. MA8271)

Dear Mr. Cottle:

On March 8, 2001, the Nuclear Regulatory Commission issued Amendment No. 114 to Facility Operating License No. NPF-80 for the STP Unit 2. The amendment related to approval of the licensee request for application of 3-volt alternate repair criteria to the methodology for repair of steam generator tubes.

Through an administrative error, the "Attachment to license Amendment 114" listing the Technical Specification page replacements inadvertently included removal and insertion of pages 3/4-12, 3/4-14, and 3/4-15. Those pages are not to be removed or inserted. The page, showing the corrected list, is included for your use.

Sincerely,

/RA/

Mohan C. Thadani, Senior Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Corrected page

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDlpmLpdiv (SRichards)	G.Hill (2)
PDIV-1 RF	RidsAcrcAcnwMailCenter	RidsNrrDlpm (JZwolinski/SBlack)
	RidsNrrDlpmLpdiv (RGramm)	RidsNrrLAMMcAllister
	RidsNrrPMMThadani	RidsNrrDripRtsb (WBeckner)
RidsOgcRp	RidsRgn4MailCenter (KBrockman, JTapia, LHurley, DBujol)	

ACCESSION NUMBER: ML010750545

OFFICE	PDIV-1/PM	PDIV-D/LA	PDIV-1/SC
NAME	MThadani:db	MMcAllister	RGramm
DATE	03/15/01	03/15/01	03/16/01

OFFICIAL RECORD COPY