



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 16, 2001

Mr. Mark Reddemann  
Site Vice President  
Kewaunee and Point Beach Nuclear Power Plants  
Nuclear Management Company, LLC  
6610 Nuclear Road  
Two Rivers, WI 54241

SUBJECT: KEWAUNEE NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL  
INFORMATION RELATED TO RELOAD SAFETY EVALUATION METHODS  
TOPICAL REPORT, WPSRSEM-NP, REVISION 3 (TAC NO. MB0306)

Dear Mr. Reddemann :

By letter dated October 12, 2000, Nuclear Management Company, LLC (NMC or the licensee) forwarded a topical report WPSRSEM-NP, Revision 3, entitled, "Reload Safety Evaluation Methods for Application to Kewaunee" and requested Nuclear Regulatory Commission (NRC) staff review and approval. Also, the topical report is intended to be applicable to Kewaunee reload cycles after and including Cycle 25, presently scheduled to commence in the fall of 2001.

The topical report reflects the following:

- Editorial changes, including corrections to the limiting directions of core physics parameters and clarification of the definition of core physics parameters.
- Changes made to incorporate the CONTEMPT code for containment analysis. CONTEMPT is currently described for this purpose in the Kewaunee updated safety analysis report (USAR).
- The adoption of the GOTHIC code for containment analysis.
- Changes in Reload Safety Evaluation Methods due to Large Break Loss-of-Coolant Accident Upper Plenum Injection Analysis.
- The adoption of RETRAN- 3D for use in the 2D mode for system analysis.
- The extension of the VIPRE-01 code to reflect changes in fuel design.

The NRC staff finds that the additional information identified in Enclosure 1 is needed.

A draft of the request for additional information (RAI) (Enclosure 2) was e-mailed to Mr. G. Riste (NMC) and discussed by telephone call on March 12, 2001. Another phone call was held on March 14, 2001, between the NRC staff and the NMC staff to discuss the questions to ensure that there was no misunderstanding.

Also, the phone call on March 14, 2001, established that 21 days after the date of this letter, would be a mutually agreeable response date.

M. Reddemann

- 2 -

Please contact me at (301) 415-1446 if future circumstances should require a change in this response date.

Sincerely,

/RA/

John G. Lamb, Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation




Docket No. 50-305

Enclosures: 1. Request for Additional Information  
2. E-mail with Draft Request for Additional Information

cc w/encls: See next page

DISTRIBUTION

PUBLIC	SBlack	SSun
PDIII-1 Reading	LBerry	RLanksbury, RIII
CCraig	OGC	
JLamb	ACRS	
THarris	FAkstulewicz	

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	JLamb 	THarris 	CCraig 
DATE	03/16/01	03/16/01	03/16/01


DOCUMENT NAME: G:\PDIII-1\KEWAUNEE\RA\mb0306SPLB.wpd  
OFFICIAL RECORD COPY

M. Reddemann

- 2 -

Please contact me at (301) 415-1446 if future circumstances should require a change in this response date.

Sincerely,

A handwritten signature in black ink, appearing to read "John G. Lamb". The signature is fluid and cursive, with the first name "John" being the most prominent part.

John G. Lamb, Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-305

Enclosures: 1. Request for Additional Information  
2. E-mail with Draft Request for Additional Information

cc w/encls: See next page

Kewaunee Nuclear Power Plant

cc:

Foley & Lardner  
ATTN: Bradley D. Jackson  
One South Pinckney Street  
P.O. Box 1497  
Madison, WI 53701-1497

Nuclear Asset Manager  
Wisconsin Public Service Corporation  
600 N. Adams Street  
Green Bay, WI 54307-9002

Chairman  
Town of Carlton  
Route 1  
Kewaunee, WI 54216

Plant Manager  
Kewaunee Nuclear Power Plant  
Nuclear Management Company, LLC  
North 490, Highway 42  
Kewaunee, WI 54216-9511

Gerald Novickus, Chairman  
Kewaunee County Board  
Kewaunee County Courthouse  
Kewaunee, WI 54216

Attorney General  
114 East, State Capitol  
Madison, WI 53702

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Route #1, Box 999  
Kewaunee, WI 54216

Regional Administrator - Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4531

James D. Loock, Chief Engineer  
Public Service Commission  
of Wisconsin  
610 N. Whitney Way  
Madison, WI 53707-7854

Michael D. Wadley  
Chief Nuclear Officer  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

**REQUEST FOR ADDITIONAL INFORMATION REGARDING**  
**KEWAUNEE RELOAD SAFETY EVALUATION METHODS TOPICAL REPORT,**  
**WPSRSEM-NP, REVISION 3 (TAC NO. MB0306)**

The Nuclear Regulatory Commission (NRC) staff finds that the following additional information is needed:

1. Please provide one copy of Reference A12, WCAP-15427, "Development and Qualification of a GOTHIC Containment Evaluation Model for the Kewaunee Nuclear Power Plant," R. Ofstun, July 2000.
2. To the extent that the above report does not contain this information, provide for the GOTHIC model:
  - 2.1 Details of how the Kewaunee containment will be modeled for a loss-of-coolant (LOCA) and a main steamline break.
  - 2.2 Assumptions used for licensing basis calculations including containment initial conditions of temperature, pressure and humidity; heat transfer correlations; modeling of the velocity of the containment atmosphere and its effect on heat transfer; timing of engineered safety feature (ESF) equipment; assumptions of spray behavior (droplet size distribution, spray effectiveness); interactions of containment atmosphere with the sump following a LOCA; modeling of residual heat removal (RHR) heat exchanger; modeling of fan coolers; modeling of containment structures; any other modeling assumptions which have a significant effect on the calculated pressure and temperature of the containment.
  - 2.3 Describe or provide a reference on how calculations of the mass and energy release (including entrainment) to the containment are performed.
  - 2.4 List and describe the conservatism in the above modeling.
  - 2.5 List any other licensing basis uses of the GOTHIC code beside LOCA and main steamline break analyses.
3. Is the Kewaunee use of GOTHIC consistent with the guidance of generic letter (GL) 83-11, "Licensee Qualification for Performing safety Analyses in Support of Licensing Actions," [February 8, 1983] and GL 83-11 Supplement 1, "Licensee Qualification for Performing Safety Analyses" [June 24, 1999]?

ENCLOSURE 1

REQUEST FOR ADDITIONAL INFORMATION  
WISCONSIN PUBLIC SERVICE CORPORATION RELOAD SAFETY EVALUATION  
METHODS TOPICAL REPORT  
WPSRSEM-NP, Revision 3

1. Please provide one copy of Reference A12, WCAP-15427, "Development and Qualification of a GOTHIC Containment Evaluation Model for the Kewaunee Nuclear Power Plant," R. Ofstun, July 2000
2. To the extent that the above report does not contain this information, provide for the GOTHIC model:
  - 2.1 Details of how the Kewaunee containment will be modeled for a LOCA and a main steam line break
  - 2.2 Assumptions used for licensing basis calculations including containment initial conditions of temperature, pressure and humidity; heat transfer correlations; modeling of the velocity of the containment atmosphere and its effect on heat transfer; timing of ESF equipment; assumptions of spray behavior (droplet size distribution, spray effectiveness); interactions of containment atmosphere with the sump following a LOCA; modeling of RHR heat exchanger; modeling of fan coolers; modeling of containment structures; any other modeling assumptions which have a significant effect on the calculated pressure and temperature of the containment.
  - 2.3 Describe or provide a reference on how calculations of the mass and energy release (including entrainment) to the containment are performed.
  - 2.4 List and describe the conservatisms in the above modeling
  - 2.5 List any other licensing basis uses of the GOTHIC code beside LOCA and main steam line break analyses.
3. Does the Kewaunee use of GOTHIC comply with the guidance of GL 83-11, "Licensee Qualification for Performing safety Analyses in Support of Licensing Actions," [February 8, 1983] and GL 83-11 Supplement 1, "Licensee Qualification for Performing Safety Analyses?" [June 24, 1999]

ENCLOSURE 2

**From:** John Lamb  
**To:** internet: griste@wpsr.com  
**Date:** 3/12/01 4:30PM  
**Subject:** Fwd: Questions on 10/12/200 report concerning containment

Gerry,

Attached are draft questions concerning the GOTHIC code of your Reload Amendment submittal. Please review the questions. I will call you to set up a conference call to ensure that we understand the questions and to set up a response date, then I will send a formal RAI letter to you.

John

ENCLOSURE 2

**From:** Richard Lobel  
**To:** John Lamb  
**Date:** 3/12/01 4:20PM  
**Subject:** Questions on 10/12/200 report concerning containment

I have revised the questions from the ones I sent to you earlier. They are ready to transmit to the licensee.

**ENCLOSURE 2**