

March 20, 2001

Mr. H. B. Barron
Vice President, McGuire Site
Duke Energy Corporation
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

SUBJECT: MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 RE: PROPOSED MEETING TO
DISCUSS PROMATEC HEMYC 1-HOUR AND MT 3-HOUR FIRE BARRIER
SYSTEMS (TAC NO. MB1311)

Dear Mr. Barron:

During a November 1999 fire protection inspection at Carolina Power & Light Company's Shearon Harris Nuclear Power Plant (HNP), NRC Region II inspectors identified a potential issue associated with Promatec Hemyc 1-hour and MT 3-hour fire barrier systems not being qualified to meet Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, Appendix R, safe shutdown separation requirements. In a November 23, 1999, Task Interface Agreement (TIA 99-028; ADAMS Accession No. ML003671052), Region II requested the Office of Nuclear Reactor Regulation's (NRR's) assistance to resolve this issue. In its August 1, 2000, response to TIA 99-028 (ADAMS Accession No. ML003736721), the NRR staff concluded that the fire rating of the installed fire wrap at HNP was indeterminate.

The Nuclear Energy Institute (NEI) confirmed that the plants listed below use Hemyc or MT fire wrap to comply with 10 CFR Part 50, Appendix R, safe shutdown separation requirements.

Arkansas Nuclear One Units 1 and 2
Catawba Units 1 and 2
Ginna
Indian Point Units 2 and 3
Robinson 2
Waterford

Beaver Valley Unit 1
FitzPatrick
Harris
McGuire Units 1 and 2
Vermont Yankee

The NRR staff requested that NEI coordinate a generic industry initiative to address the Hemyc and MT fire barrier issue, but NEI declined. Therefore, the staff will be working with the affected licensees to resolve this issue. The staff's planned course of action includes meeting with the affected licensees as a group to discuss (1) the technical issues, (2) the applicability of the issues to the affected plants, and (3) the ultimate resolution of the issue. We are requesting that the affected licensees take the issue on as a voluntary initiative and propose an approach for resolving the issue.

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager, Section II-1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

cc: See next page

In the near future, the NRC Lead Project Manager for this issue, Richard Laufer, or I will contact you and the other affected licensees to arrange a joint meeting to discuss the Hemyc and MT fire barrier issue. Allowing time for licensees to review and consider the results from the HNP review (TIA 99-028), we estimate that the meeting will take place in the May - June 2001 timeframe.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager, Section II-1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

cc: See next page

Distribution:

PUBLIC

PD II-1 Rdg.

GJanosko

RidsNrrDlpmLpdii1 (paper copy)

SRosenberg

RLaufer

MBanerjee

RidsNrrLACHawes (paper copy)

RidsNrrPMRMartin (paper copy)

RidsOgcRp

GHill (2) (paper copies)

RidsAcrsAcnwMailCenter

RidsRgn2MailCenter

DOCUMENT NAME: C:\LtrMB1311.wpd

OFFICE	PDII-1/PM	PDII-1/LA	SPLB	SPLB	PDII-1/SC(A)
NAME	RMartin:cn	CHawes	DFrumkin	DWeiss	MBanerjee
DATE	3/13/01	3/13/01	3/14/01	3/14/01	3/19/01

OFFICIAL RECORD COPY

McGuire Nuclear Station

cc:

Ms. Lisa F. Vaughn
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

County Manager of
Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Michael T. Cash
Regulatory Compliance Manager
Duke Energy Corporation
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Anne Cottingham, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Mr. Steven P. Shaver
Senior Sales Engineer
Westinghouse Electric Company
5929 Carnegie Blvd.
Suite 500
Charlotte, North Carolina 28209

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health and Natural
Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. T. Richard Puryear
Owners Group (NCEMC)
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Mr. Fred Emerson
Nuclear Energy Institute
1776 I Street, NW., Suite 400
Washington, DC 20006