



March 12, 2001

L-2001-047
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Supplement to Proposed License Amendments
Application for Technical Specification Improvement to
Eliminate Requirements for Post-Accident Sampling Systems
Using the Consolidated Line Item Improvement Process

By letter L-2000-131, dated November 27, 2000, Florida Power and Light Company (FPL) requested to amend Facility Operating Licenses DPR-67 for St. Lucie Unit 1 and NPF-16 for St. Lucie Unit 2 by deleting Technical Specifications (TS) Section 6.8.4.e, "Post-accident Sampling," for St. Lucie Units 1 and 2 and thereby eliminating the requirement to have and maintain the post-accident sampling system (PASS) at St. Lucie Units 1 and 2. The proposed amendments were consistent with NRC approved Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler TSTF-366, "Elimination of Requirements for a Post Accident Sampling System (PASS)." The availability of the technical specification improvement was announced in the *Federal Register* on October 31, 2000, as part of the consolidated line item improvement process (CLIIP).

On February, 7, 2001, a telephone conversation between the NRC Project Manager and FPL resulted in an NRC request for additional information concerning the procedural location of contingency plans for obtaining and analyzing highly radioactive post-accident samples. In response to the NRC, FPL states that plant chemistry procedures will describe the contingency plans for obtaining and analyzing highly radioactive post-accident samples.

Due to possible refueling outage impact on procedure changes and personnel training, please issue the amendments to be effective on date of issuance and to be implemented within 120 days of receipt by FPL.


In accordance with 10 CFR 50.91, a copy of this letter is being forwarded to the State Designee for the State of Florida.

A 001

St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
L-2001-047 Page 2

Please contact us if there are any questions about this submittal.

Very truly yours,

A handwritten signature in black ink, appearing to read "Rajiv S. Kundalkar". The signature is fluid and cursive, with the first name "Rajiv" being more prominent.

Rajiv S. Kundalkar
Vice President
St. Lucie Plant

RSK/GAC

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. W. A. Passetti, Florida Department of Health