

March 22, 2001

Mr. C. Lance Terry  
Senior Vice President &  
Principal Nuclear Officer  
TXU Electric Company  
Attn: Regulatory Affairs Department  
P. O. Box 1002  
Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) UNITS 1 AND 2 -  
REQUEST FOR ADDITIONAL INFORMATION REGARDING SPENT FUEL  
STORAGE RACKS AND SPENT FUEL STORAGE CAPACITY  
(TAC NOS. MB0207 AND MB0208)

Dear Mr. Terry:

By letter dated October 4, 2000, you submitted proposed changes to the Technical Specifications (TSs) associated with spent fuel storage racks and spent fuel storage capacity at CPSES, Units 1 and 2. The proposed TSs changes, when approved, will allow installation of additional, high density, spent fuel storage racks and an increase in spent fuel storage capacity. The proposed changes are needed by August 31, 2001, in order to support the spring 2002 CPSES, Unit 2, refueling outage.

The Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in the October 4, 2000, letter. In order for the NRC staff to complete its evaluation, a response to the enclosed Request for Additional Information (RAI) is required. These questions supplement those sent to you in our letter dated March 14, 2001.

The contents of this RAI have been discussed with Mr. D. Woodland of your staff on March 19, 2001, and a response time frame of ninety (90) days from receipt of this letter, was agreed to. If for any reason this date becomes unreasonable, please contact me at your earliest opportunity.

Sincerely,

**/RA/**

David H. Jaffe, Senior Project Manager, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Request for Additional Information

cc w/encl: See next page

March 22, 2001

Mr. C. Lance Terry  
Senior Vice President &  
Principal Nuclear Officer  
TXU Electric Company  
Attn: Regulatory Affairs Department  
P. O. Box 1002  
Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) UNITS 1 AND 2 -  
REQUEST FOR ADDITIONAL INFORMATION REGARDING SPENT FUEL  
STORAGE RACKS AND SPENT FUEL STORAGE CAPACITY  
(TAC NOS. MB0207 AND MB0208)

Dear Mr. Terry:

By letter dated October 4, 2000, you submitted proposed changes to the Technical Specifications (TSs) associated with spent fuel storage racks and spent fuel storage capacity at CPSES, Units 1 and 2. The proposed TSs changes, when approved, will allow installation of additional, high density, spent fuel storage racks and an increase in spent fuel storage capacity. The proposed changes are needed by August 31, 2001, in order to support the spring 2002 CPSES, Unit 2, refueling outage.

The Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in the October 4, 2000, letter. In order for the NRC staff to complete its evaluation, a response to the enclosed Request for Additional Information (RAI) is required. These questions supplement those sent to you in our letter dated March 14, 2001.

The contents of this RAI have been discussed with Mr. D. Woodland of your staff on March 19, 2001, and a response time frame of ninety (90) days from receipt of this letter, was agreed to. If for any reason this date becomes unreasonable, please contact me at your earliest opportunity.

Sincerely,

**/RAI/**

David H. Jaffe, Senior Project Manager, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Request for Additional Information

cc: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDlpm (SBlack)
PDIV-1 R/F	LBerry
RidsNrrPMRMoody	CHinson
RidsOgcRp	TAttard
RidsNrrDlpmLpdiv1 (RGramm)	
RidsAcrsAcnwMailCenter	
RidsRegion4MailCenter (KBrockman)	
RidsNrrPMDJaffe	
RidsNrrLADJohnson	
RPichumani	
DShum	

ACCESSION NO: ML010810469

OFFICE	PDIV-1/PM	PDIV-1/LA	PDIV-2/SC
NAME	DJaffe	DJohnson	RGramm
DATE	03/22/01	03/20/01	03/22/01

OFFICIAL RECORD COPY

Comanche Peak Steam Electric Station

cc:

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 2159  
Glen Rose, TX 76403-2159

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

Mrs. Juanita Ellis, President  
Citizens Association for Sound Energy  
1426 South Polk  
Dallas, TX 75224

Mr. Roger D. Walker  
Regulatory Affairs Manager  
TXU Electric  
P. O. Box 1002  
Glen Rose, TX 76043

George L. Edgar, Esq.  
Morgan, Lewis & Bockius  
1800 M Street, N.W.  
Washington, DC 20036-5869

Honorable Dale McPherson  
County Judge  
P. O. Box 851  
Glen Rose, TX 76043

Office of the Governor  
ATTN: John Howard, Director  
Environmental and Natural  
Resources Policy  
P. O. Box 12428  
Austin, TX 78711

Arthur C. Tate, Director  
Division of Compliance & Inspection  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

Jim Calloway  
Public Utility Commission of Texas  
Electric Industry Analysis  
P. O. Box 13326  
Austin, TX 78711-3326

REQUEST FOR ADDITIONAL INFORMATION  
REGARDING SPENT FUEL STORAGE RACKS AND SPENT FUEL STORAGE CAPACITY  
TXU ELECTRIC, ET. AL.  
COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2  
DOCKET NOS. 50-445 AND 50-446

Plant Systems Branch (SPLB)

- SPLB-4      The submittal (Reference 1) states that cranes to be used to move the spent fuel racks will have a suitably rated capacity. Discuss the design capacity of the lifting system (the spent fuel rack handling crane and the Fuel Building overhead crane including any special lifting and rigging devices used to handle and lift the racks), and any testing criteria that is used to support and verify the reliability of the system and the associated devices. Also cite the source of the criteria (e.g., state whether the single failure proof crane is in accordance with NUREG-0554 (Reference 2)).
- SPLB-5      If the crane is not a single failure proof crane in accordance with NUREG-0554, discuss the potential impact of a load drop onto the liner of the spent fuel pool and any compensatory measures that would be implemented to minimize and manage the damage from the drop, including, the capability of the leak detection system to limit any leaks, and the capabilities to provide adequate makeup to avoid uncovering the fuel stored in the spent fuel pools.
- SPLB-6      Describe the safe load path for the transfer of the spent fuel racks from the point of receipt and unloading to the point of staging and for the installation of the spent fuel racks.
- SPLB-7      Reference 1 discusses how the proposed changes affect the design bases events regarding the drop of a fuel cask or a tornado. Discuss the impact of this change with regard to the potential drop of a spent fuel storage rack onto a rack with stored fuel.

References:

1. Letter dated October 4, 2000, from James J. Kelley, Jr., TXU Electric to U.S. NRC, "Comanche Peak Steam Electric Station (CPSES) - License Amendment Request (LAR) 00-05 - Revision to Technical Specification - Spent Fuel Assembly Storage Racks and Fuel Storage Capacity" - TXX-00144.
2. NUREG-0554, "Single-Failure-Proof Cranes for Nuclear Power Plants," May 1979