



Carolina Power & Light Company
PO Box 165
New Hill NC 27562

James Scarola
Vice President
Harris Nuclear Plant

SERIAL: HNP-98-158
10 CFR 50.90

DEC - 7 1998

DEC 15 1998

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
RETYPE TECHNICAL SPECIFICATION PAGES FOR SPENT FUEL POOL WATER
LEVEL AND REVISED FUEL HANDLING ACCIDENT ANALYSES

Dear Sir or Madam:

On September 1, 1998, Carolina Power & Light Company (CP&L) requested a Licensed Amendment to revise the Harris Nuclear Plant (HNP) Technical Specifications (TS) 3/4.9.11 related to "Water Level - New and Spent Fuel Pools." As a result of a recently issued License Amendment, CP&L is submitting a retyped TS page which supersedes a page included in the September 1, 1998 submittal.

On October 20, 1998, the NRC issued License Amendment No. 84 to the HNP TS, which revised multiple TS pages as a result of changes to TS 3.0.4 and 4.0.4, "Limiting Conditions for Operation and Surveillance Requirements." Issuance of Amendment 84 independently affected one page, (3/4 9-13), from the September 1, 1998 request, which is currently under NRC review. Enclosure 1 contains the retyped TS page which incorporates changes resulting from the issuance of Amendment No. 84.

Please refer any questions regarding this matter to Mr. J. H. Eads at (919) 362-2646.

Sincerely,

MSE/twk

Enclosure

c: Mr. J. B. Brady (NRC Senior Resident Inspector, HNP)
Mr. S. C. Flanders (NRR Project Manager, HNP)
Mr. M. Fry (Acting Director N.C. DEHNR)
~~Mr. J. A. Royce~~ (NRC Regional Administrator, Region II)

24
3/1/99

bc:

Ms. D. B. Alexander
Mr. G. E. Attarian
Mr. R. H. Bazemore
Mr. H. K. Chernoff
Mr. B. H. Clark
Mr. W. F. Conway
Mr. G. W. Davis
Mr. R. J. Field
Mr. K. N. Harris
Ms. L. N. Hartz
Mr. W. J. Hindman
Mr. C. S. Hinnant

Mr. G. J. Kline
Ms. W. C. Langston
Mr. R. D. Martin
Mr. J. W. McKay
Mr. P. M. Odom
Mr. W. S. Orser
Mr. P. M. Sawyer
Mr. J. M. Taylor
Mr. C. A. VanDenburgh
Licensing File(s)
Nuclear Records

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
RETYPE TECHNICAL SPECIFICATION PAGES FOR
SPENT FUEL POOL WATER LEVEL AND REVISED FUEL
HANDLING ACCIDENT ANALYSES

RETYPE TS PAGE

3/4 9-13

REFUELING OPERATIONS

3/4.9.11 WATER LEVEL - NEW AND SPENT FUEL POOLS

LIMITING CONDITION FOR OPERATION

3.9.11 At least 23 feet of water shall be maintained over the top of fuel rods within irradiated fuel assemblies seated in the storage racks. |

APPLICABILITY: Whenever irradiated fuel assemblies are in a pool.

ACTION:

- a. With the requirements of the above specification not satisfied, suspend all movement of fuel assemblies and crane operations with loads in the affected pool area and restore the water level to within its limit within 4 hours.
- b. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.11 At least once per 7 days, when irradiated fuel assemblies are in a pool, the water level in that pool shall be determined to be at least its minimum required depth.