

3.5 LIMITING CONDITION FOR OPERATIONS

3.5 CORE AND CONTAINMENT COOLING SYSTEMS

Applicability:

Applies to the operational status of the Emergency Cooling Subsystems.

Objective:

To assure adequate cooling capability for heat removal in the event of a loss-of-coolant accident or isolation from the normal reactor heat sink.

Specification:

A. Core Spray and Low Pressure Coolant Injection

1. Except as specified in Specifications 3.5.A.2 through 3.5.A.4 below and 3.5.H.3 and 3.5.H.4, both Core Spray and the LPCI Subsystems shall be operable* whenever irradiated fuel is in the reactor vessel and prior to a reactor startup from the cold shutdown condition.

*Note: During Hot Shutdown, LPCI subsystems may be considered OPERABLE during alignment and operation for decay heat removal with reactor vessel pressure less than the RHR shutdown cooling permissive pressure, if capable of being manually realigned and not otherwise inoperable.

4.5 SURVEILLANCE REQUIREMENT

4.5 CORE AND CONTAINMENT COOLING SYSTEMS

Applicability:

Applied to periodic testing of the emergency cooling subsystems.

Objective:

To verify the operability of the core containment cooling subsystems.

Specification:

A. Core Spray and Low Pressure Cooling Injection

Surveillance of the Core Spray and LPCI Subsystems shall be performed as follows.

1. General Testing

<u>Item</u>	<u>Frequency</u>
a. Simulated Automatic Actuation Test	Each re-fueling outage
b. Operability testing of pumps and valves shall be in accordance with Specification 4.6.E.	
c. Flow Rate Test-Core Spray pumps shall deliver at least 3000 gpm (torus to torus) against a system head of 120 psig. Each LPCI pump shall deliver 7450 ± 150 gpm (vessel to vessel).	Each re-fueling outage

BASES:3.5 CORE AND CONTAINMENT COOLANT SYSTEMSA. Core Spray Cooling System and Low Pressure Coolant Injection System

This Specification assures that adequate standby cooling capability is available whenever irradiated fuel is in the Reactor Vessel.

Based on the loss-of-coolant analyses, the Core Spray and LPCI Systems provide sufficient cooling to the core to dissipate the energy associated with the loss-of-coolant accident and to limit the accident-caused core conditions as specified in 10CFR50, Appendix K. The analyses consider appropriate combinations of the two Core Spray Subsystems and the two LPCI Subsystems associated with various break locations and equipment availability in accordance with required single failure assumptions. (Each LPCI Subsystem consists of the LPCI pumps, the recirculation pump discharge valve, and the LPCI injection valve which combine to inject torus water into a recirculation loop.)

The LPCI System is designed to provide emergency cooling to the core by flooding in the event of a loss-of-coolant accident. This system is completely independent of the Core Spray System; however, it does function in combination with the Core Spray System to prevent excessive fuel clad temperature. The LPCI and the Core Spray Systems provide adequate cooling for break areas up to and including the double-ended recirculation line break without assistance from the high pressure emergency Core Cooling Subsystems.

Specification 3.5.A.1 is modified by a Note that allows LPCI subsystems to be considered OPERABLE during alignment and operation for decay heat removal with reactor pressure less than the RHR shutdown cooling permissive pressure, if capable of being manually realigned (remote) to the LPCI mode and not otherwise inoperable. This allows operation in the RHR shutdown cooling mode during Hot Shutdown, if necessary.

The intent of these specifications is to prevent startup from the cold condition without all associated equipment being operable. However, during operation, certain components may be out of service for the specified allowable repair times. Assurance that the systems will perform their intended function is obtained from the results of the pump and valve testing performed in accordance with ASME Section XI requirements referenced in Specification 4.6.E. Whenever one redundant system is inoperable, the potential for extended operation with two subsystems inoperable is reduced by requiring that the redundant subsystem be tested within 24 hours.

B. and C. Containment Spray Cooling Capability and RHR Service Water System

The containment heat removal portion of the RHR System is provided to remove heat energy from the containment in the event of a loss-of-coolant accident. For the flow specified, the containment long-term pressure is limited to less than 5 psig and, therefore, the flow is more than ample to provide the required heat removal capability. Reference: Section 14.6.3.3.2 FSAR.

Each Containment Cooling Subsystem consists of two RHR service water pumps, 1 heat exchanger, and 2 RHR (LPCI) pumps. Either set of equipment is capable of performing the containment cooling function. In fact, an analysis in Section 14.6 of the FSAR shows that one subsystem consisting of 1 RHR service water pump, 1 heat exchanger, and 1 RHR pump has sufficient capacity to perform the cooling function. Assurance that the systems will perform their intended function is obtained from the results of the pump and valve testing performed in accordance with ASME Section XI requirements referenced in Specification 4.6.E. Whenever one redundant system is inoperable, the potential for extended operation with two subsystems inoperable is reduced by requiring that the redundant subsystem be tested within 24 hours.