

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

April 2, 2001

Director of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, DC 20555-0001

Serial No.: 01-199  
NLOS/MM  
Docket No.: 50-339  
License No.: NPF-7


Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**NORTH ANNA POWER STATION UNIT 2**  
**STEAM GENERATOR TUBE PLUGGING REPORT**

Planned inservice inspection of the North Anna Unit 2 "C" steam generator was completed during the spring 2001 refueling outage. In accordance with North Anna Power Station Technical Specifications, Surveillance Requirement 4.4.5.5.a, this letter provides notification of the steam generator tubes that were plugged during the outage. In steam generator "C" one tube (Row 43, Column 56) was administratively plugged. The tube contained a thirty percent through-wall volumetric indication at the fifth cold leg support plate. The indication coincided with one of the lands of the support plate and appears to be of mechanical origin. No other tube degradation was detected during this examination.

No new commitments are intended by this letter. If you have any questions, concerning these results, please contact us.

Very truly yours,



S. P. Sarver, Director  
Nuclear Licensing and Operations Support

cc: U. S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth St., SW, Suite 23 T85  
Atlanta, GA 30303-8931

Mr. M. J. Morgan  
NRC Senior Resident Inspector  
North Anna Power Station

A001