

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.6 -----NOTE----- Only required to be met in MODES 1, 2 and 3. -----</p> <p>Perform leakage rate testing for each primary containment purge valve with resilient seals.</p>	184 days
<p>SR 3.6.1.3.7 Verify the isolation time of each MSIV is ≥ 3 seconds and ≤ 5 seconds.</p>	In accordance with the Inservice Testing Program
<p>SR 3.6.1.3.8 Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.</p>	24 months
<p>SR 3.6.1.3.9 Verify a representative sample of reactor instrumentation line EFCVs actuate to check flow on a simulated instrument line break.</p>	24 months
<p>SR 3.6.1.3.10 Remove and test the explosive squib from each shear isolation valve of the TIP System.</p>	24 months on a STAGGERED TEST BASIS

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.6 -----NOTE----- Only required to be met in MODES 1, 2 and 3. -----</p> <p>Perform leakage rate testing for each primary containment purge valve with resilient seals.</p>	184 days
<p>SR 3.6.1.3.7 Verify the isolation time of each MSIV is ≥ 3 seconds and ≤ 5 seconds.</p>	In accordance with the Inservice Testing Program
<p>SR 3.6.1.3.8 Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.</p>	24 months
<p>SR 3.6.1.3.9 Verify a representative sample of reactor instrumentation line EFCVs actuate to check flow on a simulated instrument line break.</p>	24 months

(continued)