

April 12, 2001

Mr. William A. Eaton
Vice President, Operations GGNS
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - REQUEST FOR ADDITIONAL
INFORMATION RE: REVISION OF TECHNICAL SPECIFICATIONS FOR
EMERGENCY DIESEL GENERATOR LUBE OIL INVENTORY
(TAC NO. MB0423)

Dear Mr. Eaton:

The staff is reviewing your request dated October 24, 2000 (GNRO-2000/00060) for revision of Grand Gulf Nuclear Station (GGNS) Technical Specifications for the Emergency Diesel Generator Lube Oil System inventory. Based on this review, the Plant Systems Branch has developed the enclosed request for additional information (RAI).

It is requested that you provide a response to the enclosed RAI within 60 days of receipt of this letter. This response schedule was discussed with Mr. Lonnie Daughtery of your staff on April 4, 2001, who indicated that GGNS will be able to meet this schedule. The staff appreciates the efforts expended with respect to this matter.

If you have any questions regarding this issue, please call me at 301-415-2623.

Sincerely,

/RA/

S. Patrick Sekerak, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosure: RAI

cc w/encl: See next page

Grand Gulf Nuclear Station

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Winston & Strawn
1400 L Street, N.W. - 12th
Floor Washington, DC 20005-3502

Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, MS 39209

President
Claiborne County
Board of Supervisors
P. O. Box 339
Port Gibson, MS 39150

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 399
Port Gibson, MS 39150

General Manager, GGNS
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, LA 70804-9005

State Health Officer
State Board of Health
P. O. Box 1700
Jackson, MS 39205

Office of the Governor
State of Mississippi
Jackson, MS 39201

Attorney General
Asst. Attorney General
State of Mississippi
P. O. Box 22947
Jackson, MS 39225

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Director, Nuclear Safety Assurance
Entergy Operations, Inc.
P.O. Box 756
Port Gibson, MS 39150

April 12, 2001

Mr. William A. Eaton
Vice President, Operations GGNS
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - REQUEST FOR ADDITIONAL
INFORMATION RE: REVISION OF TECHNICAL SPECIFICATIONS FOR
EMERGENCY DIESEL GENERATOR LUBE OIL INVENTORY
(TAC NO. MB0423)

Dear Mr. Eaton:

The staff is reviewing your request dated October 24, 2000 (GNRO-2000/00060) for revision of Grand Gulf Nuclear Station (GGNS) Technical Specifications for the Emergency Diesel Generator Lube Oil System inventory. Based on this review, the Plant Systems Branch has developed the enclosed request for additional information (RAI).

It is requested that you provide a response to the enclosed RAI within 60 days of receipt of this letter. This response schedule was discussed with Mr. Lonnie Daugherty of your staff on April 4, 2001, who indicated that GGNS will be able to meet this schedule. The staff appreciates the efforts expended with respect to this matter.

If you have any questions regarding this issue, please call me at 301-415-2623.

Sincerely,

/RA/

S. Patrick Sekerak, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PDIV-1 r/f

RidsAcrsAcnwMailCenter

RidsNrrPmPSekerak

LBerry

RidsNrrDlpm (SBlack)

RidsOgcRp

RidsNrrDlpmLpdiv1 (RGramm)

RidsNrrLADJohnson

RidsRgn4MailCenter (KBrockman)

DShum, SPLB

TEaton, SPLB

Accession No.: ML011020399

OFFICE	PDIV-1/PM	PDIV-1/LA	PDIV-1/SC
NAME	PSekerak:db	DJohnson	RGramm
DATE	4/12/01	4/12/01	4/12/01

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
RELATED TO EMERGENCY DIESEL GENERATOR LUBE OIL SYSTEM INVENTORY
GRAND GULF NUCLEAR STATION
DOCKET NO. 50-416
(REF. GNRO-2000/00060)

Plant Systems RAI Questions:

- 1.0 Discuss the provisions established, or to be established, in the plant operating procedures to ensure that Division III emergency diesel generator (EDG) engines will have sufficient lube oil for seven days of operation following a design basis accident. Information should include:
- a. A detailed description to show how the lube oil inventory in the EDGs will be monitored.
 - b. A detailed description to show how the lube oil will be transferred from the skid mounted barrels to the EDGs.

Fire Protection RAI Questions:

- 2.0 The licensee stated in the license amendment request that their fire hazard analysis (FHA) was updated to ensure that the existing design requirements were still valid, and that the ability to achieve and maintain safe shutdown was not adversely affected. Lube oil fires are typically rapidly developing fires, with high rates of heat release, that produce large amounts of dense smoke. Early detection and prompt automatic suppression are key to controlling this type of fire. Therefore, since the FHA update was not included in the license amendment request, please respond to the following staff concerns:
- a. Provide the staff with a copy of the updated portions of the FHA which assessed that the existing design requirements were still valid, and that the ability to achieve and maintain safe shutdown was not adversely affected for Division I, II, and III EDGs, and for the lube oil storage skid.

ENCLOSURE

- b. Provide either a detailed diagram or detailed written description to describe the relationship of the lube oil storage skid and the Division I, II, and III EDGs to the following:
- combustibles
 - potential ignition/heat sources
 - safe shutdown equipment or cables
 - rated fire barriers/doors
 - automatic suppression and detection systems
 - manual fire protection features
 - ventilation systems
- c. Discuss what measures are in place to prevent or detect oil leakage from the skid-mounted barrels. Furthermore, in the event that the skid-mounted barrels leak oil, describe all actions or built-in features that would minimize the potential for a fire and limit the ability of the oil to spread beyond the lube oil storage skid.