

4/5/99 Dick Dudley
SFPa at Decommissioned Plants

* No DGs (not Class 1A)

~~Some~~ Some have Diesel driven f.p.

* licensee's choice on what is still in FSAR.

Some change over to gravity feed to SFP.

No standard format, GDC, or RG on SFPa decom.

* No TS requirements of levels, temps, radiation w/o negotiations. Comm says have to implement backfit rule at decom.

* Staffing at decom plant.

eliminate licensed Rx operators; instead they train operators on handling fuel + fuel pool.

Typically operators (neither better nor young ones).
1000 \rightarrow 100 staff typical (2-5 years?)

* No known requirement of operators having to tour plant. As level of activity \downarrow , less likely.

* Dismantlement - One option

* PNs @ decom of reactors going out to look at 50.59s.
PNs doing much (40%) of inspection. Have PNs in NRR until all fuel out of wet storage. NRR maintains PM until license done

* Resident Insp - 1 immediately, 0 w/in a year of permanent shutdown.

B/109

②

4/5/99

* Licensee can reconfigure if SFP cooling can be changed. Done under 50.54. Not looked at by NRC technical staff.

* Maintenance - No requirement for licensees to maintain electricians, etc. H's only on day shift.

* Lot of Decomm licensees go to 4 - 10hr days. No one but shillator on weekends + nights.

* Typically switchyard controlled by grid needs, not plant, so don't change. 2 sources in plant?

* Probably don't have to maintain emerg. DC - interruptible DC power @ decomm Bx. Dick will check on this.

* IE Bulletin + Gb - Shortly after shutdown utility comes in w/ commitment change letters. Only FR looks at it. He only follows up w/ tech staff for high priority stuff in PM = expect

* Fire suppression - Doesn't need to be maintained. Cold shutdown in assumed to be enough. No specific Have a RC out for comment on fire just at decomm. Fairly prescriptive.

to fill SFP
one engineering

on agreed (?) ~~etc~~ have 2 ways (normal) + one quantity feed. No to fire wants on this. Normal VERY low volume (e.g. 5gpm) normal

(3) 4/5/99

* App J does not apply once permanently defueled reactor. Spent fuel buildings in PWR have rolling doors + roof hatches.

* Rancho has insect infestations

* Reporting - 50.72, 50.73 Seldom see writeups. Still applies if violate T.S.

* Dispute w/industry and w/IR NRC on whether Maint Rule applies to decommissioned plants. Not resolved. Risk-informing Maint Rule might significantly alter this.

Diane - HVAC gone once iodine gone.
SGTS gone after 1st 6 months in proposed T.S.
No one has proposed TS. Negotiate for less.