

4/12/99

Outline of SPLB/BOP input:

- ☐ Description of accident scenarios
 - ☐ Extended loss of SFP cooling
 - ☐ Rapid reduction in SFP level (e.g., siphon) w/ loss of SFP cooling
 - ☐ Structural failure due to external phenomena (e.g., seismic)
 - ☐ Cask or heavy load handling
 - ☐ Spent fuel handling accident
 - ☐ Loss of offsite power
 - ☐ Aircraft
 - ☐ Tornado missile
- ☐ Comparison/Evaluation of design considerations for wet ISFSI
 - ☐ defense in depth
 - ☐ minimum decay time
 - ☐ design events
 - ☐ controls
- ☐ Evaluation of RTM-96 actions for spent fuel pool damage
 - ☐ Actions based on GSI 82 studies
 - ☐ Assumes 24 hour response capability (full EP?)
- ☐ Current Analyses: Evaluation of conclusions from previous studies on spent fuel heatup analysis compared to current operating practices (coordinate with SRXB)
 - ☐ NUREG/CR-4982
 - ☐ NUREG/CR-0649
- ☐ Discussion of possible controls and provide recommendation
 - ☐ Detection, Mitigation, and Prevention Features Available
 - ☐ SFP level indication
 - ☐ During and in preparation of fuel movement (STS)
 - ☐ During periods of no fuel movement (suggested PDTs)
 - ☐ SFP temperature limit
 - ☐ SFP cooling and cleaning system
 - ☐ Power sources
 - ☐ SFP coolant chemistry (suggested PDTs program)
 - ☐ Radiation monitors
 - ☐ SFP makeup source
 - ☐ SFP liner leak detection
- ☐ Recommend criteria or acceptable methods for exemptions, if possible

B/129