

**From:** Joseph Staudenmeier *NRK*  
**To:** Glenn Kelly *NRK*  
**Date:** Tue, Aug 15, 2000 1:54 PM  
**Subject:** revised tables with more assumptions listed

**CC:** George Hubbard

*B/3/9*

The times calculated are in hours for an adiabatic heatup from 30 C to 800 C with no oxidation heat source. All Adiabatic Heatups are based on a Peaking Factor of 1.5. There is a large difference for the 24 hour heatup decay time between a peaking factor of 1 and a peaking factor of 1.5. The decay heats at these burnup values are interpolations or extrapolations of the decay heat from NUREG/CR-5625. The thermal mass of the BWR fuel is modeled as 9x9 fuel assemblies and the associated fuel rack structure. The mass per assembly is 170 kg UO<sub>2</sub>, 97.5 kg Zirconium and 42.4 kg stainless steel. The thermal mass PWR fuel is modeled 17x17 fuel assemblies and the associated rack structure. The mass per assembly is kg UO<sub>2</sub>, 101 kg Zirconium, and 68.6 kg stainless steel. Temperature dependent values of the specific heat are used for steel, zircaloy, and UO<sub>2</sub>.

#### Adiabatic Heatup Time at 1 Year

Burnup	PWR	BWR
50	4.5	8.1
55	4.1	7.4
60	3.8	6.8
70	3.2	5.8
80	2.8	5.1

#### Adiabatic Heatup Time at 2 Years

Burnup	PWR	BWR
50	8.2	14.3
55	7.5	12.9
60	6.9	11.9
70	5.9	10.2
80	5.2	8.9

#### Adiabatic Heatup Time at 5 Years

Burnup	PWR	BWR
50	20.5	32.0
55	18.6	29.1
60	17.1	26.7
70	14.6	22.8
80	12.8	20.0

#### Adiabatic Heatup Time at 10 Years

Burnup	PWR	BWR
50	31.4	46.4
55	28.5	42.3
60	26.1	38.7
70	22.4	33.2
80	19.6	29.0

**Decay Time in Years for a 10 Hour Adiabatic Heatup Time**

Burnup	PWR	BWR
50	2.5	1.4
55	2.7	1.5
60	3.0	1.7
70	3.5	2.0
80	3.9	2.4

**Decay Time in Years for a 24 Hour Adiabatic Heatup Time**

Burnup	PWR	BWR
50	6.4	3.6
55	7.3	4.0
60	8.7	4.4
70	12.3	5.5
80	17.1	6.7

**Spent Fuel Pool Heatup and Boiloff Time in hours to 3 feet Above Active Fuel.** Fuel Burnup is 62.5 Gwd/MTU with a 2 year cycle time. The decay heat at this value of burnup is an extrapolation of the decay heat from NUREG/CR-5625. The BWR pool holds 4200 9x9 fuel assemblies. The pool surface area is 105.7 square meters. The PWR pool holds 965 17x17 fuel assemblies. The pool surface area is 61.3 square meters. The pools have a water depth of 11.54 meters and are assumed to be at an initial temperature of 30 C. An estimated volume fraction of 0.5 of water in the racks and assemblies was used. Errors in this value can impact the heatup time portion of the heatup and boiloff calculation. The specific heat of water was assumed to be constant at 4200 J/kg for the heatup calculation. Temperature dependent properties were used for steel, zircaloy, and UO<sub>2</sub>. The enthalpy change due to vaporization used in the boiloff calculation is 2257 KJ/kg.

Decay Time	PWR	BWR
1 year	195	253
2 year	272	337
5 year	400	459
10 year	476	532