

April 17, 2001

Mr. S. K. Gambhir
Division Manager - Nuclear Operations
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, NE 68023-0399

SUBJECT: CORRECTION TO AMENDMENT NO. 195 - FORT CALHOUN STATION
(TAC NO. MA9653)

Dear Mr. Gambhir:

On March 1, 2001, the NRC issued Amendment No. 195 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. The amendment changed the technical specifications and associated Bases to allow the installation of ABB Combustion Engineering leak tight sleeves as an alternative tube repair method to plugging defective steam generator tubes. The amendment was in response to your application dated July 28, 2000, as supplemented by letter dated December 14, 2000.

Due to an administrative error, pages 3-88 and 3-89 contained typographical errors (i.e., in TS 3.17(3)(i)(3), "fails" should be "falls" and in TS 3.17(4)(i), "second" should be "secondary." Enclosed are corrected pages 3-88 and 3-89. We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

L. Raynard Wharton, Project Manager, Section 2
Project Directorate IV and Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: TS Pages 3-88 and 3-89

cc w/encl: See next page

April 17, 2001

Mr. S. K. Gambhir
Division Manager - Nuclear Operations
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, NE 68023-0399

SUBJECT: CORRECTION TO AMENDMENT NO. 195 - FORT CALHOUN STATION
(TAC NO. MA9653)

Dear Mr. Gambhir:

On March 1, 2001, the NRC issued Amendment No. 195 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. The amendment changed the technical specifications and associated Bases to allow the installation of ABB Combustion Engineering leak tight sleeves as an alternative tube repair method to plugging defective steam generator tubes. The amendment was in response to your application dated July 28, 2000, as supplemented by letter dated December 14, 2000.

Due to an administrative error, pages 3-88 and 3-89 contained typographical errors (i.e., in TS 3.17(3)(i)(3), "fails" should be "falls" and in TS 3.17(4)(i), "second" should be "secondary." Enclosed are corrected pages 3-88 and 3-89. We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

L. Raynard Wharton, Project Manager, Section 2
Project Directorate IV and Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: TS Pages 3-88 and 3-89

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsNrrDlpmPdiv (SRichards)

RidsNrrPMRWharton

RidsNrrLAEPeyton

RidsOgcRp

RidsAcrsAcnwMailCenter

RidsRgn4MailCenter (CMarschall,DBujol,LHurley)

RidsNrrDripRtsb (WBeckner)

RidsNrrDeEmcb (WBateman)

BFu

GHill (2)

*For previous concurrences

see attached ORC

ACCESSION NO.: ML011070111

PACKAGE: ML011070115

ENCLOSURE: ML011070422

OFFICE	PDIV-2/PM	PDIV-2/LA	OGC*	PDIV-2/SC
NAME	RWharton	EPeyton:esp	MYoung	SDembek
DATE	4/17/01	4/16/01	4/6/01	4/16/01

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, NE 68008

Mr. Wayne Walker, Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 309
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Mr. John Fassell, LLRW Program Manager
Health and Human Services
Regulation and Licensure
Consumer Health Services
301 Centennial Mall, South
P. O. Box 95007
Lincoln, Nebraska 68509-5007

Mr. Richard P. Clemens
Manager - Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, NE 68023

Mr. Mark T. Frans
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, NE 68023-0399