

ADMINISTRATIVE CONTROLS

PROCEDURES AND PROGRAMS

6.7.6 (Continued)

d. Backup Method for Determining Subcooling Margin

A program that will ensure the capability to accurately monitor the Reactor Coolant System subcooling margin. This program shall include the following:

- 1) Training of personnel, and
- 2) Procedures for monitoring.

e. NOT USED

f. Accident Monitoring Instrumentation

A program which will ensure the capability to monitor plant variables and systems operating status during and following an accident. This program shall include those instruments provided to indicate system operating status and furnish information regarding the release of radioactive materials (Category 2 and 3 instrumentation as defined in Regulatory Guide 1.97, Revision 3)* and provide the following:

- 1) Preventive maintenance and periodic surveillance of instrumentation,
- 2) Preplanned operating procedures and backup instrumentation to be used if one or more monitoring instruments become inoperable, and
- 3) Administrative procedures for returning inoperable instruments to OPERABLE status as soon as practicable.

*Seabrook has taken exception to the categorization of instrumentation provided in Regulatory Guide 1.97, Revision 3. The Seabrook exceptions are provided in FSAR Table 7.5-1, which has been reviewed by the NRC staff in SER Supplement No. 5.